



# Telegram

253P EDT FEB 14 74 AA231

AAE334(1450)(2-049489E045)PD 02/14/74 1448

ICS IPMBNGZ CSP

DUPLICATE OF TELEPHONED TELEGRAM

4503

2057298316 TDBN ATHENS AL 73 02-14 0248P EDT

PMS US ATOMIC ENERGY COMMISSION, TLX OR FONE

REGION II DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE

ST NORTHWEST

ATLANTA GA 30303

TR  
25.420p mail

BFAO-7410T DURING ROUTINE SURVEILLANCE TESTING ON FEBRUARY 13

1974 PRESSURE SWITCHES PDIS1-36B AND 1-50A MAIN STEAM LINE HIGH

FLOW WERE FOUND OUTSIDE TECHNICAL SPECIFICATIONS TRIP LEVEL

SETTINGS OF LESS THAN OR EQUAL TO 140 PERCENT FLOW WHICH CORRESPONDS

TO 108.75 PSID THE SWITCHES OPERATED AT 109.7 AND 109.0 PSID

RESPECTIVELY THE SWITCHES WERE RESET TO A SET POINT OF 106.5

PSID AND CHECKED FOR REPEATABILITY THE REACTOR WAS IN COLD SHUTDOWN

TENNESSE VALLEY AUTHORITY H J GREEN BROWNS FERRY NUCLEUR PLANT

F-1201 (R5-69)

8311070084 740419  
PDR ADOCK 05000259  
S PDR