



Telegram

TBB157(1331)(2-033150E044)PD 02/13/74 1331

ICS IPMBNGZ CSP

2057298316 DBN ATHENS AL 34 02-13 0131P EDT

FON 4045264503

US ATOMIC ENERGY COMMISSION REGION II DIRECTORATE OF REGULATORY
OPERATIONS

230 PEACH TREE ST NW

ATLANTA GA 30303

SUBJECT BFA0-749T AT APPROXIMATELY 530PM FEBRUARY 12, 1974 PRESSURE
RELIEF VALVE PCV 1-41 FAILED TO RESEAT AFTER HAVING LIFTED AT
ITS SET POINT OF 1080 PSIG THE REACTOR WAS IN THE SHUTDOWN CONDITION

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

F-1201 (R5-89)

8311070097 740306
PDR ADOCK 05000259
S PDR

Handwritten:
50-259