



Telegram

427A EDT JAN 30 74 AA014

AAC043(0410)(2-050546E030)PD 01/30/74 0410

ICS IPMMTZZ CSP

DUPLICATE OF TELEPHONED TELEGRAM

526-4503

6092342900 RELAY TDMT MOORESTOWN NJ 01-30 0410A EDT

PMS TBD283(1704)(2-033323E029)PD 01/29/74 1701 ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 44 01-29 0501P EDT

MS ATOMIC ENERGY COMMISSION REGION 2 DIRECTORATE REGULATORY OPERATION

S 230 PEACHTREE ST NW

ATLANTA GA 30303

ON JANUARY 28 1974 WHILE PERFORMING ROUTINE SURVEILLANCE TESTING
THE REACTOR AND TURBINE BUILDING VENTILATION RADIATION MONITOR
WAS REMOVED FROM SERVICE FOR A PERIOD OF 5 HOURS WITHOUT PROVIDING
SUBSTITUTE MONITORING AS REQUIRED BY TECHNICAL SPECIFICATION

3.8.B-8, THE REACTOR WAS OPERATING APPROXIMATELY 45-0/0 POWER

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

3F-1201 (RS-69)

by 1027

30th 20,0400 C.V. Mailed

8311070106 740207
PDR ADOCK 05000259
S PDR

Insert
50259