

Telegram

637P EDT JAN 18 74 AC199

DUPLICATE OF TELEPHONED TELEGRAM

AAE259(1729)(2-149922E018)PD 01/18/74 1729

ICS IPMBNGZ CSP

526 9503

2057298316 TDBN ATHENS AL 51 01-18 0529P EDT

PMS US ATOMIC ENERGY COMMISSION, WUX

DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST NORTHWEST
ATLANTA GA 30303

BFAO-745T DURING ROUTINE SURVEILLANCE TESTING OF STANDBY LIQUID
CONTROL SYSTEM ON JANUARY 17 1974 THE SHAFT SEAL PACKING ON
IB SLC PUMP LEAKED EXCESSIVELY. 1A PUMP OPERATED SATISFACTORILY.
B PUMP WAS REMOVED FROM SERVICE. PACKING REPLACED THEN SATISFACTORILY
PASSED ITS SURVEILLANCE TEST. UNIT WAS OPERATING AT 50 PERCENT
POWER LEVEL.

H J GREEN BROWNS FERRY NUCLEAR PLANT
NNNN

Jan 21 68
By WMA m.c.l.p

SF-1201 (RIS-69)

8311080104 740125
PDR ADOCK 05000259
S PDR

Received
50-259