

TBC155 (1332) (2-091222E017) PD 01/17/74 1332

ICS IPMBNGZ CSP

2057293316 TQBN ATHENS AL 53 01-17 0132P EDT

FOR 4045264503 4045264503

US ATOMIC ENERGY COMMISSION

DIRECTORATE OF REGULATORY OPERATIONS 230 PEACH TREE ST NORTHWEST
ATLANTA GA 30303

SUBJECT BFA0-744T. ON 1-16-74 DURING ROUTINE SERVALENCE TESTING
OF "B" DIESEL GENERATOR THE ENGINE FAILED TO START ON CIRCUIT
NUMBER 1 BUT STARTED IN 9 SECONDS ON CIRCUIT NUMBER 2 PRELIMINARY
INVESTIGATION INDICATES THE TROUBLE TO BE IN THE ENGINE LEFT
BANK AIR START SYSTEM THE REACTOR WAS AT 50 PERCENT POWER

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN