

# Telegram

721A EDT JAN 11 74 AC01S

DUPLICATE OF TELEPHONED TELEGRAM

AAC 47(0723)(2-123118011)PD 01/11/74 0723

ICS IPMMTZZ CSP

6092342900 RELAY TDMT MOORESTOWN NJ 01-11 0723A EDT

PMS TDR 510(1736)(2-106430010)PD 01/10/74 1736 ICS IPBNGZ CSP

2057290016 TDR ATHENS AL 49 01-10 0536P EDT

US ATOMIC ENERGY COMMISSION PHONE 4045264500 REGION 2 DIRECTORATE  
OF REGULATORY OPERATIONS 230 PEACHTREE ST  
ATLANTA GA 30303

ON JANUARY 9 1974 AS A RESULT OF ROUTINE SURVEILLANCE TESTING  
ON THE LPCI LOGIC 2 REACTOR PRESSURE SWITCHES, PS-3-186A AND  
186B WERE FOUND VALVED OUT. THESE SWITCHES PROVIDE PERMISSIVE  
FOR THE ACTUATION OF LPCI BREAK DETECTION LOGIC. THE REACTOR  
WAS OPERATING AT APPROXIMATELY 50 PERCENT POWER

H J GREEN BFNP

NNNN

*Jan 11 1974  
HJG*

16-1201 (R5-07)

8311080128 740117  
PDR ADDCK 05000259  
S PDR

*Handwritten signature  
50259*