



Telegram

CB 9am

TBA320(1622) (2-235307E007)PD 01/07/74 1619

ICS IPMBNGZ CFP

2057298316 TBSN ATHENS AL 94 01-07 0419P EDT

FOR 4045264503

US ATOMIC ENERGY COMMISSION

REGION II DIRECTORATE OF REGULATORY OPERATIONS 230 PLACHEREE
ST NORTHWEST

ATLANTA GA-~~3030~~ 30309

SUBJECT BFA0-741 ON JANUARY 6 1974 DURING ACCELERATED SURVEILLANCE
TESTING REACTOR WATER LEVEL SWITCHES LIS-3-203 ABC AND D WERE
FOUND TO OPERATE OUTSIDE TECHNICAL SPECIFICATIONS SETPOINT LIMITS
THE TECHNICAL SPECIFICATIONS SETPOINT FOR HIGH LEVEL IS LESS
THAN OR EQUAL TO 583 INCHES AND FOR LOW LEVEL IS GREATER THAN
OR EQUAL TO 538 INCHES LIS-3-203 A AND B OPERATED AT 537 INCHES
AND 585 INCHES RESPECTIVELY AND LIS-3-203 C AND D OPERATED AT
537 INCHES AND 536 1/2 INCHES RESPECTIVELY THE REACTOR WAS AT

1201 (R)

APPROXIMATELY 50 PERCENT POWER 490 MW

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

OK 15 12 14 14

MF-1201 (RS-65)

8311080169 740115
PDR AD0CK 05000259
S PDR

Handwritten: 5725 9/260