

TBA248(1558)(2-096427E360)PD 12/26/73 1558

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 83 12-26 0358P EST

FON 4045264503

US ATOMIC ENERGY COMMISSION

DIRECTORATE OF REGULATORY OPERATIONS 230 PEACH TREE ST NORTHWEST
ATLANTA GA 30303

SUBJECT BFA0-7349T AT 3 PM ON DECEMBER 25 1973 REACTOR PRESSURE
RELIEF VALVE PCV-1-18 BELLOWS SEAL LEAKAGE ALARM INDICATING
LIGHT INDICATED BELLOWS LEAKAGE PCV-1-18 SERIAL NUMBER 35 SET
PRESSURE 1,090 PSIG WAS INSTALLED DURING THE UNIT OUTAGE LAST
WEEK THE ADS FUNCTION IS NOT IMPAIRED THIS VALVE SUCCESSFULLY
PASSED A CAPACITY FLOW TEST ON DECEMBER 24 1973 WITH NO INDICATED
PROBLEMS THE REACTOR WAS AT 50 PER CENT POWER LEVEL THERE ARE
NO OTHER KNOWN FAILED SAFETY OR RELIEF VALVES

H J GREEN BROWNS FERRY NUCLEAR PLANT

MF-1201 (RS-69)

8311080258 740104
PDR ADOCK 05000259
S PDR

Handwritten:
50259