

MGMATLA ATL
2-112934E354 12/20/73
ICS IPMBNGZ CSP
2057298316 MGM TDBN ATHENS AL 100 12-20 0541P EST
ZIP 30303



Mailgram



US ATOMIC ENERGY COMMISSION
REGION 2 DIRECTOR OF REGULATORY OPERATIONS 230 PEACHTREE ST NORTHWEST
ATLANTA GA 30303

BFAO 7347T ON DECEMBER 19 1973 DURING THE PERFORMANCE OF PRE-OPERATIO
NAL TESTS ON UNIT NUMBER TWO THE 2A RESIDUAL HEAT REMOVAL PUMP
TRIPPED WHILE POWERED FROM "A" DIESEL GENERATOR. AT 710PM ON
12 1973 THE "A" DIESEL GENERATOR WAS DECLARED INOPERABLE CAUSE
OF INOPERABILITY WAS THE FAILURE OF THE "A" DIESEL GENERATOR
TO THE SUPPLY STARTING POWER TO THE RHR PUMP

H J GREEN BFNP BROWNS FERRY NUCLEAR PLANT PO BOX 2000 DECATUR
AL 35601

1743 EST

MGMATLA ATL

8311080447 731228
PDR ADOCK 05000259
S PDR

Incident 58-259

RD
DEC 21 1973

Mailgram from Tennessee Valley Authority, H. J. Green,
dated December 20, 1973 - 50-259

DISTRIBUTION:

H. D. Thornburg (2)

RO:HQ (5)

DR Central Files

Regulatory Standards (3)

Directorate of Licensing (13)

PDR

Local PDR

NSIC

OIS, OR

State

RECEIVED

1974 JAN 3 AM 2 46

U.S. ATOMIC ENERGY COMM.
DIVISION OF COMPLIANCE