

Duke Power Company
Catawba Nuclear Generation Department
4800 Concord Road
York, SC 29745

D. L. REHN
Vice President
(803)831-3205 Office
(803)831-3426 Fax



DUKE POWER

June 20, 1995

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Catawba Nuclear Station, Unit 2
Docket No. 50-414
Special Report
Vibration and Loose Parts Monitoring System

On May 1, 1995, Channel 1, Lower Reactor Vessel Tube 4, was declared inoperable. The channel was evaluated on May 10, 1995 with no problem found. Data from May 23, 1995 also indicated that the channel was operating as expected by a healthy channel. However, the channel was not removed from the Technical Specification Action Item Log (TSAIL) and declared operable. Channel 2, Lower Reactor Vessel Tube 9, is operable and available to cover the collection region.

Since Channel 1 has been inoperable for more than thirty days, it is reportable to the NRC per Technical Specification 3.3.3.9. This report was due to the NRC on June 12, 1995; consequently, this report is being submitted eight days late.

Very truly yours,

Mark E. Patrick for
D.L. Rehn

LJR/SR062095 LPM

xc: S.D. Ebnetter, Regional Administrator
Region II

R.J. Freudenberger, Senior Resident Inspector

R.E. Martin, Senior Project Manager
ONRR

270005

JE22/10