



Telegram

1140A EST DEC 9 73 AC033

DUPLICATE OF TELEPHONED TELEGRAM

AAB040(1029)(2-160058E343)PD 12/09/73 1029

526.4503

ICS IPMMIZZ CSP

6092342900 TDMT MOORESTOWN NJ 12-09 1029A EST

PMS 2-118218E341 2057298316 TDBN ATHENS AL 12-7 500P EST, WUX

US ATOMIC ENERGY COMMISSION REGION II DIRECTORATE OF REGULATORY

OPERATIONS 230 PEACHTREE ST NORTHWEST

ATLANTA GA 30303

BFA0-7346T ON DEC 6 1973 DOING ROUTINE SURVEILLANCE TESTING

1 PRESSER DIFFERENTIAL SWITCH WAS FOUND TO EXCEED ITS LIMITS

OF EQUAL TO OR LESS THAN 2PSID THE SWITCH ACTUATED AT 2.2 PSID

THIS SWITCH IS USED IN THE LPCI BRAKE DETECTION LOGIC AND RECIRCULATI

NG PUMP RUNNING LOGIC THE REMAINING 7 SWITCHES WERE TESTED AND

FOUND TO BE OPERABLE

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

F-1201 (R5-67)

8311080468 731214
PDR ADOCK 05000259
S PDR