

MGMATLA ATL

2-118934E335 12/01/73

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 12-01 1214P EST
ZIP 3030

western union Mailgram



US ATOMIC ENERGY COMMISSION
REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACH TREE ST
NORTHWEST
ATLANTA GA 30303

ON NOVEMBER 30 1973 THE UNIT 1 CORE SPRAY SPARGER TO REACTOR
PRESSURE VESSEL ALARM DELTA P SWITCHES PDIS-75-28 AND 75-56
WERE FOUND OUTSIDE THEIR REQUIRED SET POINT THE REACTOR WAS
OPERATING WAS APPROXIMATELY 25 PERCENT POWER
H J GREEN BROWNS FERRY NUCLEAR PLANT PO BOX 2000 DECATUR ALABAMA
35601

1215 EST

MGMATLA ATL

8311080627 731130
PDR ADOCK 05000259
S PDR

*Wait
50259*