



Telegram

141P EST NOV 18 73 AB040

AAE036(1133)(2-119957E322)PD 11/18/73 1153

ICS IPMMTZZ CSP

6092342900 TDMT MOORESTOWN NJ 11-18 1133A EST

FMS 2-078515E320 2057298316 TDBN ATHENS AL 11-16 723P EST, WUX
US ATOMIC ENERGY COMMISSION REGION II DIRECTORATE OF REGULATORY
OPERATIONS 230 PEACHTREE ST NW

ATLANTA GA 30203

BFA07340T ON NOV 15 1973 DURING EXCELLERATED SURVEILLANCE TESTING
HPCI STEAM FLOW EXCESSIVE PRESSURE SWITCHES WERE FOUND TO OPERATE
OUTSIDE THE TECHNICAL SPECIFICATIONS SETPOINT OF LESS THAN OR
EQUAL TO 90 PSID PRESSURE SWITCHES PDIS-73-1A AND 1B WERE FOUND
TO OPERATE AT 92.5 AND 96.0 PSID RESPECTIVELY THE REACTOR WAS
AT 25 PERCENT THERMAL POWER

J F GROVES BROWNS FERRY NUCLEAR PLANT

NNNN

SF-1201 (RS-69)

Nov 19 W. S. Wright 10/10a
Nov 19 CB
11/20a markel

8311090155 731123
PDR ADOCK 05000259
S PDR