



# Telegram

145P EST NOV 18 73 AB042

DUPLICATE OF TELEPHONED TELEGRAM

AAC036(1131)(2-119924E322)PD 11/18/73 1131

ICS IPMMTZZ CSP

6092342900 TDMT MOORESTOWN NJ 11-18 1131A EST

PMS 2-078829E320 2057298316 TDBN ATHENS AL 11-16 717P EST, WUX

US ATOMIC ENERGY COMMISSION 230 PEACHTREE ST NW

ATLANTA GA 30303

THE BFA07339T ON NOV 15 1973 DURING EXCELLERATED SURVEILLANCE  
TESTING TURBINE CONDENSER LOW VACUUM PRESSURE SWICH PS-2-1B  
WAS FOUND TO OPERATE OUTSIDE THE TECHNICAL SPECIFITIONS SETPOINT  
OF GREATER THAN OR EQUAL TO 23 INCH MERCURY VACUUM THE SWITCH  
OPERATED AT 22.8 INCHES THE REACTOR WAS AT 25 PERCENT THERMAL  
POWER

J F ROVES BROWNS FERRY NUCLEAR PLANT

NNNN

*Nov 19 11:00 AM  
Nov 19 CB  
By 10214 mald*

BF-1201 (R5-69)

8311090172 731128  
PDR ADOCK 05000259  
S PDR