



Telegram

TBC125(1155)(2-231397E318)PD 11/14/73 1155

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 67 11-14 1155A EST

FON 4045264503

US ATOMIC ENERGY COMMISSION

REGION II DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE
ST NORTHWEST

ATLANTA GA 30303

SUBJECT BFA0-7335T AT APPROXIMATELY 3PM NOVEMBER 13 1973 IT
WAS RECOGNIZED THAT THE ACTUATION SIGNAL WHICH CAUSED THE MSIV'S
TO ISOLATE IN THE START UP MODE ON HIGH REACTOR WATER LEVEL
HAD BEEN DELETED FROM THE BFNP UNIT 1 DESIGN BUT NOT FROM THE
SFAR OR TECHNICAL SPECIFICATIONS THE REACTOR WAS PLACED IN THE
HOT STAND BY CONDITION MSIV'S SHUT AT 10:28PM NOVEMBER 13 1973

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

1201 (R5-69)

8311090454 731121
PDR ADOCK 05000259
S PDR