



Telegram

TBD241(1433)(2-065517E313)PD 11/09/73 1433

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 56 11-09 0233P EST

FON 4045264503

ATOMIC ENERGY COMMISSION

REGION II DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE *Suite 818*
ST NORTHWEST

ATLANTA GA 30303

SUBJECT BFA0-7333T

ON NOVEMBER 8 1973 DURING ROUTINE SURVEILLANCE TESTING REACTOR
WATER LEVEL SWITCHES LIS-3-203 B AND C WERE FOUND TO OPERATE
OUTSIDE THE TECHNICAL SPECIFICATIONS SETPOINT OF 538 INCHES
ABOVE VESSEL 0. THE SWITCHES OPERATED AT 533 INCHES AND 537
INCHES RESPECTIVELY. THE REACTOR WAS AT APPROXIMATELY 30 PERCENT
POWER 300 MW ELECTRICAL

H J GREEN BROWNS FERRY NUCLEAR PLANT

SF-1201 (R5-69)

8311090460 731116
PDR ADOCK 05000259
S PDR

Handwritten:
50-259