



Telegram

COPY

K GNA245 (SVC) HARTSVILLE SOCAR 9 352P EST

AEC ATTN JOHN DAVIS

SUITE 818 230 PEACHTREE ST ATLA (DLR SAT AM OFC OPEN SAT)

THIS IS TO CONFIRM TELEPHONE REPORT OF 39-71 ON 3-8-71 AT 11 PM  
ON A ROUTING TEST EMERGENCY DIESELS FAILED TO PERFORM PROPERLY  
DETAILED REPORT AS REQUIRED BY TECHNICAL SPECIFICATIONS TO  
FOLLOW

G P BEATTY JR CAROLINA POWER AND LIGHT CO

WU 1201 (R 5-69)

8403090338 710407  
PDR ADOCK 05000261  
S PDR