



Telegram

JAN 21 PM 12 12

1138A EST JAN 21 71 AE049

A LLF195 DB (A KPA022) (CT RGA402) IL NL PDB RALEIGH NCAR 20  
DIRECTOR REGION DIRECTOR REGION TWO COMPLIANCE OFFICE SUITE 818

U S ATOMIC ENERGY COMMISSION DLY ATLA 230 PEACHTREE ST NW ATLA 30303

IN AMPLIFICATION OF TELEGRAM SENT JANUARY 19 1971 CAROLINA  
POWER AND LIGHT REPORTS THAT A RECENT SAFETY ANALYSIS INDICATES  
THAT OPERATION AT 50. PERCENT POWER DOES NOT INVOLVE AND UNEVALUATED  
SAFETY CONSIDERATION IF AN ACCIDENT WERE TO OCCUR. PRIOR TO  
ANY ADDITIONAL POWER ESCALATION SAFETY ANALYSIS WILL BE PERFORMED  
TO VERIFY SAFETY CONSIDERATIONS KCOMPANY NUCLEAR SAFETY COMMITTEE  
HAS REVIEWED 50 PERCENT ANALYSIS AND WILL REVIEW ANY ADDITIONAL  
POWER ESCALATION

N B BESSAC MANAGER KNUCLEAR GENERATION CAROLINA POWER AND BOW  
LIGHT.

8403090373 710701  
PDR ADOCK 05000261  
PDR

WL 116P MAILED

19 1971 50 58.(1139)

SI-1201 (R5-69)

526-4537