

Vepco

VIRGINIA ELECTRIC AND POWER COMPANY
Surry Power Station
P.O. Box 315
Surry, Virginia 23883

July 1, 1975

Director of Regulatory Operations
230 Peachtree Street, N. W.
Suite 818
Atlanta, Georgia 30303

This is to inform you by telecopy of an Abnormal Occurrence that was noted on June 30, 1975 at Surry Nuclear Power Station.

Unit 2 was operating at 100% power when it was discovered that the the Undervoltage Reactor Trip Circuit was inoperable.

E. M. Sweeney Jr. By BS
E. M. Sweeney, Jr.,
Manager

8403120386 750708
PDR ADOCK 05000281
S PDR

50-281
inquiry