

LICENSEE EVENT REPORT

AO-S2-75-10

CONTROL BLOCK

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME										LICENSE NUMBER										LICENSE TYPE					EVENT TYPE	
01	V	A	S	P	S	2	0	0	-	0	0	0	0	0	-	0	0	4	1	1	1	0	0	1		
7	8	9	14	15	25	26	30	31	32																	
01		CONT		CATEGORY		REPORT TYPE		REPORT SOURCE		DOCKET NUMBER					EVENT DATE					REPORT DATE						
01	7	8	P	0	T	L	0	5	0	-	0	2	8	1	0	6	2	4	7	5	0	6	2	6	7	5
57	58	59	60	61	68	69	74	75	80																	

EVENT DESCRIPTION

02	During normal operation on Unit No. 2, service water pump 2-SW-P-4B developed a seal																								
03	leak. Water filled the valve pit containing the isolation valve MOV-SW-202B. Water																								
04	caused electrical short in motor operator. MOV-SW-202A remained operable. Pump																								
05	leak and motor operator were repaired. The above is contrary to Tech Spec 1.0.1.6.																								
06	AO-S2-75-10																								

SYSTEM CODE		CAUSE CODE		COMPONENT CODE					PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER					VIOLATION	
07	W	A	E	V	A	L	V	O	P	A	L	2	0	0	N		
7	8	9	10	11	12	17	43	44	47	48							

CAUSE DESCRIPTION

08	Limitorque motor operator SMB-000. Water leaking from pump ran across floor and into																								
09	valve pit filling the pit with water and flooding motor of MOV-SW-202B. Floor																								
10	plating above pit will be sealed to prevent a recurrence.																								

FACILITY STATUS		% POWER		OTHER STATUS					METHOD OF DISCOVERY		DISCOVERY DESCRIPTION				
11	E	1	0	0	N/A	A	N/A								
7	8	9	10	12	13	44	45	46							
FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY					LOCATION OF RELEASE						
12	Z	Z	N/A	N/A											
7	8	9	10	11	44	45									

PERSONNEL EXPOSURES

NUMBER		TYPE		DESCRIPTION	
13	0	0	0	Z	N/A
7	8	9	11	12	13

PERSONNEL INJURIES

NUMBER		DESCRIPTION		
14	0	0	0	N/A
7	8	9	11	12

OFFSITE CONSEQUENCES

15	N/A																								
7	8	9																							

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION	
15	Z	N/A	
7	8	9	10

PUBLICITY

17	N/A																								
7	8	9																							

ADDITIONAL FACTORS

18	N/A																								
7	8	9																							

8403120390 750626
PDR ADOCK 05000281
S PDR

19																									
7	8	9																							

NAME: E. M. Sweeney, Jr.

PHONE: (804) 357-3184

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

July 1, 1975



Mr. Norman C. Moseley, Director
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission
Region II - Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

Serial No. 586
PO&M/JTB:clw

Docket No. 50-281
License No. DPR-37

Dear Mr. Moseley:

Pursuant to Surry Power Station Technical Specification 6.6.B.1, the Virginia Electric and Power Company hereby submits forty (40) copies of Abnormal Occurrence Report No. AO-S2-75-10.

The substance of this report has been reviewed by the Station Nuclear Safety and Operating Committee and will be placed on the agenda for the next meeting of the System Nuclear Safety and Operating Committee.

Very truly yours,

C. M. Stallings

C. M. Stallings
Vice President-Power Supply
and Production Operations

Enclosures

40 copies of AO-S2-75-10

cc: Mr. K. R. Goller

7238