

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 309-654-2241



LWP-95-069

July 31, 1995

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Reference: Quad Cities Nuclear Power Station
Docket Number 50-265, DPR-30, Unit Two

Enclosed is Licensee Event Report (LER) 95-003, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(v)(B). The licensee shall report any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems than are needed to remove residual heat.

The following commitments are being made by this letter:

Procedure QCOP 1000-5, Shutdown Cooling Operation, will be changed to specifically require the depressing of the reset pushbutton for the MO 1001-29A(B) prior to operation of the valve. This will be completed by September 30, 1995.

Procedure QCOS 1600-13, Refueling Outage PCI Groups 2 and 3 Isolation Test, will be changed to ensure that the proper reset of all isolations in the procedure are accomplished. In addition, a statement will be included in the procedure to ensure that the reset steps of the logic are included if performing a partial test. This will be completed by September 30, 1995.

Procedures QOP 7000-1, Reactor Protection System MG Sets, and QOA 7000-1, 120 VAC Reactor Protection Bus Failure (One or Both Buses), will be changed to require the reset of MO 1001-29A and B by depressing the pushbutton. This will be completed by September 30, 1995.

A review will be performed of all other procedures, that insert sealed in signals to valves that are susceptible to rapid reversal. The purpose of this review is to insure that the signal is properly reset prior to stroking these valves. This review will be completed by September 30, 1995 and any necessary procedure changes completed by November 30, 1995.

060017

TEC2
11

LWP-95-069
July 31, 1995
page 2

If there are any questions or comments concerning this letter, please refer them to Nick Chrissotimos, Regulatory Assurance Administrator at 309-654-2241, ext. 3100.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION

D. B. Cook for

L. W. Pearce
Station Manager

LWP/TB/plm
Enclosure

cc: J. Schrage
C. Miller
INPO Records Center
NRC Region III