

August 4, 1995

1CAN089502

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
Completion Of Generic Letter 89-10 Commitments For ANO-1

Gentlemen:

Generic Letter (GL) 89-10, "Safety-Related Motor-Operated Valve Testing and Surveillance," requested licensees to complete certain actions. This letter is submitted for ANO-1 in accordance with reporting requirement "m" of GL 89-10 to inform you that Arkansas Nuclear One, Unit 1 (ANO-1) has completed its GL 89-10 initial implementation commitments for items "a" through "h" and supplements 1-6, as applicable to ANO-1. The detailed supporting documentation is extensive and is available at ANO for review by the NRC.

The generic letter required each licensee to notify the NRC in writing within 30 days after completing the actions described in the first paragraph of item "i" which states that completion of design basis reviews, analyses, verifications, tests, and inspections must be completed within five years or three refueling outages of the date of the generic letter, whichever is later. The completion date for ANO was extended based on justification provided to the NRC in a letter dated March 19, 1993 (OCAN039308). The new completion date for ANO-1 was determined to be 120 days following completion of refueling outage 1R12, which was the fourth refueling outage after the date of the generic letter. Refueling outage 1R12 concluded on April 1, 1995.

Additionally, a followup meeting with the NRC was conducted at Arkansas Nuclear One on October 27, 1994, to discuss the status of actions to complete Entergy Operations' commitments to GL 89-10. Based on those discussions, and on the written commitments in the March 19, 1993, correspondence referenced above, it was agreed that a GL 89-10 completion letter was to be submitted to the NRC by August 6, 1995, for ANO-1 and March 3, 1996, for ANO-2 (reference letter OCNA129421 from the NRC dated December 29, 1994).


000000
7508090230 950804
PDR ADDCK 05000313
P PDR

Aug 4
1995

U. S. NRC
August 4, 1995
1CAN089502 Page 2

Should you have any questions, please contact me.

Very truly yours,


for Dwight C. Mims
Director, Licensing

DCM/dwb

cc: Mr. Leonard J. Callan
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One
P.O. Box 310
London, AR 72847

Mr. George Kalman
NRR Project Manager Region IV/ANO-1 & 2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, MD 20852