

The Light company

Houston Lighting & Power South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, Texas 77483

August 3, 1995
ST-HL-AE-5132
File No.: G09.06
10CFR50.90, 50.92

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

South Texas Project Units 1 & 2
Docket Nos. STN 50-498, STN 50-499
Replacement Figure 1 to Additional Information Regarding
South Texas Project, Unit 2 Core Exit Thermocouple


References:

1. Letter from J. F. Groth, Houston Lighting & Power, to Nuclear Regulatory Commission Document Control Desk, dated May 4, 1995, (ST-HL-AE-5080), "Additional Information Regarding South Texas Project, Unit 2 Core Exit Thermocouple."

In reference 1 Houston Lighting & Power Company submitted additional information relative to the South Texas Project, Unit 2 Core Exit Thermocouple arrangement. Included in the referenced submittal was Figure 1, Core Exit Thermocouple Instrumentation Arrangement as a reference in Attachment 1, Description of Temporary Modification. Houston Lighting and Power Company has since found an error in Figure 1 and submits the attached replacement page for Figure 1. The error that has been corrected with this attachment is from Core Exit Thermocouple 17 via a jumper to Train C Reference Junction. Previously the jumper was incorrectly depicted as going from Train A to Train C Reference Junctions via a jumper without being connected to Core Exit Thermocouple 17. The written description in the referenced submittal was accurately made. The error in the figure had no impact upon the modification. The attached replacement Figure 1 is being submitted as a matter of record.

Please replace Figure 1 in the referenced letter with the figure attached to this letter.

If you should have any questions concerning this matter, please call Mr. M. A. McBurnett at (512) 972-7206 or myself at (512) 972-8664.


J. F. Groth
Vice President,
Nuclear Generation

050029

HRP/ps
Attachment: Replacement Figure 1

Project Manager on Behalf of the Participants in the South Texas Project

9508090256 950803
PDR ADDCK 05000499
P PDR

A001
11

Houston Lighting & Power Company
South Texas Project Electric Generating Station

ST-HL-AE-5132
File No.: G09.06
Page 2

c:

Leonard J. Callan
Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Thomas W. Alexion
Project Manager
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001 13H15

David P. Loveless
Sr. Resident Inspector
c/o U. S. Nuclear Regulatory Comm.
P. O. Box 910
Bay City, TX 77404-0910

J. R. Newman, Esquire
Morgan, Lewis & Bockius
1800 M Street, N.W.
Washington, DC 20036-5869

K. J. Fiedler/M. T. Hardt
City Public Service
P. O. Box 1771
San Antonio, TX 78296

J. C. Lanier/M. B. Lee
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

C. A. Johnson
Central Power and Light Company
P. O. Box 289, Mail Code: N5012
Wadsworth, TX 77483

Rufus S. Scott
Associate General Counsel
Houston Lighting & Power Company
P. O. Box 61067
Houston, TX 77208

Institute of Nuclear Power
Operations - Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957

Dr. Joseph M. Hendrie
50 Bellport Lane
Bellport, NY 11713

Richard A. Ratliff
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

U. S. Nuclear Regulatory Comm.
Attn: Document Control Desk
Washington, D. C. 20555-0001

J. R. Egan, Esquire
Egan & Associates, P.C.
2300 N Street, N.W.
Washington, D.C. 20037

CORE EXIT THERMOCOUPLE INSTRUMENTATION ARRANGEMENT

