

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of less than or equal to L_a , 0.30% by weight of the containment air per 24 hours at P_a , ~~41.2~~ psig.
- b. A combined leakage rate of less than 0.60 L_a for all penetrations and valves subject to Type B and C tests, when pressurized to P_a .

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With either the measured overall integrated containment leakage rate exceeding 0.75 L_a or the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding 0.60 L_a , restore the overall integrated leakage rate to less than 0.75 L_a and the combined leakage rate for all penetrations subject to Type B and C tests to less than 0.60 L_a ~~prior to increasing the Reactor Coolant System temperature above 200°F~~, within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

~~4.6.1.2 The containment leakage rates shall be determined in accordance with the test schedule, criteria, methods and provisions specified or endorsed in Appendix J of 10 CFR 50.~~

Perform required visual examinations and leakage rate testing, except for containment air lock testing, in accordance with 10 CFR 50, Appendix j, as modified by approved exemptions.

~~a. Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted during shutdown at intervals as specified by Appendix J of 10 CFR 50 or as permitted by Nuclear Regulatory Commission approved exemptions, at a pressure not less than P_a , 41.2 psig.~~

SOUTH TEXAS - UNITS 1 & 2

3/4 6-2

Unit 1 - Amendment No. ~~26~~ 61,75
Unit 2 - Amendment No. ~~16~~ 50,64

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of less than or equal to L_o , 0.30% by weight of the containment air per 24 hours at P_o , ~~41.2~~ psig.
- b. A combined leakage rate of less than 0.60 L_o for all penetrations and valves subject to Type B and C tests, when pressurized to P_o .

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With either the measured overall integrated containment leakage rate exceeding 0.75 L_o or the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding 0.60 L_o , restore the overall integrated leakage rate to less than 0.75 L_o and the combined leakage rate for all penetrations subject to Type B and C tests to less than 0.60 L_o prior to increasing the Reactor Coolant System temperature above 200°F. Within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLA shutdown within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be determined in conformance with the test schedule, criteria, methods and provisions specified or endorsed in Appendix J of 10 CFR Part 50. Perform required visual examinations and leakage rate testing, except for containment air lock testing, in accordance with 10 CFR 50, Appendix J, as modified by approved exemptions.

a. Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted during shutdown at intervals as specified by Appendix J of 10 CFR Part 50 or as permitted by Nuclear Regulatory Commission-approved exemptions, at a pressure not less than P_o , 41.2 psig;