



Illinois Power Company
Clinton Power Station
P.O. Box 678
Clinton, IL 61727
Tel 217 935-8881

U-602477
L30-95(08-03)-LP
8E.100c

August 3, 1995

10CFR50.36

Docket No. 50-461

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Clinton Power Station, Unit 1
Facility Operating License NPF-62
July 1995 Monthly Operating Report

Dear Sir:

Please find in Attachment 1 the Monthly Operating Report for Clinton Power Station, Unit 1, for the period ending July 31, 1995.

Sincerely yours,

Richard F. Phares
Director - Licensing

MCH/krm

Attachment

cc: NRC Region III Regional Administrator
NRC Resident Office, V-690
Illinois Department of Nuclear Safety

100008

9508090366 950731
PDR ADOCK 05000461
R PDR

JE24.1

CHALLENGES TO MAIN STEAM SAFETY/RELIEF VALVES

Month July 1995

None

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-461

UNIT Clinton 1

DATE 07/31/95

COMPLETED BY M. C. Hollon

TELEPHONE (217) 935-8881 X3537

MONTH July 1995

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>915</u>
2	<u>914</u>
3	<u>915</u>
4	<u>915</u>
5	<u>914</u>
6	<u>914</u>
7	<u>915</u>
8	<u>916</u>
9	<u>913</u>
10	<u>914</u>
11	<u>912</u>
12	<u>909</u>
13	<u>906</u>
14	<u>905</u>
15	<u>906</u>
16	<u>765</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>906</u>
18	<u>910</u>
19	<u>911</u>
20	<u>909</u>
21	<u>909</u>
22	<u>911</u>
23	<u>909</u>
24	<u>908</u>
25	<u>908</u>
26	<u>908</u>
27	<u>908</u>
28	<u>907</u>
29	<u>905</u>
30	<u>902</u>
31	<u>900</u>

OPERATING DATA REPORT

DOCKET NO. 50-461
UNIT Clinton 1
DATE 07/31/95
COMPLETED BY M. C. Hollon
TELEPHONE (217) 935-8081 X3537

OPERATING STATUS

1. REPORTING PERIOD: July 1995 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2894
MAX. DEPEND. CAPACITY (MDC) (MWe-Net): 930
DESIGN ELECTRICAL RATING (MWe-Net): 933
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL...	<u>744.0</u>	<u>3,806.9</u>	<u>49,558.8</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
7. HOURS GENERATOR ON LINE.....	<u>744.0</u>	<u>3,707.6</u>	<u>48,132.0</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>4.0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)...	<u>2,151,464</u>	<u>9,733,052</u>	<u>128,199,250</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>704,571</u>	<u>3,191,868</u>	<u>42,348,819</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)...	<u>673,318</u>	<u>3,037,480</u>	<u>40,313,658</u>
12. REACTOR SERVICE FACTOR.....	<u>100.0%</u>	<u>74.8%</u>	<u>73.6%</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>100.0%</u>	<u>74.8%</u>	<u>73.6%</u>
14. UNIT SERVICE FACTOR.....	<u>100.0%</u>	<u>72.9%</u>	<u>71.5%</u>
15. UNIT AVAILABILITY FACTOR.....	<u>100.0%</u>	<u>72.9%</u>	<u>71.5%</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>97.3%</u>	<u>64.2%</u>	<u>64.4%</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)	<u>97.0%</u>	<u>64.0%</u>	<u>64.2%</u>
18. UNIT FORCED OUTAGE RATE.....	<u>0.0%</u>	<u>4.1%</u>	<u>8.9%</u>

19. SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, DURATION OF EACH):
None

20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NA

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-461
UNIT Clinton 1
DATE 07/31/95
COMPLETED BY M. C. Hollen
TELEPHONE (217) 935-8881 X3537

REPORT MONTH July 1995

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON(1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS/COMMENTS
-----	------	-----------------------------------	---------------------	-----------	---	--------------------------------

NONE

- (1) Reason
A-Equipment Failure (explain), B-Maintenance or Test, C-Refueling, D-Regulatory Restriction,
E-Operator Training & License Examination, F-Administrative, G-Operational Error (explain),
H-Other (explain)
- (2) Method
1-Manual, 2-Manual Scram, 3-Automatic Scram, 4-Other (explain)