

CP&L

Carolina Power & Light Company

P. O. Box 101, New Hill, N. C. 27562

March 2, 1984

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest (Suite 2900)
Atlanta, Georgia 30303

NRC-190

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
1986 - 900,000 KW - UNIT 1
STANDBY DIESEL GENERATOR, ITEM 159

Dear Mr. O'Reilly:

On February 6, 1984, Mr. N. J. Chiangi notified the NRC (Mr. A. Hardin) of a potentially reportable item per the provisions of 10CFR50.55(e) and 10CFR, Part 21. The NRC was informed that the flexible coupling drive hubs on the drive shaft in the overspeed governor and fuel transfer pump drive of the Standby Diesel Generator may have a potential problem depending upon whether the hubs are found to be loose upon inspection. The inspection procedure from Transamerica Delaval had not been received at that time.

The inspection procedure was received from Transamerica Delaval on February 24, 1984. A field change request has been issued to direct the field to perform the inspection. It is projected that the inspection will be completed by March 30, 1984 and we will require until April 16, 1984 to submit a report on the reportability of this item.

Thank you for your consideration in this matter.

Yours very truly,



R. M. Parsons
Project General Manager
Shearon Harris Nuclear Power Plant

RMP/sh

cc: Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP)
Mr. R. C. DeYoung (NRC)

8403130237 840302
PDR ADOCK 05000400
S PDR

OFFICIAL COPY

IEZ7

110