



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 3, 1984

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 34-008,0 - Fire
Barriers Opened to
Implement Design Change
Package
AECM-84/0117

On January 24, 1984, fire barriers located in U720 Control Room floor module at LA59-L01 and LA59-L04 were opened to implement a design change package. A fire watch was established within one hour and will be maintained for the duration of the planned maintenance activities in accordance with Technical Specification 3.7.7.

This is reported as a Special Report pursuant to Technical Specification 6.9.2. This condition has no effect on the health and safety of the public and does not constitute a threat to plant safety. This work task is expected to be complete by April 16, 1984.

Yours truly,

L. F. Dale
Manager of Nuclear Services

EBS/SHH:sad

cc: (See Next Page)

8403130248 840305
PDR ADDCK 050004:6
S PDR

OFFICIAL COPY

ITCC

1/0

MISSISSIPPI POWER & LIGHT COMPANY

AECM-84/0117

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555