

Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

February 28, 1984
ANPP-28966-BSK/TRB

U. S. Nuclear Regulatory Commission
Region V
Creekside Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, CA 94596-5368

Attention: Mr. T. W. Bishop, Director
Division of Resident
Reactor Projects and Engineering Programs

Subject: Time Extension For Report - DER 83-64
A 50.55(e) Potentially Reportable Deficiency Relating To
Pressure Relief Valves By Target Rock Failed To Meet
Pre-Requisite Tests.
File: 84-019-026; D.4.33.2

Reference: (A) Telephone conversation between P. Johnson and R. Tucker on
September 28, 1983
(B) ANPP-28096, dated, October 26, 1983 (Interim Report)
(C) ANPP-28096, dated, January 26, 1984 (Time Extension)

Dear Sir:

The NRC was notified of a potentially reportable deficiency in
Reference (A), and an Interim Report was transmitted by Reference (B),
and a Time Extension requested by Reference (C). At that time, it was
estimated that a Final Report would be available by March 5, 1984.

Due to the extensive investigation and evaluation required, it is now
expected that this information will be finalized by April 2, 1984, at
which time a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,

E. E. Van Brunt / BSK
E. E. Van Brunt, Jr.
APS Vice President, Nuclear
ANPP Project Director

EEVB/TRB:db

cc: See Page Two

8403130449 840228
PDR ADOCK 05000528
S PDR

1E-27 1/1

Mr. T. W. Bishop
DER 83-64
Page Two

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
W. E. Ide
D. B. Fasnacht
A. C. Rogers
B. S. Kaplan
L. A. Souza
J. Vorees
J. R. Bynum
P. P. Klute
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
H. D. Foster
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli
S. R. Frost
J. Self
D. Canady

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339