

Omaha Public Power District
444 South 16th Street Mall
Omaha, Nebraska 68102-2247
402/636-2000

August 4, 1995
LIC-95-0151

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, DC 20555

Reference: Docket No. 50-285

SUBJECT: Application for Amendment of Operating License

Enclosed please find the Omaha Public Power District's (OPPD) "Application for Amendment of Operating License" which seeks to amend Specification 2.15, Tables 2-3 and 2-4, and Specification 3.1, Table 3-2, of the Fort Calhoun Station Unit No. 1 Technical Specifications (TS). The TS Definitions Section as well as the Basis Section to Specification 2.15 are also being revised.

The proposed TS changes would reduce the minimum operable Containment Radiation High Signal (CRHS) channels from two to one; add a statement of clarification to the Basis Section of Specification 2.15 regarding the number of installed channels for CRHS as two; revise the requirement to place the Safety Injection Refueling Water (SIRW) tank low level channels in the "bypass" condition rather than placing them in "trip"; administratively revise the CRHS surveillance methods to be consistent with the applicable surveillance functions; and delete the term "source check" from the TS Definitions Section.

Attachment A contains a markup reflecting the requested changes of the Technical Specifications. Attachment B provides the "Discussion, Justification and No Significant Hazards Consideration."

140011

ADDI 138

U. S. Nuclear Regulatory Commission
LIC-95-0151
Page 2

If you should have any questions, please contact me.

Sincerely,

W. G. Gates

W. G. Gates
Vice President

WGG/d11

Attachments

c: Winston & Strawn (w/o Attachments)
L. J. Callan, NRC Regional Administrator, Region IV
T. Y. Liu, NRC Acting Project Manager
W. C. Walker, NRC Senior Resident Inspector
B. E. Casari, Director - Environmental Health Division, State of Nebraska

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)

)
Omaha Public Power District)
(Fort Calhoun Station)
Unit No. 1))

Docket No. 50-285

AFFIDAVIT

W. G. Gates, being duly sworn, hereby deposes and says that he is the Vice President in charge of all nuclear activities of the Omaha Public Power District; that as such he is duly authorized to sign and file with the Nuclear Regulatory Commission the attached information concerning the Application for Amendment dated August 4, 1995 concerning revisions to Technical Specifications 2.15, Tables 2-3 and 2-4, reducing the minimum operable Containment Radiation High Signal (CRHS) channels from two to one and revising the requirement for placing the Safety Injection Refueling Water tank low level channels in "bypass" rather than "trip", and revising Specification 3.1, Table 3-2, CRHS surveillance methods to be consistent with the applicable surveillance functions; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information, and belief.

W. G. Gates

W. G. Gates
Vice President

STATE OF NEBRASKA)
) ss
COUNTY OF DOUGLAS)

Subscribed and sworn to before me, a Notary Public in and for the State of Nebraska on this 4th day of August, 1995.

Steve R. Olson
Notary Public

