

GPU Nuclear Corporation  
Post Office Box 480  
Route 441 South  
Middletown, Pennsylvania 17057-0191  
717 944-7621  
TELEX 84-2386  
Writer's Direct Dial Number:

March 12, 1984  
5211-84-2036


Office of Nuclear Reactor Regulations  
Attn: John F. Stolz, Chief  
Operating Reactors Branch No. 4  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Sir:

Three Mile Nuclear Station, Unit I (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289  
Radiation Monitor Setpoints

Attached for your information is a copy of a letter to the PaDER  
concerning the setpoints for RMA5 and RM-G25.

Sincerely,

  
H. D. Hukill,  
Director, TMI-1

HDH:CWS:mle  
Attachment

cc: H. Silver

8403160022 840312  
PDR ADOCK 05000289  
P PDR

SUMMARY OF CONDENSOR OFF GAS  
RADIATION MONITORS RESPONSES  
AS THEY RELATE TO OTSG LEAKAGE

RMA-5 (Low Channel)

High Alarm Set Point: 2.5E5 cpm \*

Basis:

A primary to secondary leak rate of 7 gph (0.12gpm) at a nominal failed fuel fraction of 0.03% will indicate 2.5E5 cpm. This high alarm set point also corresponds to the GPUNC administrative shutdown limit of 7 gph primary to secondary leakage.

Alert Alarm Set Point: 115 cpm \*

Basis:

A primary to secondary leak rate of 3 gph (0.05 gpm) at nominal failed fuel fraction of 0.03% will indicate  $1 \times 10^5$  cpm on RMA-5 low range. This alarm is set at a value higher than the baseline leak rate, approximately 50% of the administrative shutdown limit.

RMA-5 (High Channel)

High Alarm Set Point: 3E4 cpm \*

Basis:

An Alert emergency classification\*\* is declared at 3E4 cpm on RMA-5 High which corresponds to 10 mR/hr dose rate at the site boundary assuming a nominal failed fuel fraction of 0.03% and adverse meteorology. A 250 gpm primary to secondary leak rate at a nominal failed fuel fraction of 0.03% is actually required to reach a dose rate of 10 mR/hr at site boundary.

Alert Alarm Set Point: 130 cpm \*

Basis:

An Unusual Event is declared at 1 gpm primary to secondary leak rate which corresponds to 130 cpm on RMA-5 High based on a nominal failed fuel fraction of 0.03%. The 1 gpm is the Tech. Spec. shutdown limit.

RMG-25

High Alarm Set Point: 5.5E3 mR/hr \*

Basis:

A Site emergency classification is declared at 5.5E3 mR/hr on RMG-25, which corresponds to 50 mR/hr dose rate at the site boundary assuming a nominal failed fuel fraction of 0.03% and adverse meteorology.

RMG-25 (Continued)

Alert Alarm Set Point: 1.1E3 mR/hr \*

Basis:

An Alert emergency classification \*\* is declared at 1.1E3 mR/hr on RMG-25, which corresponds to 10 mR/hr dose rate at the site boundary assuming a nominal failed fuel fraction of 0.03% and adverse meteorology. A 250 gpm primary to secondary leak rate at a nominal failed fuel fraction of 0.03% is actually required to reach a dose rate of 10 mR/hr at the site boundary.

\* These values may change slightly due to instrument response characteristics.

\*\* An Alert emergency classification is also declared for greater than 50 gpm primary to secondary leakrate when saturation margin is not lost regardless of radiation monitor reading.