



ENTERGY

Entergy Operations, Inc.
P.O. Box 8
Woburn, MA 01801
Tel 617 299 6774

R. F. Burski
Manager
Nuclear Safety
Woburn, MA

W3F191-0689
A4.05
QA

January 14, 1992

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Waterford 3 SES
Docket No. 50-382
License No. NPF-38
Resolution of Generic Issues 48, "LCOs for Class 1E Instrument
Buses," and 49, "Interlocks and LCOs for Class 1E Tie Breakers,"
Pursuant to 10CFR50.54(f)
(NRC Generic Letter 91-11)

Gentlemen:

This submittal serves to assure that the concerns of the subject letter are adequately addressed at Waterford 3.

Generic Letter (GL) 91-11 issued on July 18, 1991, requires licensees to respond within 180 days of receipt, to confirm that their appropriate plant procedures include time limitations and surveillance requirements for:

1. Vital instrument buses (typically 120V ac buses),
2. Inverters or other onsite power sources to the vital instrument buses, and
3. The practice is that [] connect redundant Class 1E buses (ac or dc) at one unit or that can connect Class 1E buses between units at the same site.

GL 91-11 in licensees that the current Combustion Engineering (CE) standard technical specifications include the requirements contained in the generic letter and that the recently licensed CE facilities have resolved the subject concerns by implementing the Standard Technical Specifications (STS).

9201210135 920114
FDR ADDCK 05000382
FDR

A001
1/0

Resolution of Generic Issues 48, "LCOs for Class 1E Instrument Buses," and 49, "Interlocks and LCOs for Class 1E Tie Breakers," Pursuant to 10CFR50.54(f)
(NRC Generic Letter 91-11)

W3F191-0689


Page 2

January 14, 1992

Waterford 3 is a CE designed facility licensed in March of 1985. Technical Specification 3/4.8.3, "Onsite Power Distribution," implements the CE STS (NUREG-0212, Revision 3, issued Fall of 1981) which include the requirements contained in GL 91-11. Based on a review of the requirements stated in GL 91-11 and the administrative controls (i.e., surveillance procedures) established at Waterford 3, no additional action is required.

Should you desire any further information concerning this subject, please contact Paul Caropino at (504) 739-6092.

Very truly yours,



RFB/PLC/ssf

cc:

R.D. Martin, NRC Region IV

D.L. Wigginton, NRC-NRR

R.B. McGehee

N.S. Reynolds

NRC Resident Inspectors Office

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the matter of)

Entergy Operations, Incorporated)
Waterford 3 Steam Electric Station)

Docket No. 50-382

AFFIDAVIT

R.F. Burski, being duly sworn, hereby deposes and says that he is Director Nuclear Safety - Waterford 3 of Entergy Operations, Incorporated; that he is duly authorized to sign and file with the Nuclear Regulatory Commission the attached Response to NRC Generic Letter 91-11; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information and belief.



R.F. Burski


Director Nuclear Safety - Waterford 3

STATE OF LOUISIANA)

) ss

PARISH OF ST. CHARLES)

Subscribed and sworn to before me, a Notary Public in and for the Parish and State above named this 14TH day of JANUARY, 1992.



Notary Public

My Commission expires WITH LIFE.