

March 2, 1984

Mr. James P. O'Reilly
Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
Suite 2900
101 Marietta St., N. W.
Atlanta, Georgia 30303

Serial No. 770
NO/JDH:acm
Docket Nos. 50-280
50-281
50-338
50-339
License Nos. DPR-32
DPR-37
NPF-4
NPF-7

Dear Mr. O'Reilly:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION, UNITS 1 AND 2
SURRY POWER STATION, UNITS 1 AND 2
RESPONSE TO I.E. BULLETIN NO. 83-08

I.E. Bulletin No. 83-08, "Electrical Circuit Breakers with an Undervoltage Trip Feature in Use in Safety-Related Applications Other than the Reactor Trip System," dated December 28, 1983, requested licensees to identify applications of W type DB, W type DS, or GE type AK-2 circuit breakers with the undervoltage trip feature in safety related applications, other than as reactor trip breakers. The bulletin also requested licensees to identify similar applications of other types of breakers by other manufacturers that use an undervoltage trip feature. If any breakers described above were identified by the licensee, certain additional actions were required.

We have reviewed the use of all breakers in safety-related applications at both North Anna and Surry and have determined that there are no breakers with undervoltage trip attachments of the type described in the bulletin in any safety-related systems at either station, except for the reactor trip breakers. Therefore, no additional actions in response to the bulletin are required.

The bulletin also requested the following information to help NRC evaluate the cost of the bulletin; staff time to perform requested review: 40 staff hours; staff time to prepare requested documentation: 4 staff hours.

Very truly yours,

W. L. Stewart
W. L. Stewart

Dupe

8403160154

2 pp

James P. O'Reilly

cc: U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Mr. D. J. Burke
NRC Resident Inspector
Surry Power Station

Mr. M. W. Branch
NRC Resident Inspector
North Anna Power Station

Mr. James R. Miller, Chief
Operating Reactors Branch No. 3
Division of Licensing, NRR
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing, NRR
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by W. L. Stewart who is Vice President - Nuclear Operations, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 2nd day of March, 19 84.

My Commission expires: 2-26, 19 85.

Ann C. Morse
Notary Public

(SEAL)

S/001