



Log # TXX-92034  
File # 10010  
903.8  
Ref. # 10CFR2.102(a)

**TU ELECTRIC**

William J. Cahill, Jr.  
Group Vice President

January 15, 1992

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES) - UNIT 2  
JACKET NO. 50-446  
REQUEST FOR ADDITIONAL INFORMATION  
FSAR SECTION 3.8.1.2.5

REF: 1) TU Electric Letter logged TXX-91325 from William J. Cahill to NRC  
dated September 17, 1991

Gentlemen:

On January 15, 1990, TU Electric notified the NRC of a change to the FSAR via TXX-90011 (pages 32 through 34 of the Attachment, FSAR Change Request Number 89-587). The FSAR change involved adding an exception to the ASME-ACI 359 document for liquid penetrant or magnetic particle examination of full penetration attachment welds (section 5523.1). As a result of subsequent discussions with the NRC staff regarding this change, the following additional information is provided as requested.

The nondestructive examinations (NDE) of the accessible welds below the spring line are complete. The nondestructive examinations comply with the acceptance requirements of the specification. Additionally, no relevant indications were identified. The NDE results will be incorporated into the Unit 2 calculation (Reference 1). Since no unacceptable linear indications were identified, the conclusions of the calculation remain unchanged.

9201220056 920115  
PDR ADDCK 05000446  
A PDR

400 N. Olive Street L.B. 21 Dallas, Texas 75201


Do29  
110

TXX-92034  
Page 2 of 2

Should you have any questions regarding this issue, please contact  
Mr. Carl Corbin at (214) 812-8859.

Sincerely,

William J. Cahill, Jr.

By:   
D. R. Woodlan  
Docket Licensing Manager

CBC/cbc

cc: R. D. Martin, Region IV  
Regional Inspectors, CPSES (2)  
M. B. Fields, NRR