

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of ) UNIT NO. 2  
 ) Docket No. 50-412  
Duquesne Light Company ) License No. NPF-73  
Beaver Valley Power Station)

APPLICATION FOR AMENDMENT  
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U.S. Nuclear Regulatory Commission, Duquesne Light Company hereby requests that the technical specifications set forth in Appendix A to this license be amended to revise Table 3.2-1 of Specification 3.2.5. Specifically, the value for reactor coolant system flow uncertainty would be lowered from 3.5% to 2.0% and the measured reactor coolant system flow limit would be lowered from  $\geq 274,800$  gpm to  $\geq 270,850$  gpm.

The proposed technical specification change is set forth in Attachment A to this application. A safety analysis and no significant hazard evaluation are set forth in Attachment B. A typed replacement page for the technical specification is contained on Attachment C. Based on the guidance provided by the commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.92.

WHEREFORE, Applicant respectfully requests that Appendix A to the operating license be amended in the form attached hereto as Attachment A.

Duquesne Light Company

By J.D. Sieber  
J.D. Sieber  
Vice President  
Nuclear Group

Subscribed and sworn to before me

on this 13 day of January, 1992

Sheila M. Fattore

