



Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609

August 9, 1995

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:


In the Matter of)	Docket Nos. 50-259
Tennessee Valley Authority)	50-260
		50-296

**BROWNS FERRY NUCLEAR PLANT (BFN) - MONTHLY OPERATING REPORT
FOR THE MONTH OF JULY 1995**

In accordance with the requirements of Units 1, 2, and 3
Technical Specifications, Section 6.9. TVA is submitting
the Monthly Operating Report for the month of July 1995 in
the enclosure.

If you have any questions, please call me at (205) 729-2636.

Sincerely,



Pedro Salas
Manager of Site Licensing

Enclosure
cc: See page 2

150100

9508150175 950731
PDR ADCK 05000259
R PDR

JE24.1

U.S. Nuclear Regulatory Commission
Page 2

August 9, 1995

Enclosure

cc (Enclosure):

Mr. Mark S. Lesser, Acting Branch Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Frederick J. Hebdon, Director
Project Directorate II-4
Division of Reactor Projects I-II
Office of Nuclear Reactor
Regulation, Mail 13 H3
Washington, D.C. 20555

INPO Records Center
Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, Georgia 30339-5957

Mr. Jim Lang
Director of Engineering and Operations
Electric Power Research Institute
P. O. Box 10412
Palo Alto, California 94304

NRC Resident Inspector
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, Alabama 35611

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Fred Yost, Director of Research
Utility Data Institute
1200 G Street, NW
Washington, D.C. 20005-3802

ENCLOSURE

TENNESSEE VALLEY AUTHORITY
BROWNS FERRY NUCLEAR PLANT (BFN)
UNITS 1, 2, AND 3

MONTHLY OPERATING REPORT
JULY 1995

SEE ATTACHED

OPERATIONAL SUMMARY
JULY 1995

BROWNS FERRY 1

Unit 1 remains shutdown on administrative hold to resolve various TVA and NRC concerns. Unit 1 has been on administrative hold since June 1, 1985. As a result, TVA considers that accrual of reporting hours is suspended since the unit has a maximum dependable capacity of 0 MWe. Accordingly, TVA does not consider cumulative reporting period hours for the period beginning June 1, 1985, when calculating the operating status variables.

BROWNS FERRY 2

During the month Unit 2 operated at a capacity factor of 99.2 percent and generated 805,580 megawatt hours gross electrical power. As of July 31, 1995, Unit 2 has operated continuously for 120 days.

BROWNS FERRY 3

Unit 3 remains shutdown on administrative hold to resolve various TVA and NRC concerns. Unit 3 has been on administrative hold since June 1, 1985. As a result, TVA considers that accrual of reporting hours is suspended since the unit has a maximum dependable capacity of 0 MWe. Accordingly, TVA does not consider cumulative reporting period hours for the period beginning June 1, 1985, when calculating the operating status variables.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-259

UNIT: BROWN; FERRY 1

PREPARED BY: T. R. Smith

TELEPHONE: (205) 729-2955

MONTH JULY 1995

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

16	<u>0</u>
17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>0</u>

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-260
UNIT: BROWNS FERRY 2
PREPARED BY: T. R. Smith
TELEPHONE: (205) 729-2955

MONTH JULY 1995

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>1063</u>
2	<u>1063</u>
3	<u>1070</u>
4	<u>1062</u>
5	<u>1068</u>
6	<u>1061</u>
7	<u>1068</u>
8	<u>1059</u>
9	<u>1061</u>
10	<u>1060</u>
11	<u>1060</u>
12	<u>1066</u>
13	<u>1049</u>
14	<u>1055</u>
15	<u>1052</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

16	<u>1050</u>
17	<u>1048</u>
18	<u>1058</u>
19	<u>1053</u>
20	<u>1048</u>
21	<u>1055</u>
22	<u>1046</u>
23	<u>1057</u>
24	<u>1052</u>
25	<u>1057</u>
26	<u>1058</u>
27	<u>1056</u>
28	<u>1057</u>
29	<u>1038</u>
30	<u>1055</u>
31	<u>1054</u>

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-296

UNIT: BROWNS FERRY 3

PREPARED BY: T. R. Smith

TELEPHONE: (205) 729-2955

MONTH: JULY 1995

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

16	<u>0</u>
17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>0</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS
REPORT MONTH: JULY 1995

DOCKET NO: 50-259
UNIT: BROWNS FERRY 1
PREPARED BY: T. R. Smith
TELEPHONE: (205) 729-2955

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	License Event Report No.	System Code ⁴	Component Code ⁴	Cause and Corrective Action to Prevent Recurrence
1	06/01/85	S	744	F	4				Administrative hold to resolve various TVA and NRC concerns.

¹F-Forced
S-Scheduled

²A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training and License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continuation of Existing Outage
5-Reduction
9-Other

⁴Instructions for Preparation of Licensee Event Reports (NUREG-1022)

UNIT SHUTDOWNS AND POWER REDUCTIONS
REPORT MONTH: JULY 1995

DOCKET NO: 50-260
UNIT: BROWNS FERRY 2
PREPARED BY: T. R. Smith
TELEPHONE: (205) 729-2955

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	License Event Report No.	System Code ⁴	Component Code ⁴	Cause and Corrective Action to Prevent Recurrence
N/A									

¹F-Forced
S-Scheduled

²A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training and License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continuation of Existing Outage
5-Reduction
9-Other

⁴Instructions for Preparation of Licensee
Event Reports (NUREG-1022)

UNIT SHUTDOWNS AND POWER REDUCTIONS
REPORT MONTH: JULY 1995

DOCKET NO: 50-296
UNIT: BROWNS FERRY 3
PREPARED BY: T. R. Smith
TELEPHONE: (205) 729-2955

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	License Event Report No.	System Code ⁴	Component Code ⁴	Cause and Corrective Action to Prevent Recurrence
1	06/01/85	S	744	F	4				Administrative hold to resolve various TVA and NRC concerns.

¹F-Forced
S-Scheduled

²A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training and License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continuation of Existing Outage
5-Reduction
9-Other

⁴Instructions for Preparation of Licensee
Event Reports (NUREG-1022)

OPERATING DATA REPORT

DOCKET: 50-259
UNIT: BROWNS FERRY 1
PREPARED BY: T. R. SMITH
TELEPHONE: (205) 729-2955

OPERATING STATUS

1. Unit Name: BROWNS FERRY UNIT 1
2. Reporting Period: July 1995
3. Licensed Thermal Power (MWt): 3293
4. Nameplate Rating (Gross MWe): 1152
5. Design Electrical Rating (Net MWe): 1065
6. Maximum Dependable Capacity (Gross MWe): 0
7. Maximum Dependable Capacity (Net MWe): 0
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reason: N/A
9. Power Level To Which Restricted, If Any (Net MWe): 0
10. Reason For Restrictions, If Any: Administrative Hold

THIS MONTH YEAR TO DATE CUMULATIVE*

11. Hours in Reporting Period	0	0	95743
12. Hours Reactor Was Critical	0	0	59521
13. Reactor Reserve Shutdown Hours	0	0	6997
14. Hours Generator On Line	0	0	58267
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Generation (MWh)	0	0	168066787
17. Gross Electrical Generation (MWh)	0	0	55398130
18. Net Electrical Generation (MWh)	0	0	53796427
19. Unit Service Factor	0	0	60.9
20. Unit Availability Factor	0	0	60.9
21. Unit Capacity Factor (MDC Net)	0	0	52.8
22. Unit Capacity Factor (DER net)	0	0	52.8
23. Unit Forced Outage Rate	0	0	25.6
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): N/A			
25. If Shut Down At End Of Reporting Period, Estimated Date of Startup: To be determined			

* Excludes hours under administrative hold
(June 1, 1985 to present)

OPERATING DATA REPORT

DOCKET: 50-260
UNIT: BROWNS FERRY 2
PREPARED BY: T. R. SMITH
TELEPHONE: (205) 729-2955

OPERATING STATUS

1. Unit Name: BROWNS FERRY UNIT 2
2. Reporting Period: July 1995
3. Licensed Thermal Power (MWt): 3293
4. Nameplate Rating (Gross MW): 1152
5. Design Electrical Rating (Net MWe): 1065
6. Maximum Dependable Capacity (Gross MWe): 1098.4
7. Maximum Dependable Capacity (Net MWe): 1065
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reason: N/A
9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reason For Restrictions, If Any: N/A

THIS MONTH YEAR TO DATE CUMULATIVE*

11. Hours in Reporting Period	744	5087	127158
12. Hours Reactor Was Critical	744	5006	87133
13. Reactor Reserve Shutdown Hours	0	0	14200
14. Hours Generator On Line	744	4987	84847
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Generation (MWh)	2444998	16253435	247422350
17. Gross Electrical Generation (MWh)	805580	5461320	82204498
18. Net Electrical Generation (MWh)	786201	5330379	79920215
19. Unit Service Factor	100.0	98.0	66.7
20. Unit Availability Factor	100.0	98.0	66.7
21. Unit Capacity Factor (MDC Net)	99.2	98.4	59.0
22. Unit Capacity Factor (DER net)	99.2	98.4	59.0
23. Unit Forced Outage Rate	0.0	2.0	16.5
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	None		
25. If Shut Down At End Of Reporting Period, Estimated Date of Startup:	N/A		

* Excludes hours under administrative hold
(June 1, 1985 to May 24, 1991)

OPERATING DATA REPORT

DOCKET: 50-296
 UNIT: BROWNS FERRY 3
 PREPARED BY: T. R. SMITH
 TELEPHONE: (205) 729-2955

OPERATING STATUS

1. Unit Name: BROWNS FERRY UNIT 3
2. Reporting Period: July 1995
3. Licensed Thermal Power (MWt): 3293
4. Nameplate Rating (Gross MWe): 1152
5. Design Electrical Rating (Net MWe): 1065
6. Maximum Dependable Capacity (Gross MWe): 0
7. Maximum Dependable Capacity (Net MWe): 0
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reason: N/A
9. Power Level To Which Restricted, If Any (Net MWe): 0
10. Reason For Restrictions, If Any: Administrative Hold

THIS MONTH YEAR TO DATE CUMULATIVE*

11. Hours in Reporting Period	0	0	73055
12. Hours Reactor Was Critical	0	0	45306
13. Reactor Reserve Shutdown Hours	0	0	5150
14. Hours Generator On Line	0	0	44195
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Generation (MWh)	0	0	131868267
17. Gross Electrical Generation (MWh)	0	0	43473760
18. Net Electrical Generation (MWh)	0	0	42114009
19. Unit Service Factor	0	0	60.5
20. Unit Availability Factor	0	0	60.5
21. Unit Capacity Factor (MDC Net)	0	0	54.2
22. Unit Capacity Factor (DER net)	0	0	54.2
23. Unit Forced Outage Rate	0	0	21.6

24. Shutdowns Scheduled Over Next 6 Months
 (Type, Date, and Duration of Each): N/A
25. If Shut Down At End Of Reporting Period,
 Estimated Date of Startup: To be determined

* Excludes hours under administrative hold
 (June 1, 1985 to present)