



GPU Nuclear Corporation
Route 441 South
P.O. Box 480
Middletown, Pennsylvania 17057-0480
(717) 944-7621
Writer's Direct Dial Number:

(717) 948-8005

August 11, 1995
C311-95-2329

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Dear Sir:

Subject: Three Mile Island Nuclear Generating Station, Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Technical Specification Change Request (TSCR) No. 252, Revision 1
Removal of Makeup and Purification and Chemical Addition Systems
Requirements from Technical Specifications

In accordance with 10 CFR 50.4(b)(1), enclosed is Technical Specification Change Request No. 252, Revision 1. This revision supersedes TSCR No. 252, previously submitted on May 17, 1995 (C311-95-2225).

Also enclosed is a Certificate of Service for this request certifying service to the chief executives of the township and county in which the facility is located, as well as the designated official of the Commonwealth of Pennsylvania, Bureau of Radiation Protection.

The purpose of this TSCR is to request removal of Technical Specification Section 3.2, Makeup and Purification and Chemical Addition Systems, requirements and Bases from the Technical Specification. The pertinent design requirements and bases of this Technical Specification section are being incorporated into a licensee-controlled document (TMI-1 Updated Final Safety Analysis Report). This proposed change is consistent with the Standard Technical Specifications for Babcock and Wilcox Plants, NUREG-1430, July 1992, since Makeup and Purification and Chemical Addition System requirements are not specified in these Standard Technical Specifications. The proposed change is also consistent with NRC Commission guidance for the content of Technical Specifications issued in its "Final Policy Statement on Technical Specifications Improvements for Nuclear Power Reactors" ("Final Policy Statement"), 58 FR 39132 (July 22, 1993), which has recently been codified in a revision to 10 CFR 50.36 issued July 19, 1995, 60 FR 36953.

150056
9508150300 950811
PDR ADDCK 05000289
P PDR


GPU Nuclear Corporation is a subsidiary of General Public Utilities Corporation

ADD 11

It is requested that the amendment authorizing this change be issued by September 22, 1995 to support TMI-1 Cycle 11 startup (October 1995). This will preclude the need for an emergency technical specification change request to revise the boron storage volume and concentration requirements to be consistent with the specific Cycle 11 core reload evaluation.

Pursuant to 10 CFR 50.91(a)(1), enclosed is our analysis, applying the standards in 10 CFR 50.92 to make a determination of no significant hazards considerations.

Sincerely,



T. G. Broughton
Vice President and Director, TMI

DJD/plp

Enclosures: (1) Technical Specification Change Request No. 252, Revision 1
(2) Certificate of Service for Technical Specification Change Request No. 252, Revision 1

c: Administrator, Region I
TMI Senior Resident Inspector
TMI-1 Senior Project Manager