

Colt Industries



Fairbanks Morse
Engine Division
701 Lawton Avenue
Beloit, Wisconsin 53511
608/364-4411

March 8, 1984

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Ill. 60137

Attention: Mr. James G. Keppler, Director, Region III

Subject: Colt Industries-Fairbanks Morse Engine Division
Emergency Diesel Generators
South Carolina Electric & Gas Co.-Summer Station
January 14, 1980 Part 21 Report-Failed Engine Thrust Bearing
Supplement No. 5-Public Service of New Hampshire, Seabrook Unit 1


Gentlemen:

We have completed our inspection of the crankshaft thrust bearings on the two Diesel Generators for Public Service of New Hampshire, Seabrook Unit 1. The plugs were properly installed in both units. The units are free of the reported potential defect.

A copy of this report is being forwarded to the utility involved via the A/E.

We will report our findings on the remaining suspect units as the inspections are made, prior to their initial operation.

Very truly yours,


J. M. Moriarty
MANAGER UTILITY SALES

JMM:jc

cc: United Engineers & Constructors, Inc.
P. O. Box 8223
Philadelphia, PA 19101
Attention: Mr. D. H. Rhoads
Project Engineering Manager (Seabrook)

U. S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D. C. 20555

8403190248 840308
PDR ADOCK 05000395
S PDR

A division of the Colt Industries Operating Corp.

MAR 9 1984

IE 19
1/0