



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

34 MAR 15 4 8:38 March 12, 1984

NUCLEAR PRODUCTION DEPARTMENT

U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File: 0260/L-835.0
Special Report 84-014/0 - Fire
Doors Blocked Open to Support
Planned Maintenance Activities
AECM-84/0140

Beginning on February 4, 1984, the following fire doors were blocked open to support planned maintenance activities:

<u>Door No.</u>	<u>Location</u>	<u>Date Opened</u>	<u>Date Restored</u>
OC 102	Health Physics to Turb. Bldg. 93'	2/4/84	3/6/84
OC 105	Control Bldg. Southeast Stairwell 93'	2/4/84	3/6/84
1D 302	Diesel Generator Div. 1 Room	2/7/84	3/4/84
1A 203	Auxiliary Bldg. RCIC Room 119'	2/24/84	3/2/84
1A 204	Aux. Bldg. RHR "A" Piping Room 19'	2/15/84	3/7/84

Fire watches were established in accordance with Technical Specification 3.7.7 until the doors were restored.

This is submitted as a Special Report pursuant to Technical Specification 6.9.2 since the seven (7) day Limiting Condition for Operation (LCO) was exceeded. The event had no effect on the health and safety of the public and did not constitute a threat to plant safety. This is a final report.

Yours truly,

L. F. Dale
Manager of Nuclear Services

EBS/SHH:rg

cc: See next page

8403190292 840312
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

5622 1/0

MISSISSIPPI POWER & LIGHT COMPANY

AECM-84/0140

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555