



Boston Edison

Pilgrim Nuclear Power Station
Rocky Hill Road
Plymouth, Massachusetts 02360

PNPS TS Section 6.9.C.1.a
Reg. Guide 1.21

L. J. Olivier

Vice President Nuclear Operations
and Station Director

March 29, 1995
BECo Ltr. #95-039

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Docket No. 50-293
License No. DPR-35

The enclosed "Annual Dose Assessment to the General Public from Radioactive Effluents for 1994", is submitted in accordance with Pilgrim Nuclear Power Station Technical Specification 6.9.C.1.a.

Please do not hesitate to contact me if there are any questions regarding this report.


L.J. Olivier

WJM/lam/dose/compmtg

Attachment

cc: Mr. Thomas T. Martin
Region Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Sr. NRC Resident Inspector - Pilgrim Station

040108

9504040005 941231
PDR ADDCK 05000293
R PDR

JEH 8/1

PILGRIM NUCLEAR POWER STATION

Annual Dose Assessment to the General Public from Radioactive Effluents

January 1 through December 31, 1994



BOSTON EDISON COMPANY

PILGRIM NUCLEAR POWER STATION
ANNUAL DOSE ASSESSMENT TO THE GENERAL PUBLIC
FROM RADIOACTIVE EFFLUENTS

January 1 through December 31, 1994

Prepared by: *Kenneth B. Sejkora* 27 March 1995
K. J. Sejkora
Senior Environmental Radiochemist

Approved by: *S. R. Landahl* 3/28/95
S. R. Landahl
Radiological Protection Manager

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
<u>EXECUTIVE SUMMARY</u>	4
1.0 <u>MAXIMUM INDIVIDUAL DOSES</u>	6
1.1 Doses from Liquid Effluent Releases	6
1.2 Doses from Gaseous Effluent Releases	12
1.3 Doses from Noble Gas Releases	18
2.0 <u>POPULATION AND AVERAGE INDIVIDUAL DOSES</u>	20
2.1 Doses from Liquid Effluent Releases	22
2.2 Doses from Gaseous Effluent Releases	24
3.0 <u>OFFSITE DIRECT RADIATION MEASUREMENTS</u>	26
4.0 <u>PERCENT OF TECHNICAL SPECIFICATIONS LIMITS/OBJECTIVES</u>	29
4.1 Liquid Effluent Releases	29
4.2 Gaseous Effluent Releases	32
5.0 <u>REFERENCES</u>	35
<u>APPENDIX A: Effluent Release Information</u>	36
<u>APPENDIX B: Atmospheric Dispersion and Deposition Factors</u>	49

LIST OF TABLES

<u>Table</u>	<u>Table Title</u>	<u>Page</u>
1.1-1	Maximum Individual Organ Doses From Liquid Effluents January - March 1994	7
1.1-2	Maximum Individual Organ Doses From Liquid Effluents April - June 1994	8
1.1-3	Maximum Individual Organ Doses From Liquid Effluents July - September 1994	9
1.1-4	Maximum Individual Organ Doses From Liquid Effluents October - December 1994	10
1.1-5	Maximum Individual Organ Doses From Liquid Effluents January - December 1994	11
1.2-1	Maximum Individual Organ Doses From Gaseous Effluents January - March 1994	13
1.2-2	Maximum Individual Organ Doses From Gaseous Effluents April - June 1994	14
1.2-3	Maximum Individual Organ Doses From Gaseous Effluents July - September 1994	15
1.2-4	Maximum Individual Organ Doses From Gaseous Effluents October - December 1994	16
1.2-5	Maximum Individual Organ Doses From Gaseous Effluents January - December 1994	17
1.3-1	Maximum Doses From Noble Gas Releases During 1994	19
2.0-1	Population Distribution By Distance and Direction	21
2.1-1	Population Doses From Liquid Effluent Releases During 1994	23
2.1-2	Average Individual Doses From Liquid Effluent Releases During 1994	23
2.2-1	Population Doses From Gaseous Effluent Releases During 1994	25
2.2-2	Average Individual Doses From Gaseous Effluent Releases During 1994	25
3.0-1	Average TLD Exposures By Distance Zone During 1994	28
4.1-1	Percent of Technical Specifications Limits/Objectives For Liquid Effluent Releases During 1994	30
4.2-1	Percent of Technical Specifications Limits/Objectives For Gaseous Effluent Releases During 1994	33

EXECUTIVE SUMMARY

Pilgrim Nuclear Power Station Annual Dose Assessment To The General Public From Radioactive Effluents January 1 Through December 31, 1994

Introduction

This report quantifies the dose impact to the general public from the operation of Pilgrim Nuclear Power Station (PNPS) during the period of January 1 through December 31, 1994. The information presented in this report is prepared under Technical Specification 6.9.C.1.a as supplemental information to radioactive effluent release data submitted on a semiannual basis in accordance with NRC Regulatory Guide 1.21.

This report contains an assessment of radiological impact on humans resulting from releases of radioactivity in liquid and gaseous effluents and direct radiation exposure. Doses from radioactive effluents to a maximum exposed hypothetical individual were calculated for all major exposure pathways. In addition to maximum individual doses, cumulative population doses and average individual doses were calculated from the effluent release information. Direct radiation exposures as measured with environmental thermoluminescent dosimeters (TLDs) were also assessed.

The maximum individual doses calculated were used to determine the percent of Technical Specifications limit or objective which the doses represented. Liquid Effluent concentrations were also used to determine percent of Technical Specification concentration limits. These percentage values are the final supplemental data necessary to complete the two semiannual Radioactive Effluent and Waste Disposal Reports prepared during the reporting period.

Radiological Impact on Humans

The release of radioactivity in liquid effluents from PNPS during 1994 resulted in a total body dose of about 0.0002 mrem to the maximum-exposed hypothetical individual. The maximum hypothetical dose to any organ from liquid effluents was about 0.0003 mrem. The total body dose from liquid effluents to the entire population within 50 miles of PNPS was about 0.001 person-rem. The average individual living within 50 miles of PNPS received a total body dose of less than 0.0000003 mrem from liquid effluents released during 1994.

The release of radioactivity in gaseous effluents from PNPS during 1994 resulted in a total body dose to the maximum-exposed hypothetical individual of about 0.24 mrem from radioactive particulates, iodines and tritium. The maximum hypothetical dose to any organ from radioactive particulates, iodines and tritium was about 1.8 mrem. Noble gases released in gaseous effluents resulted in a maximum total body dose of 1.0 mrem, with a corresponding skin dose of 7.9 mrem. All of these maximum doses occurred to a hypothetical individual located on property under Boston Edison's (BECO) control. The maximum, hypothetical total body dose from the release of radioactivity in gaseous effluents was 1.2 mrem. The total body dose from gaseous effluents to the entire population within 50 miles of PNPS was about 0.8 person-rem. The average individual living within 50 miles of PNPS received a total body dose of less than 0.0002 mrem from gaseous effluents released during 1994.

Direct radiation exposure was evaluated to complete the assessment of radiological impact on humans. A small number of TLDs on BECo property in close proximity to the station indicated direct radiation exposure. However, the dose to a hypothetical member of the public accessing such areas on BECo property during 1994 was estimated as being about 1.5 mrem. There was no measurable increase during 1994 in direct radiation measurements at the nearest resident to PNPS.

The collective total body dose to a maximum-exposed hypothetical individual from liquids, gases, and direct exposure resulting from PNPS operations during 1994 was calculated as being 2.7 mrem. This amount is about 0.8% of the typical dose of 300 to 400 mrem received each year by an average person from other sources of natural and man-made radiation.

Percent of Technical Specifications

The maximum individual doses from radioactive effluents were compared to the applicable Technical Specifications dose limits and objectives. All doses from liquid effluents were less than 0.006% of their corresponding limit or objective. In addition, all quarterly average concentrations of liquids released to Cape Cod Bay were also less than 0.09% of the corresponding limits. Maximum doses resulting from releases of particulates, iodines and tritium in gaseous effluents were less than 12% of corresponding 10CFR50 objectives. Noble gas doses were less than 44% of the corresponding 10CFR50 dose objectives.

Conclusion

None of the PNPS Technical Specifications limits and objectives associated with liquid and gaseous effluents were exceeded during 1994. Compliance with these limits and objectives ensured that the radiological impact from PNPS operations was kept as low as is reasonably achievable, in accordance with 10CFR50 Appendix I. Furthermore, conformance with PNPS Technical Specifications demonstrated compliance with the Environmental Protection Agency's regulations for environmental radiation under 40CFR190. Based on the dose assessment results for 1994, there was no significant impact on the general public from Pilgrim Station's operation.

1.0 MAXIMUM INDIVIDUAL DOSES

Doses to the maximum exposed individual resulting from radionuclides in effluents released offsite were calculated using methods presented in the PNPS Offsite Dose Calculation Manual (ODCM, Ref. 1), NRC Regulatory Guide 1.109 (Ref. 2), NRC Regulatory Guide 1.111 (Ref. 3) and the Pilgrim Station Unit I Appendix I Evaluation (Ref. 4). Maximum individual doses are calculated separately for: (1) liquid effluents; (2) particulates, iodines and tritium in gaseous effluents; and, (3) noble gases in gaseous effluents. Maximum consumption and use factors for various pathways from Table E-5 of the PNPS ODCM are used for calculating the doses to the maximum-exposed individual.

Information related to liquid and gaseous effluent releases are summarized in two semiannual Radioactive Effluent and Waste Disposal Reports (Ref. 5 and 6). Copies of this information are included in Appendix A of this report. These effluent release data were used as input to computer programs to calculate the resulting doses. The Yankee Atomic Electric Company "YODA"-series of computer programs was used to compile the dose contributions to the various organs in each age class from major exposure pathways (Ref. 7).

1.1 Doses From Liquid Effluent Releases

Liquid effluent release data presented in Tables 2A and 2B from the semiannual effluent release reports were used as input to the Yankee Atomic "YODA" computer programs to calculate radiation doses. The maximum individual doses resulting from radionuclides released in liquid effluents are presented in Tables 1.1-1 through 1.1-5. These tables cover the individual calendar quarters and total calendar year, respectively.

Tables 1.1-1 through 1.1-5 summarize the maximum total body and organ doses for the adult, teen and child age classes resulting from the major liquid exposure pathways. NRC Regulatory Guide 1.109 does not recognize the infant age class as being exposed to the liquid effluent pathways. Therefore, doses for this age class are not included in any of the tables.

Radioactivity released in liquid effluents from PNPS during 1994 resulted in a maximum total body dose (teen age class) of $1.56\text{E-}04$ mrem. The maximum organ dose (child age class, bone) was $3.11\text{E-}04$ mrem.

Table 1.1-1

MAXIMUM INDIVIDUAL ORGAN DOSES BY EXPOSURE PATHWAY -- mrem
from Liquid Release Period: January-March 1994

Exposure Pathway:	Saltwater Fish	Saltwater Shellfish	Shoreline Deposits	Swimming/ Boating	Total
Age-Class: Adult					
Bone	1.30E-05	3.23E-05	3.21E-06	8.09E-09	4.85E-05
Liver	1.19E-05	2.29E-05	3.21E-06	8.09E-09	3.80E-05
Kidney	1.61E-06	4.73E-07	3.21E-06	8.09E-09	5.30E-06
Lung	4.23E-06	1.08E-05	3.21E-06	8.09E-09	1.82E-05
GI-LLI	1.91E-05	6.12E-05	3.21E-06	8.09E-09	8.35E-05
Whole-Body	5.61E-06	1.18E-05	3.21E-06	8.09E-09	2.06E-05
Thyroid	1.50E-07	6.66E-08	3.21E-06	8.09E-09	3.43E-06
Age-Class: Teen					
Bone	1.35E-05	2.89E-05	1.79E-05	8.09E-09	6.03E-05
Liver	1.24E-05	2.13E-05	1.79E-05	8.09E-09	5.16E-05
Kidney	1.62E-06	4.11E-07	1.79E-05	8.09E-09	2.00E-05
Lung	5.10E-06	1.15E-05	1.79E-05	8.09E-09	3.45E-05
GI-LLI	1.36E-05	3.82E-05	1.79E-05	8.09E-09	6.97E-05
Whole-Body	4.74E-06	1.03E-05	1.79E-05	8.09E-09	3.30E-05
Thyroid	1.16E-07	4.48E-08	1.79E-05	8.09E-09	1.81E-05
Age-Class: Child					
Bone	1.72E-05	4.27E-05	3.75E-06	4.51E-09	6.36E-05
Liver	1.16E-05	2.37E-05	3.75E-06	4.51E-09	3.90E-05
Kidney	1.35E-06	3.96E-07	3.75E-06	4.51E-09	5.50E-06
Lung	4.43E-06	1.17E-05	3.75E-06	4.51E-09	1.98E-05
GI-LLI	4.93E-06	1.60E-05	3.75E-06	4.51E-09	2.46E-05
Whole-Body	4.58E-06	1.36E-05	3.75E-06	4.51E-09	2.19E-05
Thyroid	9.55E-08	4.29E-08	3.75E-06	4.51E-09	3.89E-06

Table 1.1-2

MAXIMUM INDIVIDUAL ORGAN DOSES DUE TO LIQUID RELEASES -- mrem
from Liquid Release Period: April-June 1994

Exposure Pathway:	Saltwater Fish	Saltwater Shellfish	Shoreline Deposits	Swimming/ Boating	Total
Age-Class: Adult					
Bone	1.26E-05	2.87E-05	3.06E-06	7.22E-09	4.43E-05
Liver	1.16E-05	1.82E-05	3.06E-06	7.22E-09	3.28E-05
Kidney	2.19E-06	6.37E-07	3.06E-06	7.22E-09	5.89E-06
Lung	3.60E-06	8.21E-06	3.06E-06	7.22E-09	1.48E-05
GI-LLI	1.54E-05	5.17E-05	3.06E-06	7.22E-09	7.01E-05
Whole-Body	6.44E-06	1.11E-05	3.06E-06	7.22E-09	2.06E-05
Thyroid	2.43E-07	1.07E-07	3.06E-06	7.22E-09	3.41E-06
Age-Class: Teen					
Bone	1.29E-05	2.50E-05	1.71E-05	7.22E-09	5.50E-05
Liver	1.21E-05	1.69E-05	1.71E-05	7.22E-09	4.61E-05
Kidney	2.20E-06	5.53E-07	1.71E-05	7.22E-09	1.98E-05
Lung	4.29E-06	8.74E-06	1.71E-05	7.22E-09	3.01E-05
GI-LLI	1.10E-05	3.23E-05	1.71E-05	7.22E-09	6.04E-05
Whole-Body	4.95E-06	9.40E-06	1.71E-05	7.22E-09	3.14E-05
Thyroid	1.87E-07	7.23E-08	1.71E-05	7.22E-09	1.73E-05
Age-Class: Child					
Bone	1.62E-05	3.55E-05	3.57E-06	4.03E-09	5.52E-05
Liver	1.12E-05	1.87E-05	3.57E-06	4.03E-09	3.34E-05
Kidney	1.87E-06	5.44E-07	3.57E-06	4.03E-09	5.99E-06
Lung	3.69E-06	8.85E-06	3.57E-06	4.03E-09	1.61E-05
GI-LLI	4.03E-06	1.35E-05	3.57E-06	4.03E-09	2.11E-05
Whole-Body	4.21E-06	1.19E-05	3.57E-06	4.03E-09	1.96E-05
Thyroid	1.54E-07	6.92E-08	3.57E-06	4.03E-09	3.80E-06

Table 1.1-3

MAXIMUM INDIVIDUAL ORGAN DOSES DUE TO LIQUID RELEASES -- mrem
from Liquid Release Period: July-September 1994

Exposure Pathway:	Saltwater Fish	Saltwater Shellfish	Shoreline Deposits	Swimming/ Boating	Total
Age-Class: Adult					
Bone	3.50E-05	8.00E-05	5.51E-06	1.07E-08	1.20E-04
Liver	2.56E-05	1.59E-05	5.51E-06	1.07E-08	4.70E-05
Kidney	7.69E-06	2.09E-06	5.51E-06	1.07E-08	1.53E-05
Lung	4.00E-06	4.67E-06	5.51E-06	1.07E-08	1.41E-05
GI-LLI	1.58E-05	6.12E-05	5.51E-06	1.07E-08	8.25E-05
Whole-Body	1.96E-05	2.40E-05	5.51E-06	1.07E-08	4.91E-05
Thyroid	1.27E-07	5.61E-08	5.51E-06	1.07E-08	5.70E-06
Age-Class: Teen					
Bone	3.49E-05	6.52E-05	3.07E-05	1.07E-08	1.30E-04
Liver	2.66E-05	1.46E-05	3.07E-05	1.07E-08	7.19E-05
Kidney	7.99E-06	1.89E-06	3.07E-05	1.07E-08	4.06E-05
Lung	4.83E-06	4.97E-06	3.07E-05	1.07E-08	4.05E-05
GI-LLI	1.12E-05	3.80E-05	3.07E-05	1.07E-08	7.99E-05
Whole-Body	1.27E-05	1.81E-05	3.07E-05	1.07E-08	6.15E-05
Thyroid	9.75E-08	3.78E-08	3.07E-05	1.07E-08	3.09E-05
Age-Class: Child					
Bone	4.07E-05	8.12E-05	6.44E-06	6.00E-09	1.28E-04
Liver	2.42E-05	1.56E-05	6.44E-06	6.00E-09	4.62E-05
Kidney	6.92E-06	1.90E-06	6.44E-06	6.00E-09	1.52E-05
Lung	4.00E-06	4.98E-06	6.44E-06	6.00E-09	1.54E-05
GI-LLI	4.08E-06	1.57E-05	6.44E-06	6.00E-09	2.62E-05
Whole-Body	7.82E-06	1.98E-05	6.44E-06	6.00E-09	3.40E-05
Thyroid	8.05E-08	3.62E-08	6.44E-06	6.00E-09	6.56E-06

Table 1.1-4

MAXIMUM INDIVIDUAL ORGAN DOSES DUE TO LIQUID RELEASES -- mrem
from Liquid Release Period: October-December 1994

Exposure Pathway:	Saltwater Fish	Saltwater Shellfish	Shoreline Deposits	Swimming/ Boating	Total
Age-Class: Adult					
Bone	1.16E-05	2.07E-05	2.18E-06	4.55E-09	3.44E-05
Liver	1.22E-05	1.49E-05	2.18E-06	4.55E-09	2.92E-05
Kidney	3.05E-06	9.23E-07	2.18E-06	4.55E-09	6.16E-06
Lung	3.59E-06	6.81E-06	2.18E-06	4.55E-09	1.25E-05
GI-LLI	9.41E-06	3.11E-05	2.18E-06	4.55E-09	4.27E-05
Whole-Body	6.99E-06	7.64E-06	2.18E-06	4.55E-09	1.68E-05
Thyroid	5.80E-07	2.57E-07	2.18E-06	4.55E-09	3.02E-06
Age-Class: Teen					
Bone	1.21E-05	1.85E-05	1.21E-05	4.55E-09	4.27E-05
Liver	1.26E-05	1.38E-05	1.21E-05	4.55E-09	3.85E-05
Kidney	3.02E-06	7.80E-07	1.21E-05	4.55E-09	1.59E-05
Lung	4.13E-06	7.17E-06	1.21E-05	4.55E-09	2.34E-05
GI-LLI	6.83E-06	1.96E-05	1.21E-05	4.55E-09	3.86E-05
Whole-Body	4.86E-06	6.29E-06	1.21E-05	4.55E-09	2.33E-05
Thyroid	4.46E-07	1.73E-07	1.21E-05	4.55E-09	1.28E-05
Age-Class: Child					
Bone	1.54E-05	2.71E-05	2.54E-06	2.53E-09	4.50E-05
Liver	1.17E-05	1.52E-05	2.54E-06	2.53E-09	2.94E-05
Kidney	2.60E-06	7.73E-07	2.54E-06	2.53E-09	5.92E-06
Lung	3.52E-06	7.25E-06	2.54E-06	2.53E-09	1.33E-05
GI-LLI	2.70E-06	8.33E-06	2.54E-06	2.53E-09	1.35E-05
Whole-Body	3.54E-06	7.83E-06	2.54E-06	2.53E-09	1.39E-05
Thyroid	3.68E-07	1.65E-07	2.54E-06	2.53E-09	3.08E-06

Table 1.1-5

MAXIMUM INDIVIDUAL ORGAN DOSES DUE TO LIQUID RELEASES -- mrem
from Liquid Release Period: January-December 1994

Exposure Pathway:	Saltwater Fish	Saltwater Shellfish	Shoreline Deposits	Swimming/ Boating	Total
Age-Class: Adult					
Bone	7.92E-05	1.76E-04	1.44E-05	3.07E-08	2.69E-04
Liver	6.53E-05	6.78E-05	1.44E-05	3.07E-08	1.47E-04
Kidney	1.66E-05	4.68E-06	1.44E-05	3.07E-08	3.58E-05
Lung	1.51E-05	2.76E-05	1.44E-05	3.07E-08	5.72E-05
GI-LLI	5.67E-05	1.99E-04	1.44E-05	3.07E-08	2.70E-04
Whole-Body	4.32E-05	5.77E-05	1.44E-05	3.07E-08	1.15E-04
Thyroid	1.10E-06	4.88E-07	1.44E-05	3.07E-08	1.61E-05
Age-Class: Teen					
Bone	8.01E-05	1.48E-04	8.06E-05	3.07E-08	3.08E-04
Liver	6.81E-05	6.26E-05	8.06E-05	3.07E-08	2.11E-04
Kidney	1.70E-05	4.15E-06	8.06E-05	3.07E-08	1.01E-04
Lung	1.79E-05	2.93E-05	8.06E-05	3.07E-08	1.27E-04
GI-LLI	4.05E-05	1.24E-04	8.06E-05	3.07E-08	2.45E-04
Whole-Body	2.97E-05	4.58E-05	8.06E-05	3.07E-08	1.56E-04
Thyroid	8.47E-07	3.28E-07	8.06E-05	3.07E-08	8.18E-05
Age-Class: Child					
Bone	9.68E-05	1.97E-04	1.68E-05	1.71E-08	3.10E-04
Liver	6.25E-05	6.87E-05	1.68E-05	1.71E-08	1.48E-04
Kidney	1.47E-05	4.13E-06	1.68E-05	1.71E-08	3.57E-05
Lung	1.52E-05	2.96E-05	1.68E-05	1.71E-08	6.16E-05
GI-LLI	1.50E-05	5.18E-05	1.68E-05	1.71E-08	8.36E-05
Whole-Body	2.09E-05	5.40E-05	1.68E-05	1.71E-08	9.17E-05
Thyroid	7.00E-07	3.14E-07	1.68E-05	1.71E-08	1.79E-05

1.2 Doses From Gaseous Effluent Releases

Gaseous effluent release data presented in Tables 1A, 1B, and 1C from the semiannual effluent release reports were used as input to the Yankee Atomic "YODA" computer programs to calculate radiation doses. These data include gaseous releases from the PNPS main stack, reactor building vent, turbine building roof exhausters, and tool decontamination facility. Meteorological data obtained from the PNPS 220-foot meteorological tower during 1994 were also used as input to the Yankee Atomic Electric Company's "AEOLUS" computer program (Ref. 8). This computer program calculated the atmospheric dispersion and deposition factors used in the "YODA"-series of computer programs to calculate maximum individual doses. These various dispersion (X/Q) and deposition (D/Q) factors are presented in Appendix B of this report.

The maximum individual doses resulting from radioactive particulates, iodines and tritium released in gaseous effluents are presented in Tables 1.2-1 through 1.2-5. These tables cover the individual calendar quarters and total calendar year, respectively. Doses resulting from releases of noble gases are addressed independently in the PNPS Technical Specifications. Therefore, none of these tables for maximum individual doses include any dose contributions from noble gases. The presentation and analysis of doses resulting from noble gases are addressed in Section 1.3 of this report.

Tables 1.2-1 through 1.2-5 summarize the maximum total body and organ doses for the adult, teen, child and infant age classes resulting from the major gaseous exposure pathways. These tables present the dose data according to specific receptor location and the exposure pathways assumed to occur at that location. For example, the second column of the tables presents the information for the hypothetical maximum-exposed individual at the most restrictive site boundary location, where only inhalation and ground deposition exposure pathways are assumed to occur. Since this is a shoreline location effectively controlled by Boston Edison Company, the other pathways of garden vegetable production, milk production and meat production are assumed not to occur. Doses for other offsite locations not under Boston Edison control, where other exposure pathways can and do occur, are presented in subsequent columns of the tables, and represent the potential maximum doses to individuals at these locations.

Radioactivity released in gaseous effluents from PNPS during 1994 resulted in a maximum total body dose (teen age class) of $2.44\text{E-}01$ mrem. The maximum organ dose (child age class, thyroid) was $1.78\text{E+}00$ mrem. Both of these doses occurred to hypothetical individuals at the shoreline 110 meters north-northeast of the PNPS Reactor Building, an area effectively under Boston Edison Control. For the more "realistic" individuals at offsite locations, the maximum total body dose was $1.35\text{E-}02$ mrem (child age class at a location 820 meters [0.5 miles] southeast of the Reactor Building yielding garden vegetables), while the maximum organ dose was $2.75\text{E-}01$ mrem (infant thyroid at a location 3970 meters [2.5 miles] west-southwest, yielding vegetables and cow and goat milk).

Table 1.2-1

MAXIMUM INDIVIDUAL ORGAN DOSE AT RECEPTOR LOCATION -- mrem
From Gaseous Release Period: January-March 1994

Receptor:	Boundary	Cow/Goat	Garden	Cow/Meat	Resident	Meat
Direction:	N	WSW	SE	W	ESE	S
Distance:	80 m	3970 m	820 m	5770 m	800 m	3800 m
Pathway*:	DI	DIVCG	DIV	DIVCM	DI	DIVM
Age-Class: Adult						
Bone	3.06E-03	3.73E-04	4.61E-03	4.63E-05	1.56E-04	2.73E-04
Liver	3.25E-02	1.75E-04	2.09E-03	2.86E-05	1.03E-03	1.23E-04
Kidney	3.32E-02	1.99E-04	2.11E-03	3.18E-05	1.04E-03	1.26E-04
Lung	3.87E-02	1.24E-04	2.09E-03	2.40E-05	1.20E-03	1.22E-04
GI-LLI	3.36E-02	1.93E-04	2.82E-03	3.27E-05	1.06E-03	1.67E-04
Thyroid	1.95E-01	1.38E-02	2.14E-02	1.61E-03	5.51E-03	1.85E-03
W-Body	3.20E-02	1.60E-04	2.16E-03	2.72E-05	1.01E-03	1.27E-04
Age-Class: Teen						
Bone	3.73E-03	6.15E-04	6.92E-03	7.16E-05	1.74E-04	4.02E-04
Liver	3.31E-02	2.37E-04	2.31E-03	3.45E-05	1.04E-03	1.31E-04
Kidney	3.39E-02	2.79E-04	2.32E-03	3.98E-05	1.07E-03	1.33E-04
Lung	4.37E-02	1.50E-04	2.38E-03	2.72E-05	1.33E-03	1.33E-04
GI-LLI	3.40E-02	2.31E-04	3.09E-03	3.62E-05	1.07E-03	1.76E-04
Thyroid	2.45E-01	2.11E-02	1.96E-02	2.32E-03	6.90E-03	1.62E-03
W-Body	3.23E-02	2.02E-04	2.43E-03	3.15E-05	1.02E-03	1.37E-04
Age-Class: Child						
Bone	4.56E-03	1.48E-03	1.63E-02	1.69E-04	1.97E-04	9.38E-04
Liver	2.95E-02	3.71E-04	3.17E-03	5.11E-05	9.38E-04	1.78E-04
Kidney	3.03E-02	4.33E-04	3.16E-03	5.89E-05	9.59E-04	1.79E-04
Lung	3.88E-02	2.16E-04	3.16E-03	3.72E-05	1.19E-03	1.76E-04
GI-LLI	2.93E-02	2.76E-04	3.66E-03	4.37E-05	9.32E-04	2.06E-04
Thyroid	2.93E-01	4.16E-02	2.88E-02	4.47E-03	8.21E-03	2.39E-03
W-Body	2.89E-02	3.20E-04	3.50E-03	4.76E-05	9.20E-04	1.96E-04
Age-Class: Infant						
Bone	3.68E-03	1.44E-03	1.03E-04	8.98E-05	1.73E-04	6.04E-06
Liver	1.81E-02	5.35E-04	3.58E-04	4.91E-05	5.99E-04	1.95E-05
Kidney	1.82E-02	5.45E-04	3.61E-04	5.28E-05	6.04E-04	1.97E-05
Lung	2.66E-02	1.78E-04	5.00E-04	1.73E-05	8.36E-04	2.75E-05
GI-LLI	1.73E-02	2.06E-04	3.46E-04	1.85E-05	5.78E-04	1.86E-05
Thyroid	2.61E-01	9.73E-02	4.38E-03	9.90E-03	7.29E-03	2.87E-04
W-Body	1.73E-02	3.34E-04	3.46E-04	3.07E-05	5.79E-04	1.87E-05

* Pathway designations are as follows:

D = Deposition (Ground Plane) C = Cow Milk
I = Inhalation G = Goat Milk
V = Vegetable Garden M = Meat

Table 1.2-2

MAXIMUM INDIVIDUAL ORGAN DOSE AT RECEPTOR LOCATION -- mrem
From Gaseous Release Period: April-June 1994

Receptor: Direction: Distance: Pathway*:	Boundary NNE 100 m DI	Cow/Goat WSW 3970 m DIVCG	Garden SE 820 m DIV	Cow/Meat W 5770 m DIVCM	Resident ESE 800 m DI	Meat S 3800 m DIVM
Age-Class: Adult						
Bone	8.62E-03	1.71E-04	1.27E-03	6.95E-05	9.54E-05	2.27E-04
Liver	5.84E-02	1.22E-04	1.83E-03	4.15E-05	6.27E-04	1.23E-04
Kidney	5.98E-02	1.42E-04	1.87E-03	4.72E-05	6.41E-04	1.27E-04
Lung	6.35E-02	8.45E-05	1.83E-03	3.22E-05	6.78E-04	1.18E-04
GI-LLI	5.89E-02	1.17E-04	2.02E-03	4.48E-05	6.32E-04	1.54E-04
Thyroid	4.13E-01	1.05E-02	1.68E-02	2.91E-03	4.19E-03	2.48E-03
W-Body	5.72E-02	1.11E-04	1.83E-03	4.01E-05	6.15E-04	1.29E-04
Age-Class: Teen						
Bone	9.47E-03	2.77E-04	1.88E-03	1.05E-04	1.04E-04	3.24E-04
Liver	5.94E-02	1.66E-04	2.02E-03	5.13E-05	6.37E-04	1.30E-04
Kidney	6.14E-02	2.00E-04	2.06E-03	6.05E-05	6.57E-04	1.33E-04
Lung	6.84E-02	1.02E-04	2.05E-03	3.64E-05	7.28E-04	1.28E-04
GI-LLI	5.94E-02	1.40E-04	2.22E-03	4.95E-05	6.37E-04	1.61E-04
Thyroid	5.23E-01	1.60E-02	1.60E-02	4.21E-03	5.29E-03	2.17E-03
W-Body	5.78E-02	1.40E-04	2.03E-03	4.60E-05	6.20E-04	1.38E-04
Age-Class: Child						
Bone	1.05E-02	6.51E-04	4.33E-03	2.40E-04	1.15E-04	7.28E-04
Liver	5.36E-02	2.61E-04	2.76E-03	7.68E-05	5.75E-04	1.76E-04
Kidney	5.53E-02	3.10E-04	2.79E-03	9.03E-05	5.92E-04	1.78E-04
Lung	6.11E-02	1.46E-04	2.76E-03	4.95E-05	6.51E-04	1.68E-04
GI-LLI	5.22E-02	1.74E-04	2.86E-03	5.90E-05	5.61E-04	1.90E-04
Thyroid	6.29E-01	3.15E-02	2.31E-02	8.11E-03	6.36E-03	3.21E-03
W-Body	5.21E-02	2.19E-04	2.83E-03	7.10E-05	5.60E-04	1.97E-04
Age-Class: Infant						
Bone	9.51E-03	6.70E-04	7.96E-05	1.33E-04	1.04E-04	9.01E-06
Liver	3.46E-02	3.84E-04	3.20E-04	8.36E-05	3.72E-04	2.19E-05
Kidney	3.50E-02	3.97E-04	3.23E-04	8.92E-05	3.76E-04	2.22E-05
Lung	4.15E-02	1.21E-04	3.83E-04	2.36E-05	4.42E-04	2.86E-05
GI-LLI	3.26E-02	1.35E-04	3.02E-04	2.58E-05	3.52E-04	2.05E-05
Thyroid	5.64E-01	7.37E-02	5.11E-03	1.80E-02	5.70E-03	4.14E-04
W-Body	3.29E-02	2.30E-04	3.05E-04	4.83E-05	3.56E-04	2.08E-05

* Pathway designations are as follows:

D = Deposition (Ground Plane) C = Cow Milk
I = Inhalation G = Goat Milk
V = Vegetable Garden M = Meat

Table 1.2-3

MAXIMUM INDIVIDUAL ORGAN DOSE AT RECEPTOR LOCATION -- mrem
 From Gaseous Release Period: July-September 1994

Receptor:	Boundary	Cow/Goat	Garden	Cow/Meat	Resident	Meat
Direction:	NE	WSW	SE	W	ESE	S
Distance:	110 m	3970 m	820 m	5770 m	800 m	3800 m
Pathway*:	DI	DIVCG	DIV	DIVCM	DI	DIVM
Age-Class: Adult						
Bone	3.25E-03	7.17E-05	4.73E-04	1.50E-05	2.79E-05	6.56E-05
Liver	1.49E-01	2.96E-04	3.41E-03	7.15E-05	1.16E-03	3.66E-04
Kidney	1.51E-01	3.21E-04	3.45E-03	7.60E-05	1.17E-03	3.71E-04
Lung	1.55E-01	2.47E-04	3.42E-03	6.38E-05	1.20E-03	3.59E-04
GI-LLI	1.50E-01	2.67E-04	3.50E-03	6.79E-05	1.16E-03	3.73E-04
Thyroid	5.97E-01	1.34E-02	1.54E-02	2.32E-03	4.42E-03	2.86E-03
W-Body	1.48E-01	2.74E-04	3.40E-03	6.80E-05	1.15E-03	3.62E-04
Age-Class: Teen						
Bone	4.12E-03	1.20E-04	6.92E-04	2.32E-05	3.42E-05	9.14E-05
Liver	1.51E-01	3.79E-04	3.77E-03	8.32E-05	1.17E-03	3.87E-04
Kidney	1.53E-01	4.21E-04	3.81E-03	9.06E-05	1.19E-03	3.91E-04
Lung	1.61E-01	2.96E-04	3.80E-03	7.07E-05	1.25E-03	3.83E-04
GI-LLI	1.51E-01	3.18E-04	3.85E-03	7.49E-05	1.17E-03	3.93E-04
Thyroid	7.34E-01	2.04E-02	1.51E-02	3.34E-03	5.42E-03	2.58E-03
W-Body	1.49E-01	3.34E-04	3.76E-03	7.65E-05	1.16E-03	3.83E-04
Age-Class: Child						
Bone	5.20E-03	2.84E-04	1.59E-03	5.34E-05	4.21E-05	2.05E-04
Liver	1.34E-01	5.78E-04	5.19E-03	1.21E-04	1.04E-03	5.29E-04
Kidney	1.36E-01	6.40E-04	5.23E-03	1.32E-04	1.06E-03	5.32E-04
Lung	1.42E-01	4.32E-04	5.20E-03	9.92E-05	1.10E-03	5.20E-04
GI-LLI	1.32E-01	4.48E-04	5.22E-03	1.02E-04	1.03E-03	5.25E-04
Thyroid	8.55E-01	3.99E-02	2.15E-02	6.42E-03	6.30E-03	3.76E-03
W-Body	1.32E-01	5.02E-04	5.21E-03	1.10E-04	1.03E-03	5.24E-04
Age-Class: Infant						
Bone	4.24E-03	4.00E-04	3.00E-05	5.38E-05	3.51E-05	6.10E-06
Liver	7.87E-02	6.84E-04	5.10E-04	9.14E-05	6.13E-04	5.16E-05
Kidney	7.92E-02	7.00E-04	5.13E-04	9.60E-05	6.17E-04	5.20E-05
Lung	8.64E-02	3.51E-04	5.56E-04	4.38E-05	6.69E-04	5.57E-05
GI-LLI	7.63E-02	3.61E-04	4.95E-04	4.51E-05	5.95E-04	4.98E-05
Thyroid	7.42E-01	9.30E-02	4.54E-03	1.41E-02	5.45E-03	5.31E-04
W-Body	7.67E-02	4.75E-04	4.97E-04	6.22E-05	5.99E-04	5.02E-05

* Pathway designations are as follows:

D = Deposition (Ground Plane) C = Cow Milk
 I = Inhalation G = Goat Milk
 V = Vegetable Garden M = Meat

Table 1.2-4

MAXIMUM INDIVIDUAL ORGAN DOSE AT RECEPTOR LOCATION -- mrem
From Gaseous Release Period: October-December 1994

Receptor: Direction: Distance: Pathway*	Boundary NE 110 m DI	Cow/Goat WSW 3970 m DIVCG	Garden SE 820 m DIV	Cow/Meat W 5770 m DIVCM	Resident ESE 800 m DI	Meat S 3800 m DIVM
Age-Class: Adult						
Bone	1.23E-03	4.90E-05	1.48E-03	8.14E-06	2.47E-05	6.47E-05
Liver	3.89E-02	5.48E-05	1.47E-03	9.27E-06	5.63E-04	8.60E-05
Kidney	3.91E-02	5.93E-05	1.47E-03	9.97E-06	5.65E-04	8.69E-05
Lung	4.23E-02	4.79E-05	1.49E-03	8.38E-06	6.08E-04	8.63E-05
GI-LLI	3.96E-02	5.73E-05	1.71E-03	9.96E-06	5.73E-04	9.65E-05
Thyroid	7.63E-02	2.13E-03	3.72E-03	3.12E-04	1.08E-03	4.78E-04
W-Body	3.88E-02	5.26E-05	1.50E-03	8.99E-06	5.61E-04	8.70E-05
Age-Class: Teen						
Bone	1.55E-03	8.10E-05	2.24E-03	1.26E-05	2.89E-05	9.53E-05
Liver	3.92E-02	6.92E-05	1.63E-03	1.08E-05	5.68E-04	9.11E-05
Kidney	3.95E-02	7.68E-05	1.63E-03	1.19E-05	5.70E-04	9.18E-05
Lung	4.50E-02	5.74E-05	1.67E-03	9.34E-06	6.45E-04	9.25E-05
GI-LLI	3.99E-02	6.85E-05	1.89E-03	1.10E-05	5.77E-04	1.02E-04
Thyroid	8.83E-02	3.24E-03	3.68E-03	4.50E-04	1.24E-03	4.35E-04
W-Body	3.91E-02	6.44E-05	1.68E-03	1.02E-05	5.65E-04	9.27E-05
Age-Class: Child						
Bone	1.95E-03	1.95E-04	5.28E-03	2.99E-05	3.43E-05	2.23E-04
Liver	3.48E-02	1.05E-04	2.24E-03	1.57E-05	5.04E-04	1.25E-04
Kidney	3.50E-02	1.16E-04	2.24E-03	1.74E-05	5.07E-04	1.25E-04
Lung	3.99E-02	8.37E-05	2.27E-03	1.30E-05	5.72E-04	1.25E-04
GI-LLI	3.50E-02	9.22E-05	2.43E-03	1.43E-05	5.06E-04	1.32E-04
Thyroid	9.64E-02	6.37E-03	5.27E-03	8.68E-04	1.35E-03	6.35E-04
W-Body	3.46E-02	9.86E-05	2.37E-03	1.50E-05	5.02E-04	1.29E-04
Age-Class: Infant						
Bone	1.49E-03	1.92E-04	2.23E-05	1.61E-05	2.82E-05	1.34E-06
Liver	2.03E-02	1.18E-04	2.21E-04	1.19E-05	2.98E-04	1.19E-05
Kidney	2.04E-02	1.23E-04	2.22E-04	1.28E-05	2.98E-04	1.19E-05
Lung	2.51E-02	6.77E-05	2.68E-04	5.79E-06	3.61E-04	1.42E-05
GI-LLI	2.02E-02	7.21E-05	2.20E-04	6.12E-06	2.96E-04	1.16E-05
Thyroid	7.70E-02	1.48E-02	7.99E-04	1.91E-03	1.08E-03	8.71E-05
W-Body	2.02E-02	9.09E-05	2.19E-04	8.43E-06	2.95E-04	1.16E-05

* Pathway designations are as follows:

D = Deposition (Ground Plane) C = Cow Milk
I = Inhalation G = Goat Milk
V = Vegetable Garden M = Meat

Table 1.2-5

MAXIMUM INDIVIDUAL ORGAN DOSE AT RECEPTOR LOCATION -- mrem
From Gaseous Release Period: January-December 1994

Receptor:	Boundary	Cow/Goat	Garden	Cow/Meat	Resident	Meat
Direction:	NE	WSW	SE	W	ESE	S
Distance:	110 m	3970 m	820 m	5770 m	800 m	3800 m
Pathway:	DI	DIVCG	DIV	DIVCM	DI	DIVM
Age-Class: Adult						
Bone	1.65E-02	6.34E-04	6.99E-03	1.36E-04	3.51E-04	6.58E-04
Liver	2.45E-01	6.03E-04	8.58E-03	1.37E-04	3.50E-03	6.50E-04
Kidney	2.49E-01	6.77E-04	8.69E-03	1.50E-04	3.55E-03	6.63E-04
Lung	2.88E-01	4.65E-04	8.60E-03	1.17E-04	3.80E-03	6.40E-04
GI-LLI	2.49E-01	5.88E-04	9.69E-03	1.43E-04	3.55E-03	7.48E-04
Thyroid	1.21E+00	3.93E-02	6.05E-02	6.59E-03	1.60E-02	7.52E-03
W-Body	2.42E-01	5.56E-04	8.65E-03	1.31E-04	3.46E-03	6.59E-04
Age-Class: Teen						
Bone	1.94E-02	1.04E-03	1.04E-02	2.08E-04	3.88E-04	9.50E-04
Liver	2.49E-01	7.94E-04	9.48E-03	1.63E-04	3.55E-03	6.88E-04
Kidney	2.51E-01	9.22E-04	9.58E-03	1.85E-04	3.62E-03	6.99E-04
Lung	2.80E-01	5.58E-04	9.64E-03	1.31E-04	4.06E-03	6.90E-04
GI-LLI	2.51E-01	7.02E-04	1.06E-02	1.58E-04	3.58E-03	7.86E-04
Thyroid	1.50E+00	6.00E-02	5.69E-02	9.51E-03	1.98E-02	6.68E-03
W-Body	2.44E-01	6.90E-04	9.61E-03	1.50E-04	3.49E-03	7.02E-04
Age-Class: Child						
Bone	2.30E-02	2.47E-03	2.43E-02	4.83E-04	4.35E-04	2.18E-03
Liver	2.22E-01	1.23E-03	1.30E-02	2.40E-04	3.18E-03	9.36E-04
Kidney	2.27E-01	1.42E-03	1.31E-02	2.72E-04	3.24E-03	9.44E-04
Lung	2.56E-01	8.07E-04	1.30E-02	1.80E-04	3.62E-03	9.21E-04
GI-LLI	2.19E-01	9.14E-04	1.37E-02	2.00E-04	3.14E-03	9.85E-04
Thyroid	1.78E+00	1.18E-01	8.26E-02	1.83E-02	2.34E-02	9.80E-03
W-Body	2.18E-01	1.06E-03	1.35E-02	2.22E-04	3.13E-03	9.79E-04
Age-Class: Infant						
Bone	1.94E-02	2.56E-03	2.75E-04	2.81E-04	3.88E-04	2.70E-05
Liver	1.34E-01	1.64E-03	1.41E-03	2.16E-04	1.97E-03	1.02E-04
Kidney	1.35E-01	1.69E-03	1.42E-03	2.30E-04	1.99E-03	1.03E-04
Lung	1.66E-01	6.60E-04	1.70E-03	8.26E-05	2.38E-03	1.26E-04
GI-LLI	1.29E-01	7.14E-04	1.37E-03	8.73E-05	1.91E-03	9.81E-05
Thyroid	1.57E+00	2.75E-01	1.48E-02	4.05E-02	2.06E-02	1.32E-03
W-Body	1.30E-01	1.06E-03	1.37E-03	1.37E-04	1.92E-03	9.87E-05

* Pathway designations are as follows:

D = Deposition (Ground Plane) C = Cow Milk
I = Inhalation G = Goat Milk
V = Vegetable Garden M = Meat

1.3 Doses From Noble Gas Releases

Noble gas release data presented in Tables 1A, 1B, and 1C from the semiannual effluent release reports were used as input to the Yankee Atomic "YODA" computer programs to calculate radiation doses. Doses resulting from noble gas releases were calculated using 1994 meteorological data, as described in Section 1.2 of this report. The various dispersion (X/Q) factors calculated with the "AEOLUS" computer program and used to estimate doses from noble gases are presented in Appendix B of this report.

The maximum individual doses resulting from radioactive noble gases released in gaseous effluents are presented in Table 1.3-1 according to specific receptor location. This table includes all noble gas doses for the individual calendar quarters and total calendar year.

Noble gases released in gaseous effluents from PNPS during 1994 resulted in a maximum total body dose of 1.03E+00 mrem. The maximum skin dose was 7.91E+00 mrem. Both of these doses occurred to a hypothetical individual. The maximum total body dose occurred at the shoreline 100 meters (0.1 miles) north-northeast of the PNPS Reactor Building. The maximum skin dose occurred at the shoreline 110 meters (0.05 miles) northeast of the PNPS Reactor Building. Both of these areas are effectively under Boston Edison control. Doses to more "realistic" individuals at offsite locations would be lower than the doses for these hypothetical site boundary individuals.

Table 1.3-1

Maximum Doses From Noble Gas Releases During 1994

Release Period	Gamma Air Dose (Location)	Beta Air Dose (Location)	Whole Body Dose (Location)	Skin Dose (Location)
January through March	5.56E-01 mrad (0.1 mi. ENE)	2.62E+00 mrad (0.1 mi. N)	3.72E-01 mrem (0.1 mi. ENE)	2.47E+00 mrem (0.1 mi. NE)
April through June	3.32E-01 mrad (0.1 mi. NNE)	1.69E+00 mrad (0.1 mi. NNE)	2.20E-01 mrem (0.1 mi. NNE)	1.53E+00 mrem (0.1 mi. NNE)
July through September	3.74E-01 mrad (0.1 mi. NNE)	2.67E+00 mrad (0.1 mi. NE)	2.47E-01 mrem (0.3 mi. NNE)	2.27E+00 mrem (0.1 mi. NE)
October through December	1.30E-01 mrad (0.1 mi. NE)	5.86E-01 mrad (0.1 mi. NE)	8.71E-02 mrem (0.1 mi. NE)	5.44E-01 mrem (0.1 mi. NE)
January through December	1.55E+00 mrad (0.1 mi. NNE)	8.62E+00 mrad (0.1 mi. NE)	1.03E+00 mrem (0.1 mi. NNE)	7.91E+00 mrem (0.1 mi. NE)

2.0 POPULATION AND AVERAGE INDIVIDUAL DOSES

PNPS Technical Specifications do not contain any limits or operational objectives related to population doses. However, NRC Regulatory Guide 1.21 (Ref. 9) recommends calculation of population and average individual doses to the total body as part of the overall assessment of radiological impact on man.

Total body doses to the entire population within 50 miles of Pilgrim Station resulting from radionuclides in effluents released offsite were calculated using the population distribution listed in Table 2.0-1. The values presented in this table are based on 1980 census data.

These cumulative population doses were also calculated using methods presented in the PNPS ODCM, NRC Regulatory Guide 1.109, NRC Regulatory Guide 1.111 and the Pilgrim Station Unit 1 Appendix I Evaluation. Population doses were calculated separately for: (1) liquid effluents; and, (2) gaseous effluents. Unlike the Technical Specification addressing doses to maximum exposed individuals resulting from the three types of releases addressed in Section 1 of this report, population doses for gaseous effluents combine the dose contributions from noble gases along with those from radioactive particulates, iodines and tritium. Also, in the case of population doses, average consumption and use factors for various pathways from Table E-4 of the PNPS ODCM are assumed, rather than the maximum use factors assumed for the maximum exposed individual.

Information related to liquid and gaseous effluent releases were obtained from the two semiannual Radioactive Effluent and Waste Disposal Reports (Ref. 5 and 6). These effluent release data were used as input to computer programs to calculate the resulting total body doses. The Yankee Atomic Electric Company "YODA"-series of computer programs was used to compile the dose contributions to the total body in each age class from major exposure pathways (Ref. 7).

In addition to population total body doses, doses to an average individual in the population were calculated. These average total body doses were estimated by dividing the total population dose (person-rem) by the total population of 4.18 million people within 50 miles of PNPS.

TABLE 2.0-1

POPULATION DISTRIBUTION BY DISTANCE AND DIRECTION

SECTOR	Distance Interval from Pilgrim Station - miles										0-50
	0-1	1-2	2-3	3-4	4-5	5-10	10-20	20-30	30-40	40-50	
N	0	0	0	0	0	0	0	0	0	3.09E4	3.09E4
NNE	0	0	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	5.30E2	3.48E3	0	0	4.01E3
E	0	0	0	0	0	0	0	3.29E3	3.41E2	0	3.63E3
ESE	0	0	1.50E1	0	0	0	0	5.88E3	1.31E4	0	1.90E4
SE	5.70E2	1.76E2	4.76E2	0	0	0	1.24E3	4.02E4	5.91E3	0	4.86E4
SSE	1.90E1	2.10E2	5.30E2	2.03E3	8.19E2	1.39E3	1.32E4	1.95E4	0	7.12E2	3.84E4
S	0	3.90E1	2.08E2	5.30E1	2.20E1	2.39E3	1.66E4	2.52E4	7.80E3	7.12E2	5.30E4
SSW	1.90E1	0	2.30E1	0	0	9.98E2	1.58E4	7.80E3	3.16E2	3.59E2	2.53E4
SW	0	3.90E1	1.23E2	6.50E1	3.49E2	4.97E2	1.28E4	1.42E5	4.64E4	4.65E4	2.49E5
WSW	0	7.70E1	2.36E2	3.00E0	2.17E2	2.52E3	1.18E4	5.04E4	1.37E5	1.85E5	3.87E5
W	5.80E1	9.50E1	4.75E2	1.25E3	4.52E3	9.56E3	1.76E4	6.05E4	1.42E5	3.78E5	6.14E5
WNW	1.17E2	0	0	0	7.11E2	1.03E4	2.83E4	1.65E5	1.13E5	1.08E5	4.25E5
NW	1.90E1	0	0	0	8.00E0	5.65E3	3.96E4	2.07E5	8.21E5	6.36E5	1.71E6
NNW	0	0	0	0	1.30E1	1.55E3	2.66E4	2.83E4	1.04E5	4.14E5	5.74E5
TOTAL	8.02E2	6.36E2	2.09E3	3.40E3	6.66E3	3.49E4	1.84E5	7.59E5	1.39E6	1.80E6	4.18E6

* Population distribution data based on 1980 Census Data

2.1 Doses From Liquid Effluent Releases

Population total body doses (person-rem) resulting from releases of radionuclides in liquid effluents are presented in Table 2.1-1. This table includes the doses for the four calendar quarters and entire year resulting from the various liquid exposure pathways. The corresponding average individual total body doses (mrem) are presented in Table 2.1-2.

Radioactivity released in liquid effluents from PNPS during 1994 resulted in a population total body dose of $1.40\text{E-}03$ person-rem. The corresponding average individual total body dose was $3.36\text{E-}07$ mrem.

Again, it should be noted that the calculated dose for the entire year is less than the sum of the individual four quarters. This difference is due to the calculational methods and equations used to calculate dose from liquid effluents, as recommended by the NRC in Regulatory Guide 1.109 (Reference 2). A more detailed description of the difference can be found on Page 6, in the discussion of maximum individual doses from liquid effluent releases.

Table 2.1-1

Population Doses From Liquid Effluent Releases During 1994

Exposure Pathway	Population Total Body Dose (person-rem)				
	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Annual
Fish	9.57E-05	1.05E-04	2.95E-04	1.09E-04	6.67E-04
Shellfish	1.29E-04	1.19E-04	2.40E-04	8.08E-05	5.96E-04
Swimming	8.09E-08	7.23E-08	1.08E-07	4.55E-08	3.07E-07
Shoreline	3.56E-05	3.25E-05	5.00E-05	2.09E-05	1.40E-04
Total	2.60E-04	2.56E-04	5.85E-04	2.10E-04	1.40E-03

Table 2.1-2

Average Individual Doses From Liquid Effluent Releases During 1994

Exposure Pathway	Average Individual Total Body Dose (mrem)				
	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Annual
Fish	2.29E-08	2.51E-08	7.04E-08	2.60E-08	1.59E-07
Shellfish	3.08E-08	2.84E-08	5.75E-08	1.93E-08	1.43E-07
Swimming	1.93E-11	1.73E-11	2.57E-11	1.09E-11	7.34E-11
Shoreline	8.50E-09	7.77E-09	1.20E-08	4.99E-09	3.35E-08
Total	6.22E-08	6.12E-08	1.39E-07	5.03E-08	3.36E-07

2.2 Doses From Gaseous Effluent Releases

Population total body doses (person-rem) resulting from releases of radionuclides in gaseous effluents are presented in Table 2.2-1. This table includes the doses for the four calendar quarters and entire year resulting from the various gaseous exposure pathways. The corresponding average individual total body doses (mrem) are presented in Table 2.2-2.

Radioactivity released in gaseous effluents from PNPS during 1994 resulted in a population total body dose of $8.02\text{E-}01$ person-rem. The corresponding average individual total body dose was $1.92\text{E-}04$ mrem.

Table 2.2-1

Population Doses From Gaseous Effluent Releases During 1994

Exposure Pathway	Population Total Body Dose (person-rem)				
	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Annual
Noble Gas	1.98E-01	1.96E-01	1.35E-01	2.15E-01	7.85E-01
Ground Deposition	1.91E-04	3.58E-04	1.60E-04	3.77E-05	7.19E-04
Inhalation	2.74E-03	3.01E-03	6.25E-03	2.25E-03	1.40E-02
Vegetables	2.59E-04	2.50E-04	5.45E-04	1.57E-04	1.16E-03
Milk	1.92E-04	2.16E-04	3.74E-04	8.55E-05	8.20E-04
Meat	9.49E-06	8.69E-06	2.06E-05	5.52E-06	4.21E-05
Total	2.01E-01	1.99E-01	1.42E-01	2.17E-01	8.02E-01

Table 2.2-2

Average Individual Doses From Gaseous Effluent Releases During 1994

Exposure Pathway	Average Individual Total Body Dose (mrem)				
	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Annual
Noble Gas	4.74E-05	4.69E-05	3.23E-05	5.15E-05	1.88E-04
Ground Deposition	4.57E-08	8.56E-08	3.83E-08	9.01E-09	1.72E-07
Inhalation	6.55E-07	7.20E-07	1.49E-06	5.38E-07	3.35E-06
Vegetables	6.19E-08	5.98E-08	1.30E-07	3.75E-08	2.77E-07
Milk	4.59E-08	5.16E-08	8.94E-08	2.04E-08	1.96E-07
Meat	2.27E-09	2.08E-09	4.93E-09	1.32E-09	1.01E-08
Total	4.82E-05	4.78E-05	3.40E-05	5.21E-05	1.92E-04

3.0 OFFSITE DIRECT RADIATION MEASUREMENTS

PNPS Technical Specifications do not contain any limits or operational objectives related specifically to offsite radiation exposure. However, NRC Regulatory Guide 1.21 (Ref. 9) recommends calculation of direct radiation exposure as part of the overall assessment of radiological impact on man.

Thermoluminescent dosimeters (TLDs) are located at 82 sites beyond the boundary of the PNPS restricted/protected area. A number of these TLDs are actually located on Boston Edison property in close proximity to the station proper. The TLDs are collected on a quarterly basis and used to calculate the direct radiation exposure in milliRoentgen (mR) over the exposure period. These TLDs are grouped into four zones of increasing distances from the station. Average exposure values for each of these zones were calculated for each calendar quarter and the total year. The average exposure values (mR) for the four zones are presented in Table 3.0-1.

In addition to responding to direct radiation exposure, TLDs will also record radiation resulting from noble gases (plume and immersion exposure), particulate materials deposited on the ground, cosmic rays from outer space, and from naturally-occurring radioactivity in the soil and air. Typically, the exposure from cosmic rays and other natural radioactivity components is about 40 - 70 mrem/yr. As calculated in Sections 1.2 and 1.3 of this report, the direct radiation component of doses from PNPS effluent emissions are below 1 mrem/yr and would not be discernible above the natural radiation exposure levels.

The major source of direct radiation exposure from PNPS results from high energy nitrogen-16 gamma rays emitted from the turbine building. Although this material is enclosed in the process lines and not released into the environment, the direct radiation exposure and sky shine from this contained source accounts for the majority of the direct radiation dose, especially in close proximity to the station. Other sources of direct radiation exposure include radiation emitted from contained radioactive sources or radwaste at the facility. Despite these sources of direct radiation exposure at PNPS, increases in exposure from direct radiation are typically not observable above background radiation levels at locations beyond Boston Edison controlled property.

The average exposure values presented in Table 3.0-1 appear to indicate an elevation in direct radiation exposure in TLD Zone 1, those TLDs within 2 miles of PNPS. Most of this apparent elevation is due to increases in exposure levels measured at the TLD locations on Boston Edison property in close proximity to the station proper. For example, the annual exposure at TLD location OA, located at the Overlook Area near the PNPS I&S Building, was 377 mR for the entire year. This location is immediately adjacent to the station proper and overlooks the turbine building, therefore receiving the highest direct radiation and sky shine exposure.

Although the annual exposure at TLD location OA was 318 mR/yr over the average Zone 4 exposure rate, this area is not continuously occupied by members of the general public. When adjusted for such occupancy, a hypothetical member of the public who was at this location for 40 hours per year would only receive an incremental dose of 1.5 mrem over natural background radiation levels. At the nearest residence 800 meters (0.5 miles) southeast of the PNPS Reactor Building, the annual exposure was 63.8 ± 5.3 mR, which compares quite well to the Zone 4 annual average of 59.2 ± 7.5 mR.

3.0 OFFSITE DIRECT RADIATION MEASUREMENTS (continued)

Although some of the TLDs in close proximity to PNPS indicate increases in exposure levels from direct radiation, such increases are localized to areas under Boston Edison control. For members of the general public accessing Boston Edison controlled areas (e.g., Shorefront Recreation Area, I&S Building, Parking Lots, etc.), such increases in dose from direct radiation exposure are estimated as being less than 2 mrem/yr.

Table 3.0-1

AVERAGE TLD EXPOSURES BY DISTANCE ZONE DURING 1994

Period	Average Exposure \pm Standard Deviation (mR/period)							
	Zone 1*		Zone 2		Zone 3		Zone 4	
	0 km - 3 km		3 km - 8 km		8 km - 15 km		> 15 km	
	Avg	StD	Avg	StD	Avg	StD	Avg	StD
Qtr-1	20.7	\pm 17.0	13.7	\pm 2.7	13.4	\pm 1.7	13.6	\pm 1.1
Qtr-2	21.3	\pm 17.7	13.8	\pm 2.6	13.3	\pm 1.8	14.2	\pm 1.6
Qtr-3	21.4	\pm 12.0	15.7	\pm 2.8	15.3	\pm 1.9	16.2	\pm 1.9
Qtr-4	19.7	\pm 9.0	14.9	\pm 2.5	14.5	\pm 1.8	15.2	\pm 1.9
Year	83.1	\pm 57.0	58.3	\pm 10.9	56.5	\pm 7.6	59.2	\pm 7.5

* Zone 1 extends from the restricted/protected area boundary outward to 3 kilometers (2 miles).

4.0 PERCENT OF TECHNICAL SPECIFICATIONS LIMITS/OBJECTIVES

The PNPS Technical Specifications contain dose and concentration limits for radioactive effluents. In addition, operational objectives are also specified which, if met, ensure that radioactive releases are maintained as low as is reasonably achievable. The percentages of the PNPS Technical Specifications were determined from the doses calculated in Section 1, the liquid concentrations listed in the 1994 semiannual Effluent Release and Waste Disposal Reports, and the Technical Specifications limits/objectives listed in Tables 4.1-1 and 4.2-1.

The percent of applicable limits are provided as a supplement to the information provided in the two semiannual Radioactive Effluent and Waste Disposal Reports. The format for the percent applicable limits is modified from that prescribed in Regulatory Guide 1.21 (Ref. 9) to accommodate the Radioactive Effluents Technical Specifications (RETS) which became effective March 1, 1986. The percentages have been grouped according to whether the releases were via liquid or gaseous effluent pathways.

4.1 Liquid Effluent Releases

Liquid effluents concentration limits and dose objectives from PNPS Technical Specifications are shown in Table 4.1-1. The quarterly average concentrations from the 1994 semiannual Radioactive Effluent and Waste Disposal reports were used to calculate the percent concentration limits. The maximum quarterly and annual whole body and organ doses from Tables 1.1-1 through 1.1-5 were used to calculate the corresponding percentages shown in Table 4.1-1. The resulting concentrations and doses from Pilgrim Station's liquid releases during 1994 were a very small percentage of the corresponding limits and objectives.

Table 4.1-1

Percent of Technical Specifications Limits/Objectives
for Liquid Effluent Releases During 1994

- A. Fission and Activation Product Effluent Concentration Limit
PNPS Technical Specification 3.8.A.1
Limit: 10CFR20 Appendix B, Table II, Column 2 Value

Period	Value ($\mu\text{Ci/ml}$)	Percentage of Limit
1st Quarter	4.97E-10	1.65E-02%
2nd Quarter	3.70E-10	1.67E-02%
3rd Quarter	9.24E-10	4.82E-02%
4th Quarter	5.17E-10	2.87E-02%

- B. Tritium Average Concentration Limit
PNPS Technical Specification 3.8.A.1
Limit: 1.0E-03 $\mu\text{Ci/ml}$

Period	Value ($\mu\text{Ci/ml}$)	Percentage of Limit
1st Quarter	1.42E-07	1.42E-02%
2nd Quarter	1.92E-07	1.92E-02%
3rd Quarter	7.67E-08	7.67E-03%
4th Quarter	8.07E-07	8.07E-02%

- C. Dissolved and Entrained Gases Average Concentration Limit
PNPS Technical Specification 3.8.A.1
Limit: 2.0E-04 $\mu\text{Ci/ml}$

Period	Value ($\mu\text{Ci/ml}$)	Percentage of Limit
1st Quarter	NDA	--
2nd Quarter	NDA	--
3rd Quarter	NDA	--
4th Quarter	NDA	--

- D. Quarterly Total Body Dose Objective
PNPS Technical Specification 7.2.A.1
Objective: 1.5 mrem Total Body Dose

Period	Value (mrem)	Percentage of Limit
1st Quarter	3.30E-05	2.20E-03%
2nd Quarter	3.15E-05	2.10E-03%
3rd Quarter	6.16E-05	4.10E-03%
4th Quarter	2.33E-05	1.56E-03%

Table 4.1-1 (continued)

Percent of Technical Specifications Limits/Objectives
for Liquid Effluent Releases During 1994

- E. Annual Total Body Dose Objective
PNPS Technical Specification 7.2.A.2
Objective: 3 mrem Total Body Dose

Period	Value (mrem)	Percentage of Limit
Annual	1.56E-04	5.20E-03%

- F. Quarterly Organ Dose Objective
PNPS Technical Specification 7.2.A.1
Objective: 5 mrem Organ Dose

Period	Value (mrem)	Percentage of Limit
1st Quarter	8.35E-05	1.67E-03%
2nd Quarter	7.02E-05	1.40E-03%
3rd Quarter	1.31E-04	2.62E-03%
4th Quarter	4.51E-05	9.01E-04%

- G. Annual Organ Dose Objective
PNPS Technical Specification 7.2.A.2
Objective: 10 mrem Organ Dose

Period	Value (mrem)	Percentage of Limit
Annual	3.11E-04	3.11E-03%

4.2 Gaseous Effluent Releases

Organ dose limits and objectives for the maximum individual from radioactive iodines, particulates, and tritium from PNPS Technical Specifications are shown in Table 4.2-1. The maximum quarterly and annual organ doses from Tables 1.2-1 through 1.2-5 were used to calculate the percentages shown in Table 4.2-1. The resulting organ doses from Pilgrim Station's gaseous releases during 1994 were a small percentage of the corresponding limits and objectives.

Dose limits and objectives for exposures arising from noble gases are also presented in Table 4.2-1. The maximum quarterly air doses and annual whole body and skin doses listed in Table 1.3-1 were used to calculate the percentage values shown in Table 4.2-1. All doses resulting from noble gas exposure were a small percentage of the applicable limits and objectives.

Table 4.2-1

Percent of Technical Specifications Limits/Objectives
for Gaseous Effluent Releases During 1994

- A. Annual Dose Rate Limit - Noble Gases
PNPS Technical Specification 3.8.D.1.a
Limit: 500 mrem/yr Total Body Dose

Period	Value (mrem/yr)	Percentage of Limit
Annual	1.03E+00	2.06E-01%

- B. Annual Dose Rate Limit - Noble Gases
PNPS Technical Specification 3.8.D.1.a
Limit: 3000 mrem/yr Skin Dose

Period	Value (mrem/yr)	Percentage of Limit
Annual	7.91E+00	2.64E-01%

- C. Annual Dose Rate Limit - Particulates, Iodines, & Tritium
PNPS Technical Specification 3.8.D.1.b
Limit: 1500 mrem/yr Organ Dose

Period	Value (mrem/yr)	Percentage of Limit
Annual	1.78E+00	1.19E-01%

- D. Quarterly Dose Objective - Noble Gas Gamma Air Dose
PNPS Technical Specification 7.3.A.1
Objective: 5 mrad Gamma Air Dose

Period	Value (mrad)	Percentage of Limit
1st Quarter	5.56E-01	1.11E+01%
2nd Quarter	3.32E-01	6.64E+00%
3rd Quarter	3.74E-01	7.48E+00%
4th Quarter	1.30E-01	2.60E+00%

- E. Annual Dose Objective - Noble Gas Gamma Air Dose
PNPS Technical Specification 7.3.A.2
Objective: 10 mrad Gamma Air Dose

Period	Value (mrad)	Percentage of Limit
Annual	1.55E+00	1.55E+01%

Table 4.2-1 (continued)

Percent of Technical Specifications Limits/Objectives
for Gaseous Effluent Releases During 1994

F. Quarterly Dose Objective - Noble Gas Beta Air Dose
PNPS Technical Specification 7.3.A.1
Objective: 10 mrad Beta Air Dose

Period	Value (mrad)	Percentage of Limit
1st Quarter	2.62E+00	2.62E+01%
2nd Quarter	1.69E+00	1.69E+01%
3rd Quarter	2.67E+00	2.67E+01%
4th Quarter	5.86E-01	5.86E+00%

G. Annual Dose Objective - Noble Gas Beta Air Dose
PNPS Technical Specification 7.3.A.2
Objective: 20 mrad Beta Air Dose

Period	Value (mrad)	Percentage of Limit
Annual	8.62E+00	4.31E+01%

H. Quarterly Dose Objective - Particulates, Iodines, & Tritium
PNPS Technical Specification 7.4.A.1
Objective: 7.5 mrem Organ Dose

Period	Value (mrem)	Percentage of Limit
1st Quarter	2.93E-01	3.91E+00%
2nd Quarter	6.29E-01	8.39E+00%
3rd Quarter	8.55E-01	1.14E+01%
4th Quarter	9.64E-02	1.29E+00%

I. Annual Dose Objective - Particulates, Iodines, & Tritium
PNPS Technical Specification 7.4.A.2
Objective: 15 mrem Organ Dose

Period	Value (mrem)	Percentage of Limit
Annual	1.78E+00	1.19E+01%

5.0 REFERENCES

1. Boston Edison Company, "Pilgrim Nuclear Power Station Off-site Dose Calculation Manual," Revision 6, August 1994.
2. U.S. Nuclear Regulatory Commission, Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10CFR50, Appendix I," Revision 1, October 1977.
3. U.S. Nuclear Regulatory Commission, Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors," July 1977.
4. Boston Edison Company, "Pilgrim Station Unit 1 Appendix I Evaluation," April 1977.
5. Boston Edison Company, Pilgrim Nuclear Power Station, "Radioactive Effluent and Waste Disposal Report including Meteorological Data for January 1 through June 30, 1994," August 1994.
6. Boston Edison Company, Pilgrim Nuclear Power Station, "Radioactive Effluent and Waste Disposal Report including Meteorological Data for July 1 through December 31, 1994," February 1995.
7. YAEC Calculation No. BEC-074, entitled "Dose Assessment for January-December 1994 Effluent Report," March 17, 1995.
8. J.N. Hamawi, "AEOLUS," Yankee Atomic Electric Company, YAEC - 1120, January 1977.
9. U.S. Nuclear Regulatory Commission, Regulatory Guide 1.21, "Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants," June 1974.

APPENDIX A

Effluent Release Information

<u>Table</u>		<u>Page</u>
--	Supplemental Information: January-June 1994	37
1A	Gaseous Effluents Summation of All Releases: January-June 1994	38
1B	Gaseous Effluents - Elevated Release: January-June 1994	39
1C	Gaseous Effluents - Ground Level Release: January-June 1994	40
2A	Liquid Effluents Summation of All Releases: January-June 1994	41
2B	Liquid Effluents: January-June 1994:	42
--	Supplemental Information: July-December 1994	43
1A	Gaseous Effluents Summation of All Releases: July-December 1994	44
1B	Gaseous Effluents - Elevated Release: July-December 1994	45
1C	Gaseous Effluents - Ground Level Release: July-December 1994	46
2A	Liquid Effluents Summation of All Releases: July-December 1994	47
2B	Liquid Effluents: July-December 1994	48

PILGRIM NUCLEAR POWER STATION
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

SUPPLEMENTAL INFORMATION 1994
January - June 1994

Facility Pilgrim Nuclear Power Station Licensee DPR-35

1. Regulatory Limits

- a. Fission and activation gases: 500 mrem/yr total body and 3000 mrem/yr for skin at site boundary.
- b,c. Iodines, particulates with half-lives > 8 days, tritium: 1500 mrem/yr to any organ at site boundary.
- d. Liquid effluents: 0.06 mrem/month for total body and 0.20 mrem/month for any organ (without radwaste treatment).

2. Maximum Permissible Concentration

- a. Fission and activation gases: 10 CFR 20 Appendix B Table II
- b. Iodines: 10 CFR 20 Appendix B Table II
- c. Particulates, half-lives > 8 days: 10 CFR 20 Appendix B Table II
- d. Liquid effluents: 2E-4 $\mu\text{Ci/ml}$ for entrained noble gases; 10 CFR 20 Appendix B Table II values for all other radionuclides.

3. Average Energy: Not applicable

4. Measurements and Approximations of Total Radioactivity

- a. Fission and activation gases: High-purity Ge gamma spectroscopy for
- b. Iodines: all gamma emitters; radiochemistry
- c. Particulates: analysis for H-3, Fe-55 (liquids only),
- d. Liquid effluents: Sr-89, and Sr-90.

5. Batch Releases

a. Liquid:

- 1. Number of batch releases:
- 2. Total time period for batch releases (minutes):
- 3. Maximum time period for a batch release (minutes):
- 4. Average time period for batch releases (minutes):
- 5. Minimum time period for a batch release (minutes):
- 6. Average stream flow during periods of release of effluents into a flowing stream (liters/min):

Quarter	
1st	2nd
20	22
1.40E+3	1.67E+3
2.40E+2	3.15E+2
6.98E+1	7.57E+1
2.50E+1	2.50E+1
1.14E+6	1.14E+6

- b. Gaseous: Not applicable

6. Abnormal Releases

- a. Liquid: None
- b. Gaseous: One

TABLE 1A
 PILGRIM NUCLEAR POWER STATION
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1994
 GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES
 January - June 1994

Unit	Quarter 1st	Quarter 2nd	Est.Total Error, %
------	----------------	----------------	-----------------------

A. Fission and Activation Gases

1. Total release	Ci	5.47E+2	5.30E+2	22%
2. Average release rate for period	uCi/sec	6.94E+1	6.72E+1	
3. Percent of Technical Specification limit	%	*	*	

B. Iodines

1. Total iodine-131 release	Ci	3.77E-3	5.11E-3	20%
2. Average release rate for period	uCi/sec	4.78E-4	6.48E-4	
3. Percent of Technical Specification limit	%	*	*	

C. Particulates

1. Particulates with half-lives > 8 days	Ci	2.61E-3	2.45E-3	21%
2. Average release rate for period	uCi/sec	3.31E-4	3.11E-4	
3. Percent of Technical Specification limit	%	*	*	
4. Gross alpha radioactivity	Ci	NDA	NDA	

D. Tritium

1. Total release rate for period	Ci	8.45E+0	7.78E+0	20%
2. Average release rate for period	uCi/sec	1.07E+0	9.87E-1	
3. Percent of Technical Specification limit	%	*	*	

Notes for Table 1A:

- * Percent of Technical Specification Limit Values in Sections A.3, B.3, C.3, and D.3 are based on dose assessments not performed as part of this report. These will be provided in the annual supplemental dose assessment report to be issued prior to April 1, 1995.

1. NDA is no detectable activity.
2. LLD for gross alpha listed as NDA is $1\text{E-}11 \mu\text{Ci/ml}$.

TABLE 1B
PILGRIM NUCLEAR POWER STATION
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1994
GASEOUS EFFLUENTS-ELEVATED RELEASE
January - June 1994

Nuclides Released	CONTINUOUS MODE		BATCH MODE	
	Unit	Quarter	Quarter	Quarter
		1st	2nd	N/A

1. Fission and Activation Gases

N-13	Ci	NDA	3.59E+0		
Kr-85m	Ci	2.75E+1	5.15E+1		
Kr-87	Ci	2.63E+1	2.72E+1		
Kr-88	Ci	4.09E+1	7.25E+1		
Xe-133	Ci	2.76E+1	6.80E+1		
Xe-135	Ci	5.27E+1	4.46E+1		
Xe-135m	Ci	2.08E+1	2.33E+1		
Xe-138	Ci	7.26E+1	1.08E+2		
Total for period	Ci	2.68E+2	3.99E+2		

2. Iodines

I-131	Ci	1.89E-3	2.82E-3		
I-133	Ci	9.12E-3	1.49E-2		
Total for period	Ci	1.10E-2	1.77E-2		

3. Particulates

Sr-89	Ci	3.22E-4	6.10E-4		
Sr-90	Ci	NDA	2.12E-6		
Cs-134	Ci	NDA	NDA		
Cs-137	Ci	1.95E-6	1.16E-5		
Ba/La-140	Ci	4.34E-4	8.17E-4		
Total for period	Ci	7.58E-4	1.44E-3		

4. Tritium

H-3	Ci	2.04E-1	2.52E-1		
-----	----	---------	---------	--	--

Notes for Table 1B:

1. NDA is no detectable activity.
2. LLDs for nuclides listed as NDA are as follows:

Fission gases: 1E-4 $\mu\text{Ci/ml}$
Iodines: 1E-12 $\mu\text{Ci/ml}$
Particulates: 1E-11 $\mu\text{Ci/ml}$

TABLE 1C
PILGRIM NUCLEAR POWER STATION
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1994
GASEOUS EFFLUENTS-GROUND LEVEL RELEASE
January - June 1994

Nuclides Released	CONTINUOUS MODE			BATCH MODE	
	Unit	Quarter 1st	Quarter 2nd	Quarter N/A	Quarter N/A

1. Fission and Activation Gases

Kr-85m	Ci	1.25E+0	NDA		
Kr-87	Ci	8.72E+0	NDA		
Kr-88	Ci	4.98E+0	NDA		
Xe-133	Ci	NDA	NDA		
Xe-135	Ci	1.62E+2	1.31E+2		
Xe-135m	Ci	1.99E+1	NDA		
Xe-138	Ci	8.09E+1	NDA		
Total for period	Ci	2.78E+2	1.31E+2		

2. Iodines

I-131	Ci	1.88E-3	2.29E-3		
I-133	Ci	1.62E-2	1.96E-2		
Total for period	Ci	1.81E-2	2.19E-2		

3. Particulates

Co-60	Ci	NDA	5.39E-6		
Sr-89	Ci	1.10E-3	4.82E-4		
Sr-90	Ci	NDA	NDA		
Cs-134	Ci	NDA	NDA		
Cs-137	Ci	1.06E-5	4.69E-6		
Ba/La-140	Ci	7.42E-4	5.14E-4		
Total for period	Ci	1.85E-3	1.01E-3		

4. Tritium

H-3	Ci	8.25E+0	7.53E+0		
-----	----	---------	---------	--	--

Notes for Table 1C:

1. NDA is no detectable activity.
2. LLDs for nuclides listed as NDA are as follows:

Fission gases: 1E-4 $\mu\text{Ci/ml}$
Iodines: 1E-12 $\mu\text{Ci/ml}$
Particulates: 1E-11 $\mu\text{Ci/ml}$

TABLE 2A
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1994
LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES
January - June 1994

Unit	Quarter 1st	Quarter 2nd	Est.Total Error, %
------	----------------	----------------	-----------------------

A. Fission and Activation Products

1. Total release (not including tritium, noble gases, or alpha)	Ci	3.40E-4	2.52E-4	12%
2. Average diluted concentration during period	uCi/ml	4.97E-10	3.70E-10	
3. Percent of Effluent Concentration Limit*	%	1.65E-2	1.67E-2	

B. Tritium

1. Total release	Ci	9.74E-2	1.31E-1	9.4%
2. Average diluted concentration during period	uCi/ml	1.42E-7	1.93E-7	
3. Percent of Effluent Concentration Limit*	%	1.42E-2	1.93E-2	

C. Dissolved and Entrained Gases

1. Total release	Ci	NDA	NDA	5.7%
2. Average release rate for period during period	uCi/ml	NDA	NDA	
3. Percent of Effluent Concentration Limit*	%	0.00E+0	0.00E+0	

D. Gross Alpha Radioactivity

1. Total release	Ci	NDA	NDA	5.7%
------------------	----	-----	-----	------

E. Volume of Waste Released (prior to dilution)

liters	1.81E+5	2.38E+5	5.7%
--------	---------	---------	------

F. Volume of Dilution Water Used During Period

liters	6.84E+8	6.81E+8	10%
--------	---------	---------	-----

Notes for Table 2A:

* Additional percent of Technical Specification Limit Values based on resulting dose will be provided in the annual supplemental dose assessment report to be issued prior to April 1, 1995.

1. NDA is no detectable activity.
2. LLD for gross alpha listed as NDA is 1E-7 μ Ci/ml.
3. LLD for dissolved and entrained gases listed as NDA is 1E-5 μ Ci/ml.

TABLE 2B
PILGRIM NUCLEAR POWER STATION
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1994
LIQUID EFFLUENTS
January - June 1994

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		Quarter	Quarter	Quarter	Quarter
		Not Applicable		1st	2nd

1. Fission and activation products

Cr-51	Ci	N/A	N/A	8.77E-7	NDA
Mn-54	Ci	N/A	N/A	2.92E-5	1.49E-5
Fe-55	Ci	N/A	N/A	7.16E-5	4.47E-5
Fe-59	Ci	N/A	N/A	NDA	NDA
Co-58	Ci	N/A	N/A	4.68E-6	NDA
Co-60	Ci	N/A	N/A	1.72E-4	1.26E-4
Zn-65	Ci	N/A	N/A	NDA	NDA
Sr-89	Ci	N/A	N/A	1.25E-5	1.78E-6
Sr-90	Ci	N/A	N/A	3.35E-6	5.49E-6
Zr/Nb-95	Ci	N/A	N/A	NDA	NDA
Mo-99/Tc-99m	Ci	N/A	N/A	NDA	NDA
Ag-110m	Ci	N/A	N/A	NDA	NDA
Sb-122	Ci	N/A	N/A	NDA	NDA
I-131	Ci	N/A	N/A	NDA	NDA
I-133	Ci	N/A	N/A	NDA	NDA
Cs-137	Ci	N/A	N/A	4.57E-5	5.95E-5
Ba/La-140	Ci	N/A	N/A	NDA	NDA
Ce-141	Ci	N/A	N/A	NDA	NDA
Total for period	Ci	N/A	N/A	3.40E-4	2.52E-4

2. Dissolved and entrained gases

Xe-133	Ci	N/A	N/A	NDA	NDA
Xe-135	Ci	N/A	N/A	NDA	NDA
Total for period	Ci	N/A	N/A	NDA	NDA

Notes for Table 2B:

- 1) NDA is no detectable activity.
- 2) LLDs for nuclides listed as NDA are as follows:

Sr-89	5E-8 $\mu\text{Ci/ml}$
I-131	1E-6 $\mu\text{Ci/ml}$
Xe-133, Xe-135	1E-5 $\mu\text{Ci/ml}$
All others	5E-7 $\mu\text{Ci/ml}$

PILGRIM NUCLEAR POWER STATION
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

SUPPLEMENTAL INFORMATION 1994
July - December 1994

Facility Pilgrim Nuclear Power Station Licensee DPR-35

1. Regulatory Limits

- a. Fission and activation gases: 500 mrem/yr total body and 3000 mrem/yr for skin at site boundary.
- b,c. Iodines, particulates with half-lives > 8 days, tritium: 1500 mrem/yr to any organ at site boundary.
- d. Liquid effluents: 0.06 mrem/month for total body and 0.20 mrem/month for any organ (without radwaste treatment).

2. Effluent Concentration Limits

- a. Fission and activation gases: 10 CFR 20 Appendix B Table II
- b. Iodines: 10 CFR 20 Appendix B Table II
- c. Particulates, half-lives > 8 days: 10 CFR 20 Appendix B Table II
- d. Liquid effluents: 2E-4 $\mu\text{Ci/ml}$ for entrained noble gases; 10 CFR 20 Appendix B Table II values for all other radionuclides.

3. Average Energy: Not applicable

4. Measurements and Approximations of Total Radioactivity

- a. Fission and activation gases: High-purity Ge gamma spectroscopy for all gamma emitters; radiochemistry
- b. Iodines: analysis for H-3, Fe-55 (liquids only), Sr-89, and Sr-90.
- c. Particulates:
- d. Liquid effluents:

5. Batch Releases

- a. Liquid:
 - 1. Number of batch releases:
 - 2. Total time period for batch releases (minutes):
 - 3. Maximum time period for a batch release (minutes):
 - 4. Average time period for batch releases (minutes):
 - 5. Minimum time period for a batch release (minutes):
 - 6. Average stream flow during periods of release of effluents into a flowing stream (liters/min):

Quarter	
3rd	4th
20	22
2.19E+3	9.52E+2
2.40E+2	1.62E+2
1.09E+2	4.33E+1
2.50E+1	2.00E+1
8.81E+5	7.30E+5

- b. Gaseous: Not applicable

6. Abnormal Releases

- a. Liquid: None
- b. Gaseous: None

TABLE 1A
 PILGRIM NUCLEAR POWER STATION
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1994
 GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES
 July - December 1994

Unit	Quarter 3rd	Quarter 4th	Est.Total Error, %
------	----------------	----------------	-----------------------

A. Fission and Activation Gases

1. Total release	Ci	3.37E+02	4.41E+02	22%
2. Average release rate for period	uCi/sec	4.28E+01	5.60E+01	
3. Percent of Technical Specification limit	%	*	*	

B. Iodines

1. Total iodine-131 release	Ci	3.71E-03	8.02E-04	20%
2. Average release rate for period	uCi/sec	4.70E-04	1.02E-04	
3. Percent of Technical Specification limit	%	*	*	

C. Particulates

1. Particulates with half-lives > 8 days	Ci	9.99E-04	6.27E-04	21%
2. Average release rate for period	uCi/sec	1.27E-04	7.95E-05	
3. Percent of Technical Specification limit	%	*	*	
4. Gross alpha radioactivity	Ci	NDA	NDA	

D. Tritium

1. Total release rate for period	Ci	1.43E+01	5.51E+00	20%
2. Average release rate for period	uCi/sec	1.81E-00	6.99E-01	
3. Percent of Technical Specification limit	%	*	*	

Notes for Table 1A:

- * Percent of Technical Specification Limit Values in Sections A.3, B.3, C.3, and D.3 are based on dose assessments not performed as part of this report. These will be provided in the annual supplemental dose assessment report to be issued prior to April 1, 1995.

1. NDA is no detectable activity.
2. LLD for gross alpha listed as NDA is $1\text{E-}11 \mu\text{Ci/ml}$.

TABLE 1B
PILGRIM NUCLEAR POWER STATION
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1994
GASEOUS EFFLUENTS-ELEVATED RELEASE
July - December 1994

Nuclides Released	CONTINUOUS MODE		BATCH MODE	
	Unit	Quarter 3rd	Quarter 4th	Quarter N/A

1. Fission and Activation Gases

Kr-85m	Ci	4.39E+01	7.50E+01	
Kr-87	Ci	6.15E+00	8.01E+01	
Kr-88	Ci	5.39E+01	1.81E+02	
Xe-133	Ci	6.40E+01	2.70E+01	
Xe-135	Ci	8.59E+00	3.01E+01	
Xe-135m	Ci	6.83E+00	NDA	
Xe-138	Ci	2.25E+01	6.90E+00	
Total for period	Ci	2.06E+02	4.00E+02	

2. Iodines

I-131	Ci	1.74E-03	6.15E-04	
I-133	Ci	9.50E-03	5.56E-03	
Total for period	Ci	1.12E-02	6.18E-03	

3. Particulates

Mn-54	Ci	NDA	NDA	
Co-60	Ci	NDA	NDA	
Sr-89	Ci	2.52E-05	5.65E-05	
Sr-90	Ci	NDA	NDA	
Cs-134	Ci	NDA	NDA	
Cs-137	Ci	8.47E-06	NDA	
Ba/La-140	Ci	1.87E-04	1.03E-04	
Total for period	Ci	2.21E-04	1.60E-04	

4. Tritium

H-3	Ci	3.69E-01	2.89E-01	
-----	----	----------	----------	--

Notes for Table 1B:

1. NDA is no detectable activity.
2. LLDs for nuclides listed as NDA are as follows:

Fission gases: 1E-4 μ Ci/ml
Iodines: 1E-12 μ Ci/ml
Particulates: 1E-11 μ Ci/ml

TABLE 1C
PILGRIM NUCLEAR POWER STATION
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1994
GASEOUS EFFLUENTS-GROUND LEVEL RELEASE
July - December 1994

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		Quarter 3rd	Quarter 4th	Quarter N/A	Quarter N/A

1. Fission and Activation Gases

Kr-85m	Ci	NDA	NDA		
Kr-87	Ci	NDA	NDA		
Kr-88	Ci	NDA	NDA		
Xe-133	Ci	NDA	NDA		
Xe-135	Ci	1.31E+02	4.11E+01		
Xe-135m	Ci	NDA	NDA		
Xe-138	Ci	NDA	NDA		
Total for period	Ci	1.31E+02	4.11E+01		

2. Iodines

I-131	Ci	1.97E-03	1.87E-04		
I-133	Ci	1.49E-02	2.05E-03		
Total for period	Ci	1.69E-02	2.24E-03		

3. Particulates

Sr-89	Ci	1.91E-04	3.40E-04		
Sr-90	Ci	NDA	NDA		
Cs-134	Ci	NDA	NDA		
Cs-137	Ci	NDA	2.04E-06		
Ba/La-140	Ci	5.87E-04	1.25E-04		
Total for period	Ci	7.78E-04	4.67E-04		

4. Tritium

H-3	Ci	1.39E+01	5.22E+00		
-----	----	----------	----------	--	--

Notes for Table 1C:

1. NDA is no detectable activity.
2. LLDs for nuclides listed as NDA are as follows:

Fission gases: 1E-4 $\mu\text{Ci/ml}$
Iodines: 1E-12 $\mu\text{Ci/ml}$
Particulates: 1E-11 $\mu\text{Ci/ml}$

TABLE 2A
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1994
LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES
July - December 1994

Unit	Quarter 3rd	Quarter 4th	Est.Total Error, %
------	----------------	----------------	-----------------------

A. Fission and Activation Products

1. Total release (not including tritium, noble gases, or alpha)	Ci	1.78E-03	3.59E-04	12%
2. Average diluted concentration during period	uCi/ml	9.24E-10	5.17E-10	
3. Percent of Effluent Concentration Limit*	%	4.82E-02	2.87E-02	

B. Tritium

1. Total release	Ci	1.48E-01	5.61E-01	9.4%
2. Average diluted concentration during period	uCi/ml	7.67E-08	8.07E-07	
3. Percent of Effluent Concentration Limit*	%	7.67E-03	8.07E-02	

C. Dissolved and Entrained Gases

1. Total release	Ci	NDA	NDA	16%
2. Average release rate for period during period	uCi/ml	NDA	NDA	
3. Percent of Effluent Concentration Limit*	%	0.00E+0	0.00E+0	

D. Gross Alpha Radioactivity

1. Total release	Ci	NDA	NDA	34%
------------------	----	-----	-----	-----

E. Volume of Waste Released (prior to dilution)

liters	3.33E+05	1.98E+05	5.7%
--------	----------	----------	------

F. Volume of Dilution Water Used During Period

liters	1.93E+09	6.95E+08	10%
--------	----------	----------	-----

Notes for Table 2A:

* Additional percent of Technical Specification Limit Values based on resulting dose will be provided in the annual supplemental dose assessment report to be issued prior to April 1, 1995.

1. NDA is no detectable activity.
2. LLD for gross alpha listed as NDA is $1\text{E-}7 \mu\text{Ci/ml}$.
3. LLD for dissolved and entrained gases listed as NDA is $1\text{E-}5 \mu\text{Ci/ml}$.

TABLE 2B
PILGRIM NUCLEAR POWER STATION
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1994
LIQUID EFFLUENTS
July - December 1994

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		Quarter	Quarter	Quarter	Quarter
		Not Applicable		3rd	4th

1. Fission and activation products

Cr-51	Ci	N/A	N/A	NDA	NDA
Mn-54	Ci	N/A	N/A	7.43E-06	9.65E-06
Fe-55	Ci	N/A	N/A	4.79E-05	6.38E-05
Fe-59	Ci	N/A	N/A	NDA	NDA
Co-58	Ci	N/A	N/A	NDA	NDA
Co-60	Ci	N/A	N/A	3.37E-04	1.27E-04
Zn-65	Ci	N/A	N/A	NDA	NDA
Sr-89	Ci	N/A	N/A	7.49E-04	6.78E-06
Sr-90	Ci	N/A	N/A	8.12E-05	3.84E-06
Zr/Nb-95	Ci	N/A	N/A	NDA	NDA
Mo-99/Tc-99m	Ci	N/A	N/A	NDA	NDA
Ru-103	Ci	N/A	N/A	NDA	NDA
Ag-110m	Ci	N/A	N/A	NDA	NDA
I-131	Ci	N/A	N/A	NDA	NDA
Cs-134	Ci	N/A	N/A	1.22E-06	NDA
Cs-137	Ci	N/A	N/A	5.59E-04	1.48E-04
Ba/La-140	Ci	N/A	N/A	1.40E-06	NDA
Ce-141	Ci	N/A	N/A	NDA	NDA
Ce/Pr-144	Ci	N/A	N/A	NDA	NDA
Total for period	Ci	N/A	N/A	1.78E-03	3.59E-04

2. Dissolved and entrained gases

Xe-133	Ci	N/A	N/A	NDA	NDA
Xe-135	Ci	N/A	N/A	NDA	NDA
Total for period	Ci	N/A	N/A	NDA	NDA

Notes for Table 2B:

- 1) NDA is no detectable activity.
- 2) LLDs for nuclides listed as NDA are as follows:

Sr-89	5E-8 μ Ci/ml
I-131	1E-6 μ Ci/ml
Xe-133, Xe-135	1E-5 μ Ci/ml
All others	5E-7 μ Ci/ml

APPENDIX B

Atmospheric Dispersion and Deposition Factors

<u>Table</u>		<u>Page</u>
B-1	Undepleted X/Q Factors for Reactor Building Vent	50
B-2	Depleted X/Q Factors for Reactor Building Vent	55
B-3	Gamma X/Q Factors for Reactor Building Vent	60
B-4	Deposition D/Q Factors for Reactor Building Vent	65
B-5	Undepleted X/Q Factors for Main Stack	70
B-6	Depleted X/Q Factors for Main Stack	75
B-7	Gamma X/Q Factors for Main Stack	80
B-8	Deposition D/Q Factors for Main Stack	85

Table B-1

Undepleted X/Q Factors for Reactor Building Vent

RECo 1st Quarter 1994 General Ground Level X/Q's

SECTOR AVERAGE MODEL

GROUND RELEASE: GROUND-LEVEL AVERAGE CHI/Q BEFORE DEPLETION - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	104	1.712E-05	5.049E-06	1.738E-06	9.399E-07	6.061E-07	3.312E-07	2.171E-07	1.571E-07
NNE	177	2.284E-05	6.741E-06	2.329E-06	1.277E-06	8.370E-07	4.508E-07	2.924E-07	2.102E-07
NE	186	2.962E-05	9.779E-06	2.928E-06	1.592E-06	1.035E-06	5.678E-07	3.720E-07	2.691E-07
ENE	250	3.589E-05	1.074E-05	3.754E-06	2.058E-06	1.337E-06	7.200E-07	4.656E-07	3.337E-07
E	376	3.630E-05	1.112E-05	3.989E-06	2.159E-06	1.388E-06	7.338E-07	4.699E-07	3.341E-07
ESE	235	2.530E-05	7.615E-06	2.665E-06	1.451E-06	9.407E-07	5.032E-07	3.244E-07	2.320E-07
SE	145	1.551E-05	4.688E-06	1.658E-06	8.971E-07	5.792E-07	3.082E-07	1.962E-07	1.415E-07
SSE	89	9.014E-06	2.704E-06	9.300E-07	5.006E-07	3.240E-07	1.733E-07	1.120E-07	8.032E-08
S	91	1.002E-05	2.974E-06	9.029E-07	4.797E-07	3.096E-07	1.656E-07	1.073E-07	7.718E-08
SSW	105	1.166E-05	3.520E-06	1.045E-06	5.591E-07	3.616E-07	1.969E-07	1.286E-07	9.280E-08
SW	82	6.549E-06	2.036E-06	6.348E-07	3.410E-07	2.196E-07	1.165E-07	7.470E-08	5.315E-08
WSW	80	6.991E-06	2.157E-06	6.385E-07	3.425E-07	2.214E-07	1.184E-07	7.598E-08	5.414E-08
W	19	2.766E-06	8.398E-07	2.644E-07	1.584E-07	1.027E-07	5.501E-08	3.229E-08	2.311E-08
WNW	27	3.870E-06	1.117E-06	3.957E-07	2.180E-07	1.424E-07	7.698E-08	5.493E-08	3.954E-08
NW	37	4.877E-06	1.466E-06	5.151E-07	2.804E-07	1.817E-07	9.711E-08	6.259E-08	4.476E-08
NNW	71	1.065E-05	3.204E-06	1.129E-06	6.209E-07	4.039E-07	2.168E-07	1.399E-07	1.001E-07
AVERAGE	2074	1.556E-05	4.672E-06	1.595E-06	8.672E-07	5.617E-07	3.020E-07	1.955E-07	1.402E-07
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	104	1.211E-07	9.724E-08	8.047E-08	6.802E-08	5.860E-08	3.359E-08	2.283E-08	1.334E-08
NNE	177	1.617E-07	1.297E-07	1.072E-07	9.045E-08	7.780E-08	4.448E-08	3.015E-08	1.751E-08
NE	186	2.075E-07	1.668E-07	1.382E-07	1.170E-07	1.010E-07	5.827E-08	3.974E-08	2.328E-08
ENE	250	2.558E-07	2.045E-07	1.687E-07	1.421E-07	1.220E-07	6.941E-08	4.683E-08	2.696E-08
E	376	2.541E-07	2.019E-07	1.656E-07	1.388E-07	1.187E-07	6.656E-08	4.439E-08	2.511E-08
ESE	235	1.776E-07	1.418E-07	1.168E-07	9.831E-08	8.435E-08	4.786E-08	3.221E-08	1.847E-08
SE	145	1.080E-07	8.612E-08	7.794E-08	6.552E-08	5.614E-08	2.883E-08	1.933E-08	1.102E-08
SSE	89	6.155E-08	4.924E-08	4.064E-08	3.429E-08	2.945E-08	1.679E-08	1.133E-08	6.513E-09
S	91	5.941E-08	4.770E-08	3.950E-08	3.342E-08	2.877E-08	1.652E-08	1.125E-08	6.585E-09
SSW	105	7.134E-08	5.723E-08	4.739E-08	4.015E-08	3.463E-08	2.000E-08	1.363E-08	7.968E-09
SW	82	4.038E-08	3.208E-08	2.634E-08	2.214E-08	1.897E-08	1.074E-08	7.191E-09	4.084E-09
WSW	80	4.128E-08	3.291E-08	2.981E-08	2.513E-08	2.159E-08	1.123E-08	7.638E-09	4.461E-09
W	19	1.768E-08	1.412E-08	1.163E-08	9.800E-09	8.415E-09	4.789E-09	3.224E-09	1.845E-09
WNW	27	3.052E-08	2.452E-08	1.844E-08	1.556E-08	1.338E-08	7.631E-09	5.174E-09	3.013E-09
NW	37	3.425E-08	2.735E-08	2.253E-08	1.896E-08	1.626E-08	9.219E-09	6.201E-09	3.554E-09
NNW	71	7.659E-08	6.115E-08	5.037E-08	4.238E-08	3.636E-08	2.063E-08	1.388E-08	7.946E-09
AVERAGE	2074	1.074E-07	8.589E-08	7.134E-08	6.013E-08	5.165E-08	2.916E-08	1.969E-08	1.135E-08
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	104	9.164E-09	6.800E-09	5.499E-09	4.552E-09	3.850E-09	3.333E-09	2.927E-09	
NNE	177	1.200E-08	9.001E-09	7.167E-09	5.920E-09	4.996E-09	4.319E-09	3.787E-09	
NE	186	1.603E-08	1.207E-08	9.643E-09	7.987E-09	6.756E-09	5.846E-09	5.132E-09	
ENE	250	1.838E-08	1.373E-08	1.090E-08	8.982E-09	7.564E-09	6.527E-09	5.713E-09	
E	376	1.697E-08	1.261E-08	9.959E-09	8.176E-09	6.867E-09	5.919E-09	5.176E-09	
ESE	235	1.258E-08	9.396E-09	7.454E-09	6.141E-09	5.172E-09	4.465E-09	3.910E-09	
SE	145	7.487E-09	5.584E-09	4.424E-09	3.642E-09	3.066E-09	2.648E-09	2.320E-09	
SSE	89	4.453E-09	3.337E-09	2.654E-09	2.192E-09	1.851E-09	1.602E-09	1.407E-09	
S	91	4.554E-09	3.443E-09	2.756E-09	2.289E-09	1.942E-09	1.688E-09	1.488E-09	
SSW	105	5.494E-09	4.143E-09	3.313E-09	2.747E-09	2.327E-09	2.016E-09	1.772E-09	
SW	82	2.773E-09	2.067E-09	1.638E-09	1.348E-09	1.134E-09	9.782E-10	8.564E-10	
WSW	80	3.079E-09	2.322E-09	1.857E-09	1.539E-09	1.303E-09	1.128E-09	9.907E-10	
W	19	1.255E-09	9.364E-10	7.424E-10	6.111E-10	5.142E-10	4.434E-10	3.879E-10	
WNW	27	2.066E-09	1.550E-09	1.235E-09	1.020E-09	8.614E-10	7.456E-10	6.542E-10	
NW	37	2.420E-09	1.807E-09	1.434E-09	1.181E-09	9.945E-10	8.587E-10	7.522E-10	
NNW	71	5.397E-09	4.022E-09	3.186E-09	2.620E-09	2.202E-09	1.898E-09	1.659E-09	
AVERAGE	2074	7.756E-09	5.807E-09	4.616E-09	3.809E-09	3.213E-09	2.776E-09	2.433E-09	

Table B-1

Undepleted X/Q Factors for Reactor Building Vent

BECO 2nd Quarter 1994 General Ground Level X/Q's

SECTOR AVERAGE MODEL

GROUND RELEASE: GROUND-LEVEL AVERAGE CHI/Q BEFORE DEPLETION - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	317	2.767E-05	8.421E-06	2.888E-06	1.546E-06	9.936E-07	5.312E-07	3.431E-07	2.456E-07
NNE	476	4.709E-05	1.436E-05	4.945E-06	2.688E-06	1.741E-06	9.340E-07	6.027E-07	4.310E-07
NE	256	4.185E-05	1.237E-05	3.939E-06	2.128E-06	1.383E-06	7.726E-07	5.128E-07	3.743E-07
ENE	171	3.192E-05	9.447E-06	3.120E-06	1.715E-06	1.122E-06	6.173E-07	4.045E-07	2.929E-07
E	184	3.221E-05	9.541E-06	3.175E-06	1.746E-06	1.143E-06	6.259E-07	4.083E-07	2.946E-07
ESE	119	1.687E-05	5.069E-06	1.747E-06	9.509E-07	6.168E-07	3.323E-07	2.152E-07	1.545E-07
SE	79	1.416E-05	4.261E-06	1.628E-06	8.809E-07	5.685E-07	3.048E-07	1.791E-07	1.283E-07
SSE	74	1.182E-05	3.573E-06	1.221E-06	6.043E-07	3.925E-07	2.107E-07	1.359E-07	9.730E-08
S	78	1.122E-05	3.381E-06	9.270E-07	4.860E-07	3.094E-07	1.669E-07	1.094E-07	7.920E-08
SSW	94	6.538E-06	1.975E-06	5.788E-07	2.989E-07	1.897E-07	1.010E-07	6.572E-08	4.741E-08
SW	64	4.970E-06	1.559E-06	4.541E-07	2.348E-07	1.494E-07	7.855E-08	5.036E-08	3.587E-08
WSW	39	5.005E-06	1.505E-06	4.768E-07	2.561E-07	1.645E-07	8.720E-08	5.603E-08	4.002E-08
W	25	4.053E-06	1.268E-06	3.940E-07	2.326E-07	1.491E-07	7.980E-08	4.675E-08	3.333E-08
WNW	56	5.814E-06	1.805E-06	5.997E-07	3.217E-07	2.079E-07	1.110E-07	7.865E-08	5.615E-08
NW	58	8.101E-06	2.448E-06	8.439E-07	4.559E-07	2.943E-07	1.568E-07	1.007E-07	7.182E-08
NNW	77	1.158E-05	3.492E-06	1.227E-06	6.682E-07	4.323E-07	2.306E-07	1.482E-07	1.058E-07
AVERAGE	2167	1.755E-05	5.280E-06	1.760E-06	9.508E-07	6.161E-07	3.338E-07	2.161E-07	1.555E-07
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	317	1.876E-07	1.497E-07	1.233E-07	1.039E-07	8.919E-08	5.070E-08	3.418E-08	1.968E-08
NNE	476	3.292E-07	2.626E-07	2.162E-07	1.821E-07	1.563E-07	8.887E-08	5.985E-08	3.432E-08
NE	256	2.902E-07	2.344E-07	1.950E-07	1.660E-07	1.438E-07	8.410E-08	5.789E-08	3.438E-08
ENE	171	2.263E-07	1.821E-07	1.510E-07	1.280E-07	1.106E-07	6.404E-08	4.380E-08	2.573E-08
E	184	2.272E-07	1.826E-07	1.513E-07	1.280E-07	1.104E-07	6.373E-08	4.350E-08	2.549E-08
ESE	119	1.184E-07	9.473E-08	7.816E-08	6.591E-08	5.665E-08	3.231E-08	2.183E-08	1.260E-08
SE	79	9.821E-08	7.845E-08	7.112E-08	5.989E-08	5.141E-08	2.921E-08	1.971E-08	1.138E-08
SSE	74	7.449E-08	5.953E-08	4.909E-08	4.137E-08	3.554E-08	2.027E-08	1.370E-08	7.901E-09
S	78	6.101E-08	4.902E-08	4.062E-08	3.442E-08	2.970E-08	1.715E-08	1.170E-08	6.876E-09
SSW	94	3.649E-08	2.931E-08	2.430E-08	2.060E-08	1.777E-08	1.027E-08	7.030E-09	4.153E-09
SW	64	2.726E-08	2.171E-08	1.788E-08	1.509E-08	1.297E-08	7.426E-09	5.034E-09	2.919E-09
WSW	39	3.063E-08	2.445E-08	2.215E-08	1.863E-08	1.597E-08	8.222E-09	5.552E-09	3.216E-09
W	25	2.530E-08	2.009E-08	1.649E-08	1.386E-08	1.188E-08	6.727E-09	4.512E-09	2.571E-09
WNW	56	4.279E-08	3.410E-08	2.553E-08	2.153E-08	1.850E-08	1.057E-08	7.131E-09	4.088E-09
NW	58	5.488E-08	4.378E-08	3.603E-08	3.031E-08	2.599E-08	1.474E-08	9.953E-09	5.760E-09
NNW	77	8.082E-08	6.445E-08	5.302E-08	4.456E-08	3.820E-08	2.161E-08	1.454E-08	8.362E-09
AVERAGE	2167	1.194E-07	9.569E-08	7.946E-08	6.713E-08	5.780E-08	3.312E-08	2.249E-08	1.309E-08
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	317	1.345E-08	1.008E-08	8.019E-09	6.623E-09	5.593E-09	4.838E-09	4.247E-09	
NNE	476	2.337E-08	1.746E-08	1.385E-08	1.141E-08	9.607E-09	8.287E-09	7.252E-09	
NE	256	2.383E-08	1.804E-08	1.448E-08	1.203E-08	1.020E-08	8.839E-09	7.769E-09	
ENE	171	1.772E-08	1.334E-08	1.066E-08	8.825E-09	7.459E-09	6.446E-09	5.651E-09	
E	184	1.755E-08	1.320E-08	1.054E-08	8.725E-09	7.373E-09	6.373E-09	5.588E-09	
ESE	119	8.608E-09	6.444E-09	5.123E-09	4.227E-09	3.564E-09	3.078E-09	2.697E-09	
SE	79	7.777E-09	5.825E-09	4.632E-09	3.824E-09	3.226E-09	2.789E-09	2.446E-09	
SSE	74	5.400E-09	4.045E-09	3.216E-09	2.653E-09	2.237E-09	1.932E-09	1.693E-09	
S	78	4.757E-09	3.598E-09	2.883E-09	2.396E-09	2.034E-09	1.767E-09	1.557E-09	
SSW	94	2.893E-09	2.200E-09	1.769E-09	1.475E-09	1.256E-09	1.095E-09	9.678E-10	
SW	64	2.019E-09	1.527E-09	1.223E-09	1.016E-09	8.634E-10	7.504E-10	6.620E-10	
WSW	39	2.205E-09	1.655E-09	1.318E-09	1.090E-09	9.211E-10	7.979E-10	7.009E-10	
W	25	1.746E-09	1.302E-09	1.032E-09	8.496E-10	7.150E-10	6.162E-10	5.391E-10	
WNW	56	2.792E-09	2.090E-09	1.662E-09	1.371E-09	1.156E-09	9.981E-10	8.747E-10	
NW	58	3.947E-09	2.962E-09	2.359E-09	1.949E-09	1.646E-09	1.424E-09	1.250E-09	
NNW	77	5.700E-09	4.260E-09	3.382E-09	2.787E-09	2.348E-09	2.027E-09	1.775E-09	
AVERAGE	2167	8.985E-09	6.752E-09	5.384E-09	4.453E-09	3.763E-09	3.254E-09	2.854E-09	

Table B-1

Undepleted X/Q Factors for Reactor Building Vent

BECo 3rd Quarter 1994 General Ground Level X/Q's

SECTOR AVERAGE MODEL

GROUND RELEASE: GROUND-LEVEL AVERAGE CHI/Q BEFORE DEPLETION - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	185	2.969E-05	9.097E-06	3.122E-06	1.710E-06	1.112E-06	5.967E-07	3.846E-07	2.747E-07
NNE	519	6.947E-05	2.121E-05	7.366E-06	4.009E-06	2.591E-06	1.391E-06	8.989E-07	6.432E-07
NE	434	8.851E-05	2.636E-05	8.378E-06	4.500E-06	2.912E-06	1.624E-06	1.078E-06	7.870E-07
ENE	201	4.530E-05	1.337E-05	4.356E-06	2.352E-06	1.524E-06	8.460E-07	5.593E-07	4.072E-07
E	134	3.121E-05	9.393E-06	3.205E-06	1.753E-06	1.139E-06	6.196E-07	4.033E-07	2.902E-07
ESE	91	1.948E-05	5.915E-06	2.010E-06	1.088E-06	7.036E-07	3.797E-07	2.462E-07	1.767E-07
SE	74	1.458E-05	4.459E-06	1.732E-06	9.430E-07	6.093E-07	3.244E-07	1.894E-07	1.350E-07
SSE	71	1.446E-05	4.433E-06	1.557E-06	7.709E-07	4.987E-07	2.659E-07	1.710E-07	1.220E-07
S	113	1.901E-05	5.813E-06	1.701E-06	9.193E-07	5.933E-07	3.154E-07	2.024E-07	1.442E-07
SSW	106	1.247E-05	3.876E-06	1.219E-06	6.477E-07	4.141E-07	2.190E-07	1.408E-07	1.004E-07
SW	64	9.701E-06	3.053E-06	9.678E-07	5.136E-07	3.268E-07	1.719E-07	1.098E-07	7.779E-08
WSW	43	7.906E-06	2.508E-06	8.287E-07	4.459E-07	2.846E-07	1.487E-07	9.462E-08	6.681E-08
W	25	4.543E-06	1.436E-06	4.811E-07	2.871E-07	1.840E-07	9.658E-08	5.588E-08	3.945E-08
WNW	38	6.745E-06	2.040E-06	7.576E-07	4.144E-07	2.671E-07	1.413E-07	9.950E-08	7.074E-08
NW	32	8.402E-06	2.511E-06	9.109E-07	5.009E-07	3.247E-07	1.734E-07	1.116E-07	7.974E-08
NNW	36	1.138E-05	3.422E-06	1.158E-06	6.467E-07	4.262E-07	2.325E-07	1.508E-07	1.083E-07
AVERAGE	2166	2.455E-05	7.431E-06	2.484E-06	1.344E-06	8.695E-07	4.717E-07	3.060E-07	2.202E-07
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	185	2.098E-07	1.673E-07	1.377E-07	1.159E-07	9.956E-08	5.667E-08	3.818E-08	2.186E-08
NNE	519	4.912E-07	3.917E-07	3.224E-07	2.714E-07	2.329E-07	1.323E-07	8.896E-08	5.090E-08
NE	434	6.095E-07	4.917E-07	4.090E-07	3.479E-07	3.015E-07	1.762E-07	1.212E-07	7.193E-08
ENE	201	3.152E-07	2.541E-07	2.111E-07	1.793E-07	1.551E-07	9.016E-08	6.186E-08	3.663E-08
E	134	2.227E-07	1.783E-07	1.473E-07	1.243E-07	1.070E-07	6.129E-08	4.150E-08	2.400E-08
ESE	91	1.353E-07	1.082E-07	8.921E-08	7.526E-08	6.471E-08	3.698E-08	2.500E-08	1.443E-08
SE	74	1.029E-07	8.189E-08	7.401E-08	6.216E-08	5.325E-08	3.006E-08	2.013E-08	1.145E-08
SSE	71	9.296E-08	7.401E-08	6.083E-08	5.112E-08	4.382E-08	2.478E-08	1.660E-08	9.425E-09
S	113	1.098E-07	8.731E-08	7.173E-08	6.026E-08	5.161E-08	2.911E-08	1.948E-08	1.106E-08
SSW	106	7.628E-08	6.063E-08	4.980E-08	4.187E-08	3.587E-08	2.027E-08	1.354E-08	7.658E-09
SW	64	5.879E-08	4.651E-08	3.804E-08	3.186E-08	2.723E-08	1.524E-08	1.015E-08	5.730E-09
WSW	43	5.035E-08	3.972E-08	3.563E-08	2.974E-08	2.535E-08	1.278E-08	8.410E-09	4.639E-09
W	25	2.973E-08	2.345E-08	1.912E-08	1.595E-08	1.359E-08	7.519E-09	4.935E-09	2.706E-09
WNW	38	5.384E-08	4.276E-08	3.186E-08	2.666E-08	2.277E-08	1.270E-08	8.436E-09	4.749E-09
NW	32	6.101E-08	4.866E-08	4.003E-08	3.361E-08	2.879E-08	1.623E-08	1.088E-08	6.205E-09
NNW	36	8.316E-08	6.659E-08	5.501E-08	4.649E-08	3.999E-08	2.297E-08	1.557E-08	8.993E-09
AVERAGE	2166	1.689E-07	1.352E-07	1.121E-07	9.461E-08	8.144E-08	4.657E-08	3.155E-08	1.827E-08
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	185	1.487E-08	1.109E-08	8.787E-09	7.228E-09	6.077E-09	5.231E-09	4.570E-09	
NNE	519	3.458E-08	2.578E-08	2.044E-08	1.681E-08	1.414E-08	1.219E-08	1.066E-08	
NE	434	4.985E-08	3.773E-08	3.020E-08	2.517E-08	2.135E-08	1.850E-08	1.626E-08	
ENE	201	2.535E-08	1.916E-08	1.536E-08	1.276E-08	1.081E-08	9.370E-09	8.236E-09	
E	134	1.639E-08	1.227E-08	9.755E-09	8.047E-09	6.782E-09	5.851E-09	5.121E-09	
ESE	91	9.865E-09	7.389E-09	5.878E-09	4.852E-09	4.093E-09	3.534E-09	3.097E-09	
SE	74	7.753E-09	5.767E-09	4.562E-09	3.747E-09	3.148E-09	2.712E-09	2.370E-09	
SSE	71	6.380E-09	4.744E-09	3.750E-09	3.090E-09	2.587E-09	2.227E-09	1.946E-09	
S	113	7.505E-09	5.591E-09	4.426E-09	3.640E-09	3.062E-09	2.642E-09	2.314E-09	
SSW	106	5.193E-09	3.869E-09	3.063E-09	2.521E-09	2.123E-09	1.833E-09	1.607E-09	
SW	64	3.880E-09	2.888E-09	2.285E-09	1.880E-09	1.582E-09	1.366E-09	1.196E-09	
WSW	43	3.091E-09	2.272E-09	1.780E-09	1.451E-09	1.211E-09	1.039E-09	9.051E-10	
W	25	1.795E-09	1.314E-09	1.026E-09	8.344E-10	6.950E-10	5.949E-10	5.172E-10	
WNW	38	3.194E-09	2.363E-09	1.861E-09	1.524E-09	1.277E-09	1.099E-09	9.595E-10	
NW	32	4.203E-09	3.126E-09	2.472E-09	2.030E-09	1.705E-09	1.469E-09	1.284E-09	
NNW	36	6.132E-09	4.581E-09	3.637E-09	2.994E-09	2.518E-09	2.166E-09	1.891E-09	
AVERAGE	2166	1.250E-08	9.370E-09	7.460E-09	6.160E-09	5.198E-09	4.489E-09	3.933E-09	

Table B-1

Undepleted X/Q Factors for Reactor Building Vent

BECo 4th Quarter 1994 General Ground Level X/Q's

SECTOR AVERAGE MODEL

GROUND RELEASE: GROUND-LEVEL AVERAGE CHI/Q BEFORE DEPLETION - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	117	2.122E-05	6.362E-06	2.186E-06	1.209E-06	7.902E-07	4.290E-07	2.780E-07	1.996E-07
NNE	263	3.378E-05	1.003E-05	3.483E-06	1.928E-06	1.261E-06	6.834E-07	4.429E-07	3.180E-07
NE	319	6.145E-05	1.817E-05	5.808E-06	3.185E-06	2.087E-06	1.165E-06	7.700E-07	5.606E-07
ENE	234	5.017E-05	1.473E-05	4.863E-06	2.669E-06	1.745E-06	9.666E-07	6.362E-07	4.619E-07
E	283	4.196E-05	1.258E-05	4.374E-06	2.405E-06	1.566E-06	8.454E-07	5.469E-07	3.921E-07
ESE	188	2.435E-05	7.376E-06	2.581E-06	1.414E-06	9.184E-07	4.921E-07	3.171E-07	2.266E-07
SE	164	1.859E-05	5.666E-06	1.980E-06	1.078E-06	6.984E-07	3.729E-07	2.397E-07	1.709E-07
SSE	104	1.039E-05	3.157E-06	1.120E-06	6.045E-07	3.891E-07	2.062E-07	1.323E-07	9.428E-08
S	76	1.090E-05	3.249E-06	1.051E-06	5.693E-07	3.674E-07	1.956E-07	1.260E-07	9.010E-08
SSW	145	1.706E-05	5.273E-06	1.676E-06	9.022E-07	5.808E-07	3.076E-07	1.968E-07	1.398E-07
SW	106	9.177E-06	2.946E-06	9.549E-07	5.087E-07	3.232E-07	1.682E-07	1.068E-07	7.531E-08
WSW	34	3.960E-06	1.235E-06	4.092E-07	2.212E-07	1.417E-07	7.438E-08	4.737E-08	3.350E-08
W	13	1.541E-06	4.645E-07	1.542E-07	9.176E-08	5.874E-08	3.093E-08	1.801E-08	1.283E-08
WNW	34	3.120E-06	1.028E-06	3.742E-07	2.003E-07	1.272E-07	6.592E-08	4.584E-08	3.214E-08
NW	52	1.049E-05	3.137E-06	1.132E-06	6.255E-07	4.068E-07	2.179E-07	1.403E-07	1.002E-07
NNW	71	1.259E-05	3.808E-06	1.378E-06	7.572E-07	4.906E-07	2.616E-07	1.680E-07	1.198E-07
AVERAGE	2203	2.067E-05	6.201E-06	2.095E-06	1.148E-06	7.470E-07	4.052E-07	2.633E-07	1.892E-07
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	117	1.531E-07	1.226E-07	1.012E-07	8.531E-08	7.337E-08	4.194E-08	2.839E-08	1.642E-08
NNE	263	2.444E-07	1.958E-07	1.616E-07	1.363E-07	1.172E-07	6.692E-08	4.532E-08	2.625E-08
NE	319	4.344E-07	3.505E-07	2.915E-07	2.479E-07	2.147E-07	1.254E-07	8.626E-08	5.110E-08
ENE	234	3.574E-07	2.880E-07	2.391E-07	2.028E-07	1.752E-07	1.016E-07	6.961E-08	4.106E-08
E	283	3.006E-07	2.404E-07	1.982E-07	1.670E-07	1.435E-07	8.173E-08	5.522E-08	3.186E-08
ESE	188	1.732E-07	1.382E-07	1.137E-07	9.567E-08	8.208E-08	4.656E-08	3.132E-08	1.793E-08
SE	164	1.303E-07	1.038E-07	9.384E-08	7.888E-08	6.761E-08	3.477E-08	2.333E-08	1.330E-08
SSE	104	7.187E-08	5.721E-08	4.701E-08	3.947E-08	3.379E-08	1.903E-08	1.274E-08	7.255E-09
S	76	6.902E-08	5.514E-08	4.542E-08	3.820E-08	3.275E-08	1.852E-08	1.246E-08	7.160E-09
SSW	145	1.061E-07	8.423E-08	6.908E-08	5.797E-08	4.960E-08	2.791E-08	1.865E-08	1.057E-08
SW	106	5.664E-08	4.463E-08	3.637E-08	3.037E-08	2.588E-08	1.437E-08	9.464E-09	5.222E-09
WSW	34	2.533E-08	2.003E-08	1.799E-08	1.503E-08	1.282E-08	6.472E-09	4.279E-09	2.386E-09
W	13	9.795E-09	7.797E-09	6.402E-09	5.363E-09	4.586E-09	2.569E-09	1.719E-09	9.816E-10
WNW	34	2.399E-08	1.879E-08	1.385E-08	1.152E-08	9.787E-09	5.373E-09	3.490E-09	1.871E-09
NW	52	7.665E-08	6.114E-08	5.029E-08	4.223E-08	3.619E-08	2.042E-08	1.370E-08	7.819E-09
NNW	71	9.135E-08	7.272E-08	5.972E-08	5.010E-08	4.288E-08	2.412E-08	1.612E-08	9.148E-09
AVERAGE	2203	1.453E-07	1.163E-07	9.658E-08	8.150E-08	7.012E-08	3.986E-08	2.700E-08	1.565E-08
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	117	1.121E-08	8.379E-09	6.657E-09	5.486E-09	4.619E-09	3.981E-09	3.480E-09	
NNE	263	1.792E-08	1.341E-08	1.066E-08	8.785E-09	7.398E-09	6.381E-09	5.582E-09	
NE	319	3.535E-08	2.670E-08	2.139E-08	1.774E-08	1.502E-08	1.299E-08	1.140E-08	
ENE	234	2.833E-08	2.136E-08	1.709E-08	1.416E-08	1.198E-08	1.037E-08	9.095E-09	
E	283	2.173E-08	1.624E-08	1.289E-08	1.062E-08	8.944E-09	7.713E-09	6.747E-09	
ESE	188	1.218E-08	9.082E-09	7.196E-09	5.919E-09	4.978E-09	4.289E-09	3.756E-09	
SE	164	9.035E-09	6.734E-09	5.334E-09	4.388E-09	3.691E-09	3.183E-09	2.784E-09	
SSE	104	4.926E-09	3.672E-09	2.908E-09	2.393E-09	2.015E-09	1.740E-09	1.524E-09	
S	76	4.883E-09	3.651E-09	2.898E-09	2.390E-09	2.015E-09	1.743E-09	1.528E-09	
SSW	145	7.165E-09	5.336E-09	4.223E-09	3.473E-09	2.922E-09	2.520E-09	2.207E-09	
SW	106	3.488E-09	2.568E-09	2.015E-09	1.645E-09	1.376E-09	1.181E-09	1.030E-09	
WSW	34	1.599E-09	1.180E-09	9.276E-10	7.584E-10	6.348E-10	5.457E-10	4.761E-10	
W	13	6.661E-10	4.961E-10	3.927E-10	3.230E-10	2.717E-10	2.347E-10	2.055E-10	
WNW	34	1.227E-09	8.906E-10	6.908E-10	5.584E-10	4.627E-10	3.943E-10	3.415E-10	
NW	52	5.297E-09	3.939E-09	3.115E-09	2.558E-09	2.148E-09	1.849E-09	1.615E-09	
NNW	71	6.178E-09	4.585E-09	3.619E-09	2.968E-09	2.490E-09	2.143E-09	1.870E-09	
AVERAGE	2203	1.070E-08	8.014E-09	6.375E-09	5.261E-09	4.436E-09	3.828E-09	3.352E-09	

Table B-1

Undepleted X/Q Factors for Reactor Building Vent

RECo 1994 General Ground Level X/Q's

SECTOR AVERAGE MODEL

GROUND RELEASE: GROUND-LEVEL AVERAGE CHI/Q BEFORE DEPLETION - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	723	2.399E-05	7.252E-06	2.490E-06	1.355E-06	8.779E-07	4.733E-07	3.065E-07	2.198E-07
NNE	1435	4.347E-05	1.314E-05	4.550E-06	2.486E-06	1.613E-06	8.685E-07	5.616E-07	4.023E-07
NE	1195	5.566E-05	1.651E-05	5.290E-06	2.866E-06	1.864E-06	1.038E-06	6.870E-07	5.005E-07
ENE	856	4.091E-05	1.210E-05	4.030E-06	2.202E-06	1.434E-06	7.889E-07	5.174E-07	3.747E-07
E	977	3.544E-05	1.066E-05	3.605E-06	2.016E-06	1.310E-06	7.065E-07	4.573E-07	3.280E-07
ESE	633	2.147E-05	6.485E-06	2.248E-06	1.224E-06	7.938E-07	4.263E-07	2.754E-07	1.972E-07
SE	462	1.573E-05	4.773E-06	1.674E-06	9.092E-07	5.877E-07	3.136E-07	2.018E-07	1.441E-07
SSE	338	1.084E-05	3.291E-06	1.146E-06	6.213E-07	4.018E-07	2.144E-07	1.381E-07	9.864E-08
S	358	1.217E-05	3.668E-06	1.147E-06	6.148E-07	3.957E-07	2.113E-07	1.365E-07	9.764E-08
SSW	450	1.196E-05	3.669E-06	1.133E-06	6.037E-07	3.876E-07	2.066E-07	1.333E-07	9.530E-08
SW	316	7.617E-06	2.405E-06	7.550E-07	4.006E-07	2.554E-07	1.341E-07	8.562E-08	6.067E-08
WSW	196	5.946E-06	1.845E-06	5.870E-07	3.157E-07	2.026E-07	1.069E-07	6.832E-08	4.849E-08
W	82	3.223E-06	1.001E-06	3.233E-07	1.924E-07	1.236E-07	6.555E-08	3.821E-08	2.716E-08
WNW	155	4.891E-06	1.500E-06	5.326E-07	2.890E-07	1.864E-07	9.890E-08	6.979E-08	4.968E-08
NW	179	8.011E-06	2.404E-06	8.553E-07	4.683E-07	3.036E-07	1.622E-07	1.044E-07	7.456E-08
NNW	255	1.156E-05	3.486E-06	1.225E-06	6.742E-07	4.388E-07	2.357E-07	1.519E-07	1.086E-07
AVERAGE	8610	1.956E-05	5.887E-06	1.979E-06	1.077E-06	6.985E-07	3.782E-07	2.458E-07	1.767E-07
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	723	1.684E-07	1.346E-07	1.110E-07	9.353E-08	8.038E-08	4.584E-08	3.097E-08	1.787E-08
NNE	1435	3.079E-07	2.460E-07	2.027E-07	1.707E-07	1.467E-07	8.348E-08	5.630E-08	3.238E-08
NE	1195	3.875E-07	3.126E-07	2.599E-07	2.209E-07	1.913E-07	1.116E-07	7.670E-08	4.543E-08
ENE	856	2.893E-07	2.327E-07	1.929E-07	1.634E-07	1.411E-07	8.152E-08	5.568E-08	3.269E-08
E	977	2.513E-07	2.009E-07	1.657E-07	1.397E-07	1.200E-07	6.840E-08	4.621E-08	2.665E-08
ESE	633	1.509E-07	1.205E-07	9.935E-08	8.368E-08	7.185E-08	4.088E-08	2.756E-08	1.584E-08
SE	462	1.100E-07	8.764E-08	7.930E-08	6.667E-08	5.716E-08	2.940E-08	1.774E-08	1.128E-08
SSE	338	7.535E-08	6.010E-08	4.948E-08	4.163E-08	3.571E-08	2.025E-08	1.161E-08	7.785E-09
S	358	7.494E-08	5.990E-08	4.941E-08	4.165E-08	3.577E-08	2.036E-08	1.174E-08	7.932E-09
SSW	450	7.271E-08	5.797E-08	4.774E-08	4.022E-08	3.453E-08	1.964E-08	1.323E-08	7.595E-09
SW	316	4.587E-08	3.631E-08	2.972E-08	2.492E-08	2.131E-08	1.197E-08	7.974E-09	4.496E-09
WSW	196	3.680E-08	2.920E-08	2.632E-08	2.207E-08	1.888E-08	9.645E-09	6.448E-09	3.661E-09
W	82	2.061E-08	1.635E-08	1.340E-08	1.123E-08	9.610E-09	5.395E-09	3.593E-09	2.023E-09
WNW	155	3.780E-08	3.005E-08	2.243E-08	1.882E-08	1.611E-08	9.067E-09	6.056E-09	3.428E-09
NW	179	5.702E-08	4.549E-08	3.743E-08	3.146E-08	2.696E-08	1.524E-08	1.024E-08	5.868E-09
NNW	255	8.308E-08	6.631E-08	5.460E-08	4.593E-08	3.941E-08	2.236E-08	1.505E-08	8.622E-09
AVERAGE	8610	1.356E-07	1.085E-07	9.008E-08	7.604E-08	6.542E-08	3.719E-08	2.519E-08	1.460E-08
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	723	1.220E-08	9.129E-09	7.257E-09	5.986E-09	5.045E-09	4.355E-09	3.814E-09	
NNE	1435	2.206E-08	1.648E-08	1.308E-08	1.078E-08	9.073E-09	7.825E-09	6.847E-09	
NE	1195	3.144E-08	2.377E-08	1.906E-08	1.582E-08	1.341E-08	1.161E-08	1.020E-08	
ENE	856	2.251E-08	1.695E-08	1.355E-08	1.122E-08	9.486E-09	8.204E-09	7.197E-09	
E	977	1.819E-08	1.360E-08	1.081E-08	8.908E-09	7.505E-09	6.475E-09	5.668E-09	
ESE	633	1.080E-08	8.088E-09	6.405E-09	5.278E-09	4.446E-09	3.837E-09	3.359E-09	
SE	462	7.668E-09	5.720E-09	4.534E-09	3.732E-09	3.141E-09	2.711E-09	2.373E-09	
SSE	338	5.297E-09	3.955E-09	3.136E-09	2.583E-09	2.175E-09	1.878E-09	1.644E-09	
S	358	5.432E-09	4.075E-09	3.244E-09	2.682E-09	2.266E-09	1.962E-09	1.723E-09	
SSW	450	5.191E-09	3.890E-09	3.094E-09	2.556E-09	2.158E-09	1.867E-09	1.639E-09	
SW	316	3.045E-09	2.266E-09	1.793E-09	1.474E-09	1.240E-09	1.070E-09	9.375E-10	
WSW	196	2.483E-09	1.850E-09	1.464E-09	1.204E-09	1.013E-09	8.736E-10	7.646E-10	
W	82	1.364E-09	1.011E-09	7.972E-10	6.536E-10	5.482E-10	4.716E-10	4.118E-10	
WNW	155	2.318E-09	1.722E-09	1.361E-09	1.117E-09	9.381E-10	8.082E-10	7.065E-10	
NW	179	3.989E-09	2.975E-09	2.358E-09	1.940E-09	1.632E-09	1.408E-09	1.232E-09	
NNW	255	5.858E-09	4.367E-09	3.460E-09	2.845E-09	2.392E-09	2.060E-09	1.801E-09	
AVERAGE	8610	9.990E-09	7.489E-09	5.962E-09	4.923E-09	4.154E-09	3.589E-09	3.145E-09	

Table B-2

Depleted X/Q Factors for Reactor Building Vent

BECo 1st Quarter 1994 General Ground Level X/Q's
 GROUND RELEASE: GROUND-LEVEL AVERAGE CHI/Q AFTER DEPLETION (REGULATORY GUIDE 1.111 DEPLETION MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	104	1.651E-05	4.796E-06	1.588E-06	8.376E-07	5.314E-07	2.824E-07	1.798E-07	1.272E-07
NNE	177	2.202E-05	6.403E-06	2.129E-06	1.138E-06	7.303E-07	3.843E-07	2.422E-07	1.702E-07
NE	186	2.856E-05	8.339E-06	2.677E-06	1.419E-06	9.076E-07	4.841E-07	3.081E-07	2.178E-07
ENE	250	3.461E-05	1.020E-05	3.432E-06	1.834E-06	1.173E-06	6.138E-07	3.857E-07	2.702E-07
E	376	3.501E-05	1.056E-05	3.646E-06	1.924E-06	1.217E-06	6.256E-07	3.892E-07	2.705E-07
ESE	235	2.440E-05	7.233E-06	2.436E-06	1.293E-06	8.247E-07	4.290E-07	2.687E-07	1.878E-07
SE	145	1.496E-05	4.453E-06	1.515E-06	7.995E-07	5.078E-07	2.627E-07	1.642E-07	1.145E-07
SSE	89	8.693E-06	2.569E-06	8.500E-07	4.461E-07	2.841E-07	1.478E-07	9.280E-08	6.502E-08
S	91	9.666E-06	2.825E-06	8.252E-07	4.275E-07	2.714E-07	1.412E-07	8.887E-08	6.248E-08
SSW	105	1.125E-05	3.344E-06	9.549E-07	4.982E-07	3.170E-07	1.678E-07	1.065E-07	7.513E-08
SW	82	6.316E-06	1.934E-06	5.802E-07	3.039E-07	1.925E-07	9.931E-08	6.188E-08	4.302E-08
WSW	80	6.742E-06	2.049E-06	5.836E-07	3.052E-07	1.941E-07	1.010E-07	6.294E-08	4.383E-08
W	19	2.668E-06	7.977E-07	2.416E-07	1.411E-07	9.005E-08	4.689E-08	2.674E-08	1.871E-08
WNW	27	3.732E-06	1.061E-06	3.617E-07	1.943E-07	1.249E-07	6.562E-08	4.550E-08	3.201E-08
NW	37	4.704E-06	1.392E-06	4.708E-07	2.498E-07	1.593E-07	8.279E-08	5.185E-08	3.624E-08
NNW	71	1.027E-05	3.044E-06	1.032E-06	5.533E-07	3.541E-07	1.849E-07	1.159E-07	8.101E-08
AVERAGE	2074	1.501E-05	4.438E-06	1.458E-06	7.728E-07	4.924E-07	2.574E-07	1.619E-07	1.135E-07

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	104	9.630E-08	7.608E-08	6.203E-08	5.178E-08	4.406E-08	2.373E-08	1.536E-08	8.335E-09
NNE	177	1.286E-07	1.014E-07	8.262E-08	6.886E-08	5.849E-08	3.142E-08	2.028E-08	1.094E-08
NE	186	1.650E-07	1.305E-07	1.065E-07	8.910E-08	7.592E-08	4.117E-08	2.673E-08	1.454E-08
ENE	250	2.034E-07	1.600E-07	1.300E-07	1.082E-07	9.174E-08	4.904E-08	3.150E-08	1.684E-08
E	376	2.021E-07	1.579E-07	1.276E-07	1.056E-07	8.923E-08	4.703E-08	2.987E-08	1.569E-08
ESE	235	1.412E-07	1.109E-07	9.003E-08	7.483E-08	6.342E-08	3.382E-08	2.167E-08	1.154E-08
SE	145	8.591E-08	6.738E-08	6.008E-08	4.987E-08	4.221E-08	2.037E-08	1.300E-08	6.883E-09
SSE	89	4.094E-08	3.852E-08	3.133E-08	2.610E-08	2.215E-08	1.186E-08	7.620E-09	4.068E-09
S	91	4.724E-08	3.732E-08	3.045E-08	2.544E-08	2.163E-08	1.168E-08	7.568E-09	4.113E-09
SSW	105	5.672E-08	4.478E-08	3.653E-08	3.055E-08	2.604E-08	1.413E-08	9.170E-09	4.977E-09
SW	82	3.210E-08	2.510E-08	2.031E-08	1.686E-08	1.427E-08	7.585E-09	4.838E-09	2.551E-09
WSW	80	3.283E-08	2.574E-08	2.298E-08	1.913E-08	1.623E-08	7.914E-09	5.138E-09	2.786E-09
W	19	1.406E-08	1.104E-08	8.968E-09	7.460E-09	6.327E-09	3.384E-09	2.169E-09	1.153E-09
WNW	27	2.427E-08	1.918E-08	1.422E-08	1.185E-08	1.006E-08	5.392E-09	3.481E-09	1.882E-09
NW	37	2.724E-08	2.140E-08	1.737E-08	1.443E-08	1.223E-08	6.514E-09	4.172E-09	2.220E-09
NNW	71	6.090E-08	4.784E-08	3.883E-08	3.226E-08	2.734E-08	1.458E-08	9.337E-09	4.964E-09
AVERAGE	2074	8.542E-08	6.720E-08	5.500E-08	4.577E-08	3.883E-08	2.060E-08	1.324E-08	7.093E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	104	5.335E-09	3.784E-09	2.874E-09	2.279E-09	1.853E-09	1.551E-09	1.319E-09	
NNE	177	6.985E-09	4.943E-09	3.745E-09	2.964E-09	2.405E-09	2.010E-09	1.707E-09	
NE	186	9.330E-09	6.628E-09	5.039E-09	3.998E-09	3.252E-09	2.720E-09	2.313E-09	
ENE	250	1.070E-08	7.542E-09	5.697E-09	4.497E-09	3.641E-09	3.037E-09	2.575E-09	
E	376	9.880E-09	6.924E-09	5.204E-09	4.093E-09	3.306E-09	2.754E-09	2.333E-09	
ESE	235	7.322E-09	5.160E-09	3.895E-09	3.074E-09	2.490E-09	2.078E-09	1.763E-09	
SE	145	4.358E-09	3.066E-09	2.312E-09	1.823E-09	1.476E-09	1.232E-09	1.046E-09	
SSE	89	2.592E-09	1.833E-09	1.387E-09	1.097E-09	8.909E-10	7.454E-10	6.340E-10	
S	91	2.651E-09	1.891E-09	1.440E-09	1.146E-09	9.349E-10	7.855E-10	6.707E-10	
SSW	105	3.198E-09	2.275E-09	1.731E-09	1.375E-09	1.120E-09	9.379E-10	7.986E-10	
SW	82	1.614E-09	1.135E-09	8.558E-10	6.747E-10	5.460E-10	4.552E-10	3.860E-10	
WSW	80	1.792E-09	1.275E-09	9.704E-10	7.705E-10	6.272E-10	5.248E-10	4.466E-10	
W	19	7.305E-10	5.142E-10	3.880E-10	3.059E-10	2.475E-10	2.063E-10	1.749E-10	
WNW	27	1.202E-09	8.514E-10	6.452E-10	5.107E-10	4.146E-10	3.469E-10	2.949E-10	
NW	37	1.409E-09	9.924E-10	7.491E-10	5.911E-10	4.787E-10	3.996E-10	3.390E-10	
NNW	71	3.142E-09	2.209E-09	1.665E-09	1.312E-09	1.060E-09	8.830E-10	7.476E-10	
AVERAGE	2074	4.515E-09	3.189E-09	2.412E-09	1.907E-09	1.546E-09	1.292E-09	1.097E-09	

Table B-2

Depleted X/Q Factors for Reactor Building Vent

BECo 2nd Quarter 1994 General Ground Level X/Q's
 GROUND RELEASE: GROUND-LEVEL AVERAGE CHI/Q AFTER DEPLETION (REGULATORY GUIDE 1.111 DEPLETION MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	317	2.669E-05	7.999E-06	2.639E-06	1.378E-06	8.711E-07	4.528E-07	2.842E-07	1.988E-07
NNE	476	4.541E-05	1.364E-05	4.519E-06	2.396E-06	1.526E-06	7.962E-07	4.992E-07	3.489E-07
NE	256	4.036E-05	1.175E-05	3.600E-06	1.896E-06	1.213E-06	6.587E-07	4.248E-07	3.030E-07
ENE	171	3.078E-05	8.973E-06	2.852E-06	1.528E-06	9.838E-07	5.262E-07	3.351E-07	2.371E-07
E	184	3.106E-05	9.063E-06	2.902E-06	1.555E-06	1.002E-06	5.336E-07	3.382E-07	2.365E-07
ESE	119	1.627E-05	4.814E-06	1.596E-06	8.474E-07	5.407E-07	2.833E-07	1.783E-07	1.250E-07
SE	79	1.366E-05	4.048E-06	1.488E-06	7.850E-07	4.985E-07	2.599E-07	1.483E-07	1.038E-07
SSE	74	1.140E-05	3.394E-06	1.116E-06	5.385E-07	3.441E-07	1.796E-07	1.126E-07	7.877E-08
S	78	1.082E-05	3.212E-06	8.472E-07	4.331E-07	2.712E-07	1.423E-07	9.062E-08	6.412E-08
SSW	94	6.305E-06	1.876E-06	5.290E-07	2.664E-07	1.663E-07	8.611E-08	5.444E-08	3.838E-08
SW	64	4.793E-06	1.480E-06	4.151E-07	2.093E-07	1.309E-07	6.696E-08	4.171E-08	2.904E-08
WSW	39	4.827E-06	1.430E-06	4.357E-07	2.282E-07	1.442E-07	7.433E-08	4.641E-08	3.240E-08
W	25	3.908E-06	1.204E-06	3.601E-07	2.073E-07	1.308E-07	6.803E-08	3.872E-08	2.698E-08
WNW	56	5.607E-06	1.715E-06	5.481E-07	2.867E-07	1.822E-07	9.463E-08	6.515E-08	4.546E-08
NW	58	7.813E-06	2.325E-06	7.714E-07	4.062E-07	2.580E-07	1.336E-07	8.338E-08	5.814E-08
NNW	77	1.117E-05	3.317E-06	1.122E-06	5.955E-07	3.790E-07	1.966E-07	1.227E-07	8.561E-08
AVERAGE	2167	1.693E-05	5.015E-06	1.609E-06	8.473E-07	5.401E-07	2.846E-07	1.790E-07	1.259E-07

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	317	1.492E-07	1.171E-07	9.507E-08	7.909E-08	6.706E-08	3.582E-08	2.299E-08	1.229E-08
NNE	476	2.618E-07	2.055E-07	1.667E-07	1.386E-07	1.175E-07	6.279E-08	4.026E-08	2.144E-08
NE	256	2.308E-07	1.834E-07	1.503E-07	1.263E-07	1.081E-07	5.942E-08	3.894E-08	2.147E-08
ENE	171	1.799E-07	1.425E-07	1.164E-07	9.745E-08	8.312E-08	4.525E-08	2.946E-08	1.607E-08
E	184	1.807E-07	1.428E-07	1.166E-07	9.746E-08	8.302E-08	4.503E-08	2.926E-08	1.592E-08
ESE	119	9.417E-08	7.411E-08	6.025E-08	5.017E-08	4.259E-08	2.283E-08	1.469E-08	7.871E-09
SE	79	7.809E-08	6.138E-08	5.482E-08	4.559E-08	3.866E-08	2.064E-08	1.326E-08	7.108E-09
SSE	74	5.923E-08	4.657E-08	3.784E-08	3.149E-08	2.672E-08	1.432E-08	9.214E-09	4.935E-09
S	78	4.851E-08	3.835E-08	3.131E-08	2.620E-08	2.233E-08	1.212E-08	7.873E-09	4.295E-09
SSW	94	2.901E-08	2.293E-08	1.873E-08	1.568E-08	1.336E-08	7.257E-09	4.729E-09	2.594E-09
SW	64	2.168E-08	1.698E-08	1.378E-08	1.149E-08	9.748E-09	5.247E-09	3.366E-09	1.823E-09
WSW	39	2.435E-08	1.913E-08	1.707E-08	1.418E-08	1.201E-08	5.809E-09	3.735E-09	2.009E-09
W	25	2.012E-08	1.572E-08	1.271E-08	1.055E-08	8.935E-09	4.753E-09	3.035E-09	1.606E-09
WNW	56	3.402E-08	2.669E-08	1.968E-08	1.639E-08	1.391E-08	7.469E-09	4.797E-09	2.553E-09
NW	58	4.364E-08	3.425E-08	2.778E-08	2.307E-08	1.954E-08	1.041E-08	6.696E-09	3.598E-09
NNW	77	6.426E-08	5.042E-08	4.087E-08	3.392E-08	2.872E-08	1.527E-08	9.784E-09	5.223E-09
AVERAGE	2167	9.496E-08	7.486E-08	6.125E-08	5.111E-08	4.346E-08	2.340E-08	1.513E-08	8.176E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	317	7.829E-09	5.535E-09	4.191E-09	3.316E-09	2.692E-09	2.251E-09	1.914E-09	
NNE	476	1.361E-08	9.586E-09	7.239E-09	5.712E-09	4.625E-09	3.856E-09	3.269E-09	
NE	256	1.387E-08	9.905E-09	7.564E-09	6.022E-09	4.911E-09	4.113E-09	3.502E-09	
ENE	171	1.032E-08	7.327E-09	5.571E-09	4.418E-09	3.590E-09	2.999E-09	2.547E-09	
E	184	1.021E-08	7.251E-09	5.510E-09	4.368E-09	3.549E-09	2.966E-09	2.519E-09	
ESE	119	5.011E-09	3.539E-09	2.677E-09	2.116E-09	1.716E-09	1.432E-09	1.216E-09	
SE	79	4.527E-09	3.199E-09	2.421E-09	1.914E-09	1.553E-09	1.298E-09	1.103E-09	
SSE	74	3.144E-09	2.221E-09	1.681E-09	1.328E-09	1.077E-09	8.991E-10	7.632E-10	
S	78	2.769E-09	1.976E-09	1.507E-09	1.200E-09	9.793E-10	8.223E-10	7.019E-10	
SSW	94	1.684E-09	1.208E-09	9.244E-10	7.383E-10	6.047E-10	5.095E-10	4.362E-10	
SW	64	1.175E-09	8.387E-10	6.392E-10	5.089E-10	4.156E-10	3.492E-10	2.984E-10	
WSW	39	1.283E-09	9.091E-10	6.890E-10	5.456E-10	4.434E-10	3.713E-10	3.159E-10	
W	25	1.016E-09	7.148E-10	5.394E-10	4.253E-10	3.442E-10	2.867E-10	2.430E-10	
WNW	56	1.625E-09	1.148E-09	8.684E-10	6.864E-10	5.566E-10	4.644E-10	3.943E-10	
NW	58	2.298E-09	1.627E-09	1.233E-09	9.757E-10	7.924E-10	6.620E-10	5.635E-10	
NNW	77	3.318E-09	2.339E-09	1.767E-09	1.395E-09	1.130E-09	9.433E-10	8.003E-10	
AVERAGE	2167	5.230E-09	3.708E-09	2.814E-09	2.229E-09	1.811E-09	1.514E-09	1.287E-09	

Table B-2

Depleted X/Q Factors for Reactor Building Vent

BECs 3rd Quarter 1994 General Ground Level X/Q's

SECTOR AVERAGE MODEL

GROUND RELEASE: GROUND-LEVEL AVERAGE CHI/Q AFTER DEPLETION (REGULATORY GUIDE 1.111 DEPLETION MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	185	2.863E-05	8.641E-06	2.853E-06	1.524E-06	9.746E-07	5.087E-07	3.186E-07	2.224E-07
NNE	519	6.699E-05	2.015E-05	6.733E-06	3.572E-06	2.272E-06	1.186E-06	7.446E-07	5.207E-07
NE	434	8.536E-05	2.504E-05	7.658E-06	4.010E-06	2.553E-06	1.385E-06	8.933E-07	6.372E-07
ENE	201	4.369E-05	1.270E-05	3.981E-06	2.096E-06	1.337E-06	7.212E-07	4.633E-07	3.297E-07
E	134	3.010E-05	8.922E-06	2.929E-06	1.562E-06	9.989E-07	5.282E-07	3.340E-07	2.349E-07
ESE	91	1.878E-05	5.619E-06	1.837E-06	9.696E-07	6.168E-07	3.237E-07	2.040E-07	1.431E-07
SE	74	1.406E-05	4.235E-06	1.583E-06	8.403E-07	5.342E-07	2.765E-07	1.569E-07	1.093E-07
SSE	71	1.395E-05	4.211E-06	1.423E-06	6.870E-07	4.372E-07	2.267E-07	1.416E-07	9.873E-08
S	113	1.833E-05	5.521E-06	1.554E-06	8.192E-07	5.202E-07	2.688E-07	1.677E-07	1.167E-07
SSW	106	1.203E-05	3.681E-06	1.114E-06	5.772E-07	3.631E-07	1.867E-07	1.167E-07	8.126E-08
SW	64	9.355E-06	2.900E-06	8.846E-07	4.577E-07	2.865E-07	1.466E-07	9.094E-08	6.297E-08
WSW	43	7.625E-06	2.382E-06	7.574E-07	3.973E-07	2.495E-07	1.268E-07	7.838E-08	5.408E-08
W	25	4.381E-06	1.364E-06	4.397E-07	2.558E-07	1.614E-07	8.234E-08	4.629E-08	3.194E-08
WNW	38	6.504E-06	1.938E-06	6.924E-07	3.893E-07	2.341E-07	1.205E-07	8.242E-08	5.727E-08
NW	32	8.103E-06	2.385E-06	8.326E-07	4.464E-07	2.847E-07	1.478E-07	9.245E-08	6.455E-08
NNW	36	1.097E-05	3.251E-06	1.058E-06	5.763E-07	3.736E-07	1.982E-07	1.249E-07	8.768E-08
AVERAGE	2166	2.368E-05	7.058E-06	2.271E-06	1.198E-06	7.623E-07	4.021E-07	2.535E-07	1.783E-07
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	185	1.668E-07	1.309E-07	1.062E-07	8.826E-08	7.485E-08	4.004E-08	2.568E-08	1.366E-08
NNE	519	3.906E-07	3.065E-07	2.485E-07	2.066E-07	1.751E-07	9.346E-08	5.985E-08	3.179E-08
NE	434	4.846E-07	3.847E-07	3.153E-07	2.649E-07	2.267E-07	1.245E-07	8.153E-08	4.493E-08
ENE	201	2.506E-07	1.988E-07	1.628E-07	1.365E-07	1.166E-07	6.370E-08	4.162E-08	2.268E-08
E	134	1.771E-07	1.395E-07	1.135E-07	9.465E-08	8.046E-08	4.331E-08	2.792E-08	1.499E-08
ESE	91	1.076E-07	8.461E-08	6.877E-08	5.729E-08	4.866E-08	2.612E-08	1.682E-08	9.015E-09
SE	74	8.182E-08	6.407E-08	5.705E-08	4.732E-08	4.004E-08	2.124E-08	1.354E-08	7.150E-09
SSE	71	7.392E-08	5.790E-08	4.689E-08	3.892E-08	3.295E-08	1.751E-08	1.117E-08	5.887E-09
S	113	8.727E-08	6.831E-08	5.530E-08	4.587E-08	3.880E-08	2.057E-08	1.311E-08	6.912E-09
SSW	106	6.065E-08	4.743E-08	3.839E-08	3.187E-08	2.697E-08	1.432E-08	9.111E-09	4.784E-09
SW	64	4.675E-08	3.639E-08	2.933E-08	2.426E-08	2.047E-08	1.077E-08	6.828E-09	3.579E-09
WSW	43	4.004E-08	3.107E-08	2.747E-08	2.264E-08	1.906E-08	9.028E-09	5.658E-09	2.898E-09
W	25	2.364E-08	1.835E-08	1.474E-08	1.214E-08	1.022E-08	5.313E-09	3.220E-09	1.690E-09
WNW	38	4.281E-08	3.345E-08	2.456E-08	2.029E-08	1.712E-08	8.970E-09	5.675E-09	2.967E-09
NW	32	4.851E-08	3.807E-08	3.086E-08	2.559E-08	2.165E-08	1.147E-08	7.317E-09	3.876E-09
NNW	36	6.612E-08	5.210E-08	4.241E-08	3.536E-08	3.007E-08	1.623E-08	1.047E-08	5.611E-09
AVERAGE	2166	1.343E-07	1.058E-07	8.638E-08	7.202E-08	6.123E-08	3.291E-08	2.123E-08	1.141E-08
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	185	8.653E-09	6.067E-09	4.592E-09	3.619E-09	2.925E-09	2.434E-09	2.060E-09	
NNE	519	2.013E-08	1.416E-08	1.068E-08	8.418E-09	6.808E-09	5.671E-09	4.804E-09	
NE	434	2.902E-08	2.072E-08	1.583E-08	1.260E-08	1.028E-08	8.607E-09	7.330E-09	
ENE	201	1.475E-08	1.052E-08	8.026E-09	6.385E-09	5.205E-09	4.360E-09	3.712E-09	
E	134	9.541E-09	6.737E-09	5.098E-09	4.028E-09	3.265E-09	2.722E-09	2.308E-09	
ESE	91	5.742E-09	4.058E-09	3.072E-09	2.429E-09	1.970E-09	1.645E-09	1.396E-09	
SE	74	4.513E-09	3.167E-09	2.384E-09	1.876E-09	1.515E-09	1.262E-09	1.068E-09	
SSE	71	3.714E-09	2.605E-09	1.960E-09	1.542E-09	1.245E-09	1.036E-09	8.770E-10	
S	113	4.369E-09	3.070E-09	2.313E-09	1.822E-09	1.474E-09	1.230E-09	1.043E-09	
SSW	106	3.023E-09	2.124E-09	1.601E-09	1.262E-09	1.022E-09	8.531E-10	7.244E-10	
SW	64	2.259E-09	1.586E-09	1.194E-09	9.411E-10	7.616E-10	6.354E-10	5.393E-10	
WSW	43	1.799E-09	1.248E-09	9.300E-10	7.264E-10	5.832E-10	4.835E-10	4.080E-10	
W	25	1.045E-09	7.215E-10	5.362E-10	4.177E-10	3.345E-10	2.768E-10	2.331E-10	
WNW	38	1.859E-09	1.298E-09	9.725E-10	7.628E-10	6.146E-10	5.114E-10	4.325E-10	
NW	32	2.446E-09	1.716E-09	1.292E-09	1.016E-09	8.208E-10	6.838E-10	5.789E-10	
NNW	36	3.569E-09	2.516E-09	1.901E-09	1.499E-09	1.212E-09	1.008E-09	8.523E-10	
AVERAGE	2166	7.277E-09	5.146E-09	3.898E-09	3.084E-09	2.502E-09	2.089E-09	1.773E-09	

Table B-2

Depleted X/Q Factors for Reactor Building Vent

BECo 4th Quarter 1994 General Ground Level X/Q's
 GROUND RELEASE: GROUND-LEVEL AVERAGE CHI/Q AFTER DEPLETION (REGULATORY GUIDE 1.111 DEPLETION MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	117	2.047E-05	6.043E-06	1.998E-06	1.077E-06	6.928E-07	3.657E-07	2.303E-07	1.616E-07
NNE	263	3.258E-05	9.527E-06	3.183E-06	1.718E-06	1.105E-06	5.926E-07	3.668E-07	2.575E-07
NE	319	5.926E-05	1.726E-05	5.308E-06	2.839E-06	1.830E-06	9.930E-07	6.378E-07	4.538E-07
ENE	234	4.839E-05	1.400E-05	4.445E-06	2.378E-06	1.530E-06	8.240E-07	5.270E-07	3.739E-07
E	283	4.046E-05	1.195E-05	3.998E-06	2.144E-06	1.373E-06	7.207E-07	4.530E-07	3.174E-07
ESE	188	2.349E-05	7.006E-06	2.359E-06	1.260E-06	8.052E-07	4.195E-07	2.626E-07	1.834E-07
SE	164	1.793E-05	5.382E-06	1.810E-06	9.607E-07	6.123E-07	3.179E-07	1.985E-07	1.383E-07
SSE	104	1.002E-05	2.999E-06	1.024E-06	5.387E-07	3.411E-07	1.756E-07	1.096E-07	7.633E-08
S	76	1.051E-05	3.086E-06	9.602E-07	5.074E-07	3.221E-07	1.667E-07	1.043E-07	7.294E-08
SSW	145	1.646E-05	5.009E-06	1.531E-06	8.040E-07	5.092E-07	2.622E-07	1.630E-07	1.132E-07
SW	106	8.850E-06	2.799E-06	8.728E-07	4.533E-07	2.833E-07	1.434E-07	8.848E-08	6.097E-08
WSW	34	3.819E-06	1.173E-06	3.741E-07	1.972E-07	1.242E-07	6.341E-08	3.923E-08	2.712E-08
W	13	1.486E-06	4.412E-07	1.409E-07	8.177E-08	5.150E-08	2.636E-08	1.492E-08	1.039E-08
WNW	34	3.009E-06	9.769E-07	3.420E-07	1.785E-07	1.115E-07	5.619E-08	3.797E-08	2.602E-08
NW	52	1.011E-05	2.980E-06	1.035E-06	5.574E-07	3.566E-07	1.858E-07	1.162E-07	8.113E-08
NNW	71	1.214E-05	3.617E-06	1.259E-06	6.748E-07	4.301E-07	2.230E-07	1.392E-07	9.695E-08
AVERAGE	2203	1.994E-05	5.890E-06	1.915E-06	1.023E-06	6.549E-07	3.454E-07	2.181E-07	1.532E-07

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	117	1.218E-07	9.588E-08	7.797E-08	6.494E-08	5.516E-08	2.963E-08	1.910E-08	1.026E-08
NNE	263	1.943E-07	1.532E-07	1.246E-07	1.038E-07	8.811E-08	4.728E-08	3.049E-08	1.639E-08
NE	319	3.454E-07	2.742E-07	2.247E-07	1.887E-07	1.614E-07	8.861E-08	5.803E-08	3.192E-08
ENE	234	2.842E-07	2.253E-07	1.843E-07	1.544E-07	1.317E-07	7.180E-08	4.683E-08	2.565E-08
E	283	2.390E-07	1.881E-07	1.528E-07	1.271E-07	1.079E-07	5.775E-08	3.715E-08	1.990E-08
ESE	188	1.377E-07	1.081E-07	8.767E-08	7.283E-08	6.171E-08	3.289E-08	2.107E-08	1.120E-08
SE	164	1.036E-07	8.118E-08	7.234E-08	6.005E-08	5.083E-08	2.456E-08	1.569E-08	8.310E-09
SSE	104	5.715E-08	4.476E-08	3.624E-08	3.005E-08	2.541E-08	1.345E-08	8.572E-09	4.532E-09
S	76	5.488E-08	4.314E-08	3.501E-08	2.908E-08	2.462E-08	1.309E-08	8.382E-09	4.473E-09
SSW	145	8.438E-08	6.590E-08	5.325E-08	4.413E-08	3.729E-08	1.972E-08	1.254E-08	6.602E-09
SW	106	4.504E-08	3.491E-08	2.804E-08	2.312E-08	1.946E-08	1.015E-08	6.366E-09	3.262E-09
WSW	34	2.014E-08	1.567E-08	1.387E-08	1.144E-08	9.637E-09	4.572E-09	2.879E-09	1.490E-09
W	13	7.788E-09	6.100E-09	4.935E-09	4.083E-09	3.448E-09	1.815E-09	1.156E-09	6.132E-10
WNW	34	1.908E-08	1.470E-08	1.068E-08	8.769E-09	7.359E-09	3.797E-09	2.348E-09	1.169E-09
NW	52	6.095E-08	4.783E-08	3.877E-08	3.215E-08	2.721E-08	1.443E-08	9.213E-09	4.884E-09
NNW	71	7.264E-08	5.689E-08	4.604E-08	3.814E-08	3.224E-08	1.704E-08	1.085E-08	5.714E-09
AVERAGE	2203	1.155E-07	9.099E-08	7.445E-08	6.204E-08	5.272E-08	2.816E-08	1.817E-08	9.773E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	117	6.522E-09	4.601E-09	3.479E-09	2.746E-09	2.223E-09	1.852E-09	1.569E-09	
NNE	263	1.043E-08	7.364E-09	5.569E-09	4.398E-09	3.561E-09	2.969E-09	2.516E-09	
NE	319	2.057E-08	1.466E-08	1.118E-08	8.883E-09	7.231E-09	6.045E-09	5.137E-09	
ENE	234	1.649E-08	1.173E-08	8.930E-09	7.090E-09	5.768E-09	4.823E-09	4.100E-09	
E	283	1.265E-08	8.917E-09	6.738E-09	5.318E-09	4.306E-09	3.589E-09	3.041E-09	
ESE	188	7.091E-09	4.987E-09	3.760E-09	2.963E-09	2.396E-09	1.996E-09	1.690E-09	
SE	164	5.259E-09	3.698E-09	2.788E-09	2.197E-09	1.777E-09	1.481E-09	1.255E-09	
SSE	104	2.867E-09	2.016E-09	1.520E-09	1.198E-09	9.698E-10	8.095E-10	6.870E-10	
S	76	2.842E-09	2.005E-09	1.515E-09	1.196E-09	9.699E-10	8.108E-10	6.889E-10	
SSW	145	4.171E-09	2.930E-09	2.207E-09	1.739E-09	1.406E-09	1.173E-09	9.946E-10	
SW	106	2.030E-09	1.410E-09	1.053E-09	8.236E-10	6.622E-10	5.497E-10	4.644E-10	
WSW	34	9.308E-10	6.481E-10	4.847E-10	3.797E-10	3.056E-10	2.539E-10	2.146E-10	
W	13	3.877E-10	2.725E-10	2.052E-10	1.617E-10	1.308E-10	1.092E-10	9.263E-11	
WNW	34	7.142E-10	4.891E-10	3.610E-10	2.795E-10	2.227E-10	1.835E-10	1.539E-10	
NW	52	3.083E-09	2.163E-09	1.628E-09	1.280E-09	1.034E-09	8.606E-10	7.281E-10	
NNW	71	3.596E-09	2.518E-09	1.891E-09	1.486E-09	1.199E-09	9.970E-10	8.431E-10	
AVERAGE	2203	6.228E-09	4.401E-09	3.332E-09	2.634E-09	2.135E-09	1.781E-09	1.511E-09	

Table B-2

Depleted X/Q Factors for Reactor Building Vent

BECo 1994 General Ground Level X/Q's
 GROUND RELEASE: GROUND-LEVEL AVERAGE CHI/Q AFTER DEPLETION (REGULATORY GUIDE 1.111 DEPLETION MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	723	2.313E-05	6.888E-06	2.276E-06	1.207E-06	7.697E-07	4.035E-07	2.539E-07	1.780E-07
NNE	1435	4.192E-05	1.248E-05	4.159E-06	2.215E-06	1.414E-06	7.404E-07	4.652E-07	3.257E-07
NE	1195	5.367E-05	1.568E-05	4.835E-06	2.554E-06	1.634E-06	8.848E-07	5.690E-07	4.051E-07
ENE	856	3.946E-05	1.149E-05	3.685E-06	1.962E-06	1.258E-06	6.726E-07	4.286E-07	3.034E-07
E	977	3.418E-05	1.013E-05	3.368E-06	1.797E-06	1.148E-06	6.023E-07	3.788E-07	2.655E-07
ESE	633	2.071E-05	6.160E-06	2.054E-06	1.091E-06	6.959E-07	3.634E-07	2.281E-07	1.596E-07
SE	462	1.516E-05	4.534E-06	1.530E-06	8.102E-07	5.152E-07	2.673E-07	1.671E-07	1.166E-07
SSE	338	1.046E-05	3.126E-06	1.047E-06	5.536E-07	3.523E-07	1.828E-07	1.144E-07	7.986E-08
S	358	1.174E-05	3.484E-06	1.049E-06	5.479E-07	3.469E-07	1.801E-07	1.131E-07	7.921E-08
SSW	450	1.153E-05	3.485E-06	1.035E-06	5.380E-07	3.398E-07	1.782E-07	1.104E-07	7.715E-08
SW	316	7.346E-06	2.284E-06	6.901E-07	3.570E-07	2.239E-07	1.143E-07	7.092E-08	4.911E-08
WSW	196	5.734E-06	1.753E-06	5.365E-07	2.814E-07	1.776E-07	9.115E-08	5.660E-08	3.926E-08
W	82	3.109E-06	9.512E-07	2.955E-07	1.715E-07	1.084E-07	5.588E-08	3.165E-08	2.199E-08
WNW	155	4.716E-06	1.425E-06	4.868E-07	2.575E-07	1.634E-07	8.431E-08	5.781E-08	4.022E-08
NW	179	7.725E-06	2.283E-06	7.817E-07	4.173E-07	2.662E-07	1.383E-07	8.647E-08	6.036E-08
NNW	255	2.115E-05	3.311E-06	1.119E-06	6.008E-07	3.847E-07	2.009E-07	1.256E-07	8.792E-08
AVERAGE	8610	2.155E-05	5.592E-06	1.809E-06	9.601E-07	6.124E-07	3.224E-07	2.036E-07	1.431E-07
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	723	1.339E-07	1.053E-07	8.553E-08	7.120E-08	6.044E-08	3.239E-08	2.083E-08	1.116E-08
NNE	1435	2.449E-07	1.924E-07	1.563E-07	1.300E-07	1.103E-07	5.898E-08	3.788E-08	2.022E-08
NE	1195	3.081E-07	2.445E-07	2.003E-07	1.682E-07	1.438E-07	7.886E-08	5.160E-08	2.838E-08
ENE	856	2.300E-07	1.821E-07	1.487E-07	1.244E-07	1.061E-07	5.760E-08	3.745E-08	2.042E-08
E	977	1.999E-07	1.572E-07	1.277E-07	1.063E-07	9.023E-08	4.833E-08	3.109E-08	1.665E-08
ESE	633	1.200E-07	9.431E-08	7.658E-08	6.370E-08	5.403E-08	2.888E-08	1.854E-08	9.894E-09
SE	462	8.744E-08	6.857E-08	6.113E-08	5.076E-08	4.297E-08	2.077E-08	1.328E-08	7.046E-09
SSE	338	5.992E-08	4.702E-08	3.814E-08	3.169E-08	2.685E-08	1.431E-08	9.157E-09	4.863E-09
S	358	5.959E-08	4.686E-08	3.809E-08	3.170E-08	2.689E-08	1.438E-08	9.246E-09	4.955E-09
SSW	450	5.781E-08	4.535E-08	3.680E-08	3.062E-08	2.596E-08	1.388E-08	8.901E-09	4.744E-09
SW	316	3.647E-08	2.843E-08	2.293E-08	1.897E-08	1.602E-08	8.454E-09	5.364E-09	2.808E-09
WSW	196	2.926E-08	2.284E-08	2.029E-08	1.680E-08	1.419E-08	6.814E-09	4.338E-09	2.287E-09
W	82	1.639E-08	1.279E-08	1.033E-08	8.552E-09	7.225E-09	3.812E-09	2.417E-09	1.264E-09
WNW	155	3.006E-08	2.351E-08	1.729E-08	1.433E-08	1.211E-08	6.406E-09	4.074E-09	2.141E-09
NW	179	4.534E-08	3.559E-08	2.886E-08	2.395E-08	2.027E-08	1.076E-08	6.888E-09	3.665E-09
NNW	255	6.606E-08	5.188E-08	4.209E-08	3.496E-08	2.963E-08	1.580E-08	1.012E-08	5.385E-09
AVERAGE	8610	1.078E-07	8.491E-08	6.944E-08	5.788E-08	4.919E-08	2.628E-08	1.695E-08	9.118E-09
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	723	7.101E-09	5.013E-09	3.792E-09	2.996E-09	2.429E-09	2.027E-09	1.719E-09	
NNE	1435	1.284E-08	9.049E-09	6.835E-09	5.394E-09	4.367E-09	3.641E-09	3.086E-09	
NE	1195	1.830E-08	1.305E-08	9.959E-09	7.921E-09	6.455E-09	5.402E-09	4.597E-09	
ENE	856	1.310E-08	9.309E-09	7.079E-09	5.616E-09	4.566E-09	3.817E-09	3.244E-09	
E	977	1.059E-08	7.469E-09	5.647E-09	4.460E-09	3.612E-09	3.013E-09	2.555E-09	
ESE	633	6.284E-09	4.430E-09	3.347E-09	2.642E-09	2.140E-09	1.785E-09	1.514E-09	
SE	462	4.463E-09	3.141E-09	2.369E-09	1.868E-09	1.512E-09	1.261E-09	1.070E-09	
SSE	338	3.084E-09	2.172E-09	1.639E-09	1.293E-09	1.047E-09	8.737E-10	7.412E-10	
S	358	3.162E-09	2.238E-09	1.695E-09	1.342E-09	1.091E-09	9.130E-10	7.768E-10	
SSW	450	3.022E-09	2.136E-09	1.617E-09	1.279E-09	1.039E-09	8.688E-10	7.389E-10	
SW	316	1.772E-09	1.244E-09	9.369E-10	7.381E-10	5.971E-10	4.980E-10	4.226E-10	
WSW	196	1.446E-09	1.016E-09	7.652E-10	6.028E-10	4.876E-10	4.065E-10	3.446E-10	
W	82	7.937E-10	5.550E-10	4.166E-10	3.272E-10	2.639E-10	2.194E-10	1.856E-10	
WNW	155	1.349E-09	9.456E-10	7.110E-10	5.592E-10	4.516E-10	3.761E-10	3.185E-10	
NW	179	2.322E-09	1.634E-09	1.232E-09	9.713E-10	7.858E-10	6.553E-10	5.544E-10	
NNW	255	3.410E-09	2.398E-09	1.808E-09	1.424E-09	1.151E-09	9.587E-10	8.116E-10	
AVERAGE	8610	5.815E-09	4.113E-09	3.116E-09	2.465E-09	2.000E-09	1.670E-09	1.418E-09	

Table B-3

Gamma X/Q Factors for Reactor Building Vent

BRCo 1st Quarter 1994 General Ground Level X/Q's

GROUND RELEASE: AVERAGE GAMMA DILUTION FACTORS (MET. AND ATOMIC ENERGY 1966 FINITE CLOUD SECTOR AVERAGE MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	104	3.086E-06	1.317E-06	5.769E-07	3.528E-07	2.485E-07	1.507E-07	1.054E-07	7.998E-08
NNE	177	4.988E-06	2.066E-06	8.543E-07	5.060E-07	3.565E-07	2.152E-07	1.499E-07	1.134E-07
NE	186	5.757E-06	2.414E-06	1.008E-06	6.024E-07	4.251E-07	2.583E-07	1.808E-07	1.371E-07
ENE	250	7.592E-06	3.199E-06	1.363E-06	8.204E-07	5.769E-07	3.469E-07	2.411E-07	1.819E-07
E	376	8.646E-06	3.641E-06	1.543E-06	9.184E-07	6.404E-07	3.799E-07	2.616E-07	1.960E-07
ESE	235	5.984E-06	2.481E-06	1.021E-06	5.999E-07	4.204E-07	2.514E-07	1.741E-07	1.311E-07
SE	145	3.913E-06	1.610E-06	6.538E-07	3.797E-07	2.656E-07	1.585E-07	1.095E-07	8.230E-08
SSE	89	2.469E-06	9.919E-07	3.812E-07	2.136E-07	1.494E-07	8.925E-08	6.182E-08	4.654E-08
S	91	2.959E-06	1.169E-06	3.906E-07	2.112E-07	1.465E-07	8.669E-08	5.972E-08	4.491E-08
SSW	105	2.700E-06	1.106E-06	3.943E-07	2.252E-07	1.577E-07	9.475E-08	6.584E-08	4.966E-08
SW	82	1.682E-06	6.977E-07	2.555E-07	1.477E-07	1.029E-07	6.099E-08	4.194E-08	3.136E-08
WSW	80	1.716E-06	7.134E-07	2.576E-07	1.482E-07	1.029E-07	6.079E-08	4.159E-08	3.099E-08
W	19	6.398E-07	2.669E-07	1.003E-07	6.506E-08	4.552E-08	2.712E-08	1.711E-08	1.289E-08
WNW	27	8.729E-07	3.568E-07	1.465E-07	8.627E-08	6.087E-08	3.681E-08	2.826E-08	2.143E-08
NW	37	1.162E-06	4.810E-07	1.978E-07	1.161E-07	8.137E-08	4.868E-08	3.371E-08	2.538E-08
NNW	71	2.246E-06	9.519E-07	4.101E-07	2.485E-07	1.748E-07	1.050E-07	7.294E-08	5.501E-08
AVERAGE	2074	3.526E-06	1.466E-06	5.971E-07	3.526E-07	2.472E-07	1.482E-07	1.028E-07	7.749E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	104	6.386E-08	5.276E-08	4.470E-08	3.855E-08	3.379E-08	2.049E-08	1.438E-08	8.723E-09
NNE	177	9.034E-08	7.450E-08	6.303E-08	5.428E-08	4.752E-08	2.871E-08	2.009E-08	1.212E-08
NE	186	1.095E-07	9.042E-08	7.662E-08	6.613E-08	5.799E-08	3.527E-08	2.480E-08	1.505E-08
ENE	250	1.447E-07	1.191E-07	1.006E-07	8.653E-08	7.566E-08	4.554E-08	3.175E-08	1.901E-08
E	376	1.547E-07	1.266E-07	1.064E-07	9.112E-08	7.935E-08	4.707E-08	3.240E-08	1.900E-08
ESE	235	1.040E-07	8.542E-08	7.203E-08	6.186E-08	5.402E-08	3.237E-08	2.247E-08	1.336E-08
SE	145	6.514E-08	5.341E-08	4.946E-08	4.242E-08	3.699E-08	2.005E-08	1.386E-08	8.179E-09
SSE	89	3.689E-08	3.029E-08	2.554E-08	2.193E-08	1.915E-08	1.148E-08	7.959E-09	4.718E-09
S	91	3.562E-08	2.927E-08	2.468E-08	2.121E-08	1.852E-08	1.111E-08	7.730E-09	4.620E-09
SSW	105	3.942E-08	3.242E-08	2.737E-08	2.356E-08	2.062E-08	1.245E-08	8.691E-09	5.211E-09
SW	82	2.469E-08	2.016E-08	1.692E-08	1.449E-08	1.261E-08	7.479E-09	5.140E-09	3.000E-09
WSW	80	2.437E-08	1.989E-08	1.836E-08	1.572E-08	1.369E-08	7.384E-09	5.099E-09	3.018E-09
W	19	1.023E-08	8.409E-09	7.094E-09	6.098E-09	5.328E-09	3.201E-09	2.225E-09	1.322E-09
WNW	27	1.713E-08	1.416E-08	1.091E-08	9.407E-09	8.240E-09	4.990E-09	3.502E-09	2.125E-09
NW	37	2.013E-08	1.654E-08	1.394E-08	1.197E-08	1.045E-08	6.261E-09	4.345E-09	2.582E-09
NNW	71	4.372E-08	3.597E-08	3.037E-08	2.611E-08	2.282E-08	1.372E-08	9.551E-09	5.700E-09
AVERAGE	2074	6.152E-08	5.058E-08	4.300E-08	3.696E-08	3.230E-08	1.922E-08	1.337E-08	7.984E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	104	6.136E-09	4.685E-09	3.775E-09	3.150E-09	2.682E-09	2.335E-09	2.060E-09	
NNE	177	8.495E-09	6.468E-09	5.202E-09	4.332E-09	3.682E-09	3.201E-09	2.820E-09	
NE	186	1.060E-08	8.101E-09	6.534E-09	5.455E-09	4.646E-09	4.044E-09	3.568E-09	
ENE	250	1.327E-08	1.007E-08	8.077E-09	6.711E-09	5.692E-09	4.937E-09	4.344E-09	
E	376	1.310E-08	9.851E-09	7.849E-09	6.485E-09	5.474E-09	4.733E-09	4.149E-09	
ESE	235	9.286E-09	7.027E-09	5.624E-09	4.665E-09	3.950E-09	3.424E-09	3.009E-09	
SE	145	5.662E-09	4.271E-09	3.410E-09	2.822E-09	2.386E-09	2.066E-09	1.813E-09	
SSE	89	3.278E-09	2.480E-09	1.983E-09	1.644E-09	1.392E-09	1.206E-09	1.060E-09	
S	91	3.228E-09	2.453E-09	1.971E-09	1.641E-09	1.395E-09	1.213E-09	1.070E-09	
SSW	105	3.649E-09	2.777E-09	2.234E-09	1.862E-09	1.583E-09	1.376E-09	1.212E-09	
SW	82	2.065E-09	1.552E-09	1.236E-09	1.022E-09	8.622E-10	7.449E-10	6.526E-10	
WSW	80	2.098E-09	1.589E-09	1.279E-09	1.066E-09	9.062E-10	7.873E-10	6.936E-10	
W	19	9.194E-10	6.957E-10	5.565E-10	4.613E-10	3.904E-10	3.382E-10	2.969E-10	
WNW	27	1.494E-09	1.140E-09	9.172E-10	7.645E-10	6.503E-10	5.660E-10	4.992E-10	
NW	37	1.795E-09	1.358E-09	1.086E-09	9.010E-10	7.630E-10	6.613E-10	5.811E-10	
NNW	71	3.970E-09	3.008E-09	2.409E-09	1.998E-09	1.693E-09	1.467E-09	1.289E-09	
AVERAGE	2074	5.565E-09	4.220E-09	3.384E-09	2.811E-09	2.384E-09	2.069E-09	1.820E-09	

Table B-3

Gamma X/Q Factors for Reactor Building Vent

BECO 2nd Quarter 1994 General Ground Level X/Q's

GROUND RELEASE: AVERAGE GAMMA DILUTION FACTORS (MET. AND ATOMIC ENERGY 1968 FINITE CLOUD SECTOR AVERAGE MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	317	8.358E-06	3.428E-06	1.371E-06	7.923E-07	5.490E-07	3.233E-07	2.213E-07	1.649E-07
NNE	476	1.287E-05	5.401E-06	2.254E-06	1.340E-06	9.343E-07	5.539E-07	3.805E-07	2.842E-07
NE	256	8.546E-06	3.635E-06	1.528E-06	9.229E-07	6.497E-07	3.955E-07	2.774E-07	2.109E-07
ENE	171	7.090E-06	3.013E-06	1.281E-06	7.781E-07	5.474E-07	3.305E-07	2.303E-07	1.743E-07
E	184	7.762E-06	3.253E-06	1.354E-06	8.129E-07	5.719E-07	3.446E-07	2.393E-07	1.804E-07
ESE	119	4.591E-06	1.909E-06	7.890E-07	4.673E-07	3.264E-07	1.942E-07	1.339E-07	1.003E-07
SE	79	3.932E-06	1.637E-06	7.458E-07	4.406E-07	3.065E-07	1.814E-07	1.132E-07	8.458E-08
SSE	74	3.421E-06	1.411E-06	5.708E-07	3.037E-07	2.115E-07	1.253E-07	8.604E-08	6.430E-08
S	78	3.323E-06	1.348E-06	4.340E-07	2.444E-07	1.673E-07	9.777E-08	6.693E-08	5.616E-08
SSW	94	2.432E-06	9.509E-07	3.074E-07	1.637E-07	1.106E-07	6.356E-08	4.298E-08	3.115E-08
SW	64	2.000E-06	7.861E-07	2.537E-07	1.348E-07	9.153E-08	5.240E-08	3.517E-08	2.581E-08
WSW	39	1.544E-06	6.337E-07	2.319E-07	1.340E-07	9.220E-08	5.378E-08	3.659E-08	2.723E-08
W	25	1.043E-06	4.503E-07	1.765E-07	1.170E-07	8.124E-08	4.792E-08	2.979E-08	2.212E-08
WNW	56	1.858E-06	7.583E-07	2.946E-07	1.679E-07	1.161E-07	6.811E-08	5.111E-08	3.799E-08
NW	58	2.428E-06	1.001E-06	4.050E-07	2.357E-07	1.632E-07	9.587E-08	6.538E-08	4.862E-08
NNW	77	3.235E-06	1.355E-06	5.687E-07	3.383E-07	2.352E-07	1.388E-07	9.507E-08	7.090E-08
AVERAGE	2167	4.652E-06	1.936E-06	7.854E-07	4.621E-07	3.221E-07	1.917E-07	1.316E-07	9.867E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	317	1.295E-07	1.056E-07	8.846E-08	7.556E-08	6.566E-08	3.867E-08	2.651E-08	1.549E-08
NNE	476	2.238E-07	1.828E-07	1.533E-07	1.312E-07	1.141E-07	6.754E-08	4.646E-08	2.725E-08
NE	256	1.686E-07	1.395E-07	1.184E-07	1.024E-07	8.994E-08	5.503E-08	3.888E-08	2.381E-08
ENE	171	1.390E-07	1.147E-07	9.713E-08	8.376E-08	7.339E-08	4.453E-08	3.127E-08	1.897E-08
E	184	1.435E-07	1.181E-07	9.978E-08	8.587E-08	7.511E-08	4.529E-08	3.167E-08	1.910E-08
ESE	119	7.928E-08	6.493E-08	5.460E-08	4.678E-08	4.076E-08	2.424E-08	1.675E-08	9.909E-09
SE	79	6.670E-08	5.452E-08	5.035E-08	4.308E-08	3.748E-08	2.217E-08	1.527E-08	9.002E-09
SSE	74	5.069E-08	4.144E-08	3.480E-08	2.978E-08	2.592E-08	1.537E-08	1.060E-08	6.244E-09
S	78	3.964E-08	3.247E-08	2.732E-08	2.343E-08	2.044E-08	1.220E-08	8.454E-09	5.030E-09
SSW	94	2.511E-08	2.047E-08	1.715E-08	1.466E-08	1.275E-08	7.530E-09	5.180E-09	3.051E-09
SW	64	2.008E-08	1.621E-08	1.348E-08	1.145E-08	9.904E-09	5.745E-09	3.886E-09	2.219E-09
WSW	39	2.143E-08	1.748E-08	1.612E-08	1.377E-08	1.196E-08	6.394E-09	4.391E-09	2.581E-09
W	25	1.731E-08	1.406E-08	1.175E-08	1.002E-08	8.700E-09	5.105E-09	3.484E-09	2.017E-09
WNW	56	2.977E-08	2.422E-08	1.842E-08	1.572E-08	1.366E-08	8.050E-09	5.509E-09	3.197E-09
NW	58	3.821E-08	3.115E-08	2.609E-08	2.228E-08	1.935E-08	1.138E-08	7.811E-09	4.585E-09
NNW	77	5.585E-08	4.561E-08	3.825E-08	3.269E-08	2.842E-08	1.676E-08	1.152E-08	6.771E-09
AVERAGE	2167	7.803E-08	6.395E-08	5.409E-08	4.640E-08	4.047E-08	2.413E-08	1.673E-08	9.952E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	317	1.066E-08	8.018E-09	6.394E-09	5.289E-09	4.469E-09	3.867E-09	3.392E-09	
NNE	476	1.880E-08	1.415E-08	1.129E-08	9.338E-09	7.888E-09	6.821E-09	5.979E-09	
NE	256	1.685E-08	1.292E-08	1.046E-08	8.752E-09	7.469E-09	6.508E-09	5.748E-09	
ENE	171	1.334E-08	1.018E-08	8.206E-09	6.844E-09	5.822E-09	5.061E-09	4.459E-09	
E	184	1.338E-08	1.019E-08	8.201E-09	6.832E-09	5.807E-09	5.045E-09	4.443E-09	
ESE	119	6.866E-09	5.185E-09	4.145E-09	3.435E-09	2.907E-09	2.517E-09	2.210E-09	
SE	79	6.225E-09	4.694E-09	3.752E-09	3.108E-09	2.630E-09	2.278E-09	2.000E-09	
SSE	74	4.319E-09	3.257E-09	2.603E-09	2.156E-09	1.823E-09	1.578E-09	1.385E-09	
S	78	3.504E-09	2.659E-09	2.135E-09	1.776E-09	1.509E-09	1.311E-09	1.155E-09	
SSW	94	2.116E-09	1.601E-09	1.285E-09	1.068E-09	9.075E-10	7.888E-10	6.951E-10	
SW	64	1.514E-09	1.131E-09	9.006E-10	7.441E-10	6.283E-10	5.430E-10	4.761E-10	
WSW	39	1.782E-09	1.343E-09	1.073E-09	8.892E-10	7.527E-10	6.525E-10	5.733E-10	
W	25	1.382E-09	1.035E-09	8.241E-10	6.803E-10	5.738E-10	4.953E-10	4.336E-10	
WNW	56	2.196E-09	1.648E-09	1.312E-09	1.084E-09	9.145E-10	7.894E-10	6.913E-10	
NW	58	3.164E-09	2.383E-09	1.905E-09	1.579E-09	1.336E-09	1.158E-09	1.017E-09	
NNW	77	4.672E-09	3.518E-09	2.808E-09	2.324E-09	1.965E-09	1.701E-09	1.493E-09	
AVERAGE	2167	6.923E-09	5.245E-09	4.206E-09	3.494E-09	2.963E-09	2.570E-09	2.259E-09	

Table B-3

Gamma X/Q Factors for Reactor Building Vent

BECs 3rd Quarter 1994 General Ground Level X/Q's

GROUND RELEASE: AVERAGE GAMMA DILUTION FACTORS (MET. AND ATOMIC ENERGY 1966 FINITE CLOUD SECTOR AVERAGE MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	185	7.682E-06	3.279E-06	1.401E-06	8.448E-07	5.892E-07	3.493E-07	2.400E-07	1.794E-07
NNE	519	1.777E-05	7.586E-06	3.265E-06	1.972E-06	1.375E-06	8.162E-07	5.615E-07	4.199E-07
NE	434	1.759E-05	7.572E-06	3.227E-06	1.958E-06	1.374E-06	8.333E-07	5.833E-07	4.427E-07
ENE	201	9.430E-06	4.020E-06	1.714E-06	1.040E-06	7.310E-07	4.434E-07	3.100E-07	2.350E-07
E	134	7.313E-06	3.129E-06	1.354E-06	8.250E-07	5.793E-07	3.478E-07	2.411E-07	1.814E-07
ESE	91	5.129E-06	2.155E-06	8.974E-07	5.333E-07	3.717E-07	2.209E-07	1.521E-07	1.138E-07
SE	74	4.063E-06	1.714E-06	7.395E-07	4.779E-07	3.325E-07	1.962E-07	1.222E-07	9.113E-08
SSE	71	4.051E-06	1.705E-06	7.182E-07	3.894E-07	2.711E-07	1.602E-07	1.099E-07	8.202E-08
S	113	5.951E-06	2.441E-06	8.204E-07	4.771E-07	3.321E-07	1.960E-07	1.341E-07	9.977E-08
SSW	106	4.200E-06	1.706E-06	6.070E-07	3.450E-07	2.381E-07	1.572E-07	9.482E-08	7.037E-08
SW	64	3.036E-06	1.269E-06	4.736E-07	2.759E-07	1.900E-07	1.105E-07	7.488E-08	5.524E-08
WSW	43	2.364E-06	1.011E-06	3.969E-07	2.376E-07	1.641E-07	9.566E-08	6.495E-08	4.803E-08
W	25	1.313E-06	5.644E-07	2.254E-07	1.503E-07	1.046E-07	6.156E-08	3.819E-08	2.829E-08
WNW	38	1.840E-06	7.836E-07	3.455E-07	2.103E-07	1.468E-07	8.684E-08	6.552E-08	4.885E-08
NW	32	2.181E-06	9.269E-07	4.060E-07	2.472E-07	1.729E-07	1.028E-07	7.077E-08	5.302E-08
NNW	36	2.550E-06	1.102E-06	4.835E-07	2.994E-07	2.119E-07	1.281E-07	8.908E-08	6.712E-08
AVERAGE	2166	6.029E-06	2.560E-06	1.071E-06	6.427E-07	4.490E-07	2.680E-07	1.845E-07	1.385E-07

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	185	1.414E-07	1.156E-07	9.704E-08	8.307E-08	7.233E-08	4.294E-08	2.960E-08	1.741E-08
NNE	519	3.310E-07	2.705E-07	2.271E-07	1.943E-07	1.691E-07	1.002E-07	6.900E-08	4.051E-08
NE	434	3.534E-07	2.921E-07	2.477E-07	2.140E-07	1.879E-07	1.146E-07	8.098E-08	4.947E-08
ENE	201	1.875E-07	1.549E-07	1.312E-07	1.132E-07	9.930E-08	6.038E-08	4.249E-08	2.589E-08
E	134	1.437E-07	1.179E-07	9.938E-08	8.533E-08	7.449E-08	4.461E-08	3.098E-08	1.844E-08
ESE	91	8.979E-08	7.344E-08	6.171E-08	5.286E-08	4.605E-08	2.737E-08	1.890E-08	1.115E-08
SE	74	7.166E-08	5.847E-08	5.389E-08	4.603E-08	4.000E-08	2.356E-08	1.614E-08	9.410E-09
SSE	71	6.453E-08	5.265E-08	4.413E-08	3.771E-08	3.278E-08	1.934E-08	1.325E-08	7.723E-09
S	113	7.825E-08	6.367E-08	5.325E-08	4.541E-08	3.940E-08	2.309E-08	1.575E-08	9.110E-09
SSW	106	5.502E-08	4.466E-08	3.728E-08	3.175E-08	2.752E-08	1.607E-08	1.091E-08	6.246E-09
SW	64	4.298E-08	3.474E-08	2.890E-08	2.455E-08	2.122E-08	1.227E-08	8.278E-09	4.707E-09
WSW	43	3.743E-08	3.029E-08	2.773E-08	2.356E-08	2.036E-08	1.070E-08	7.208E-09	4.071E-09
W	25	2.207E-08	1.787E-08	1.488E-08	1.265E-08	1.094E-08	6.331E-09	4.265E-09	2.408E-09
WNW	38	3.843E-08	3.134E-08	2.385E-08	2.035E-08	1.766E-08	1.034E-08	7.057E-09	4.095E-09
NW	32	4.192E-08	3.432E-08	2.884E-08	2.468E-08	2.148E-08	1.271E-08	8.757E-09	5.157E-09
NNW	36	5.329E-08	4.382E-08	3.698E-08	3.180E-08	2.780E-08	1.673E-08	1.166E-08	6.978E-09
AVERAGE	2166	1.095E-07	8.976E-08	7.586E-08	6.508E-08	5.677E-08	3.384E-08	2.345E-08	1.392E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	185	1.202E-08	9.058E-09	7.230E-09	5.981E-09	5.052E-09	4.367E-09	3.827E-09	
NNE	519	2.795E-08	2.104E-08	1.678E-08	1.387E-08	1.172E-08	1.013E-08	8.876E-09	
NE	434	3.498E-08	2.682E-08	2.170E-08	1.816E-08	1.549E-08	1.350E-08	1.192E-08	
ENE	201	1.826E-08	1.398E-08	1.129E-08	9.442E-09	8.051E-09	7.013E-09	6.191E-09	
E	134	1.283E-08	9.715E-09	7.782E-09	6.458E-09	5.470E-09	4.740E-09	4.164E-09	
ESE	91	7.725E-09	5.832E-09	4.664E-09	3.865E-09	3.271E-09	2.832E-09	2.487E-09	
SE	74	6.463E-09	4.849E-09	3.857E-09	3.182E-09	2.682E-09	2.316E-09	2.027E-09	
SSE	71	5.304E-09	3.978E-09	3.163E-09	2.608E-09	2.198E-09	1.896E-09	1.659E-09	
S	113	6.233E-09	4.663E-09	3.702E-09	3.050E-09	2.569E-09	2.216E-09	1.939E-09	
SSW	106	4.252E-09	3.170E-09	2.509E-09	2.062E-09	1.733E-09	1.493E-09	1.304E-09	
SW	64	3.191E-09	2.372E-09	1.877E-09	1.543E-09	1.297E-09	1.117E-09	9.759E-10	
WSW	43	2.744E-09	2.029E-09	1.596E-09	1.305E-09	1.091E-09	9.353E-10	8.137E-10	
W	25	1.622E-09	1.198E-09	9.413E-10	7.684E-10	6.416E-10	5.497E-10	4.777E-10	
WNW	38	2.801E-09	2.095E-09	1.661E-09	1.367E-09	1.150E-09	9.921E-10	8.676E-10	
NW	32	3.559E-09	2.679E-09	2.134E-09	1.764E-09	1.489E-09	1.288E-09	1.129E-09	
NNW	36	4.865E-09	3.689E-09	2.958E-09	2.455E-09	2.080E-09	1.801E-09	1.581E-09	
AVERAGE	2166	9.675E-09	7.323E-09	5.865E-09	4.867E-09	4.124E-09	3.574E-09	3.140E-09	

Table B-3

Gamma X/Q Factors for Reactor Building Vent

RECo 4th Quarter 1994 General Ground Level X/Q's

GROUND RELEASE: AVERAGE GAMMA DILUTION FACTORS (MBT. AND ATOMIC ENERGY 1968 FINITE CLOUD SECTOR AVERAGE MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	117	4.893E-06	2.108E-06	9.253E-07	5.695E-07	4.009E-07	2.409E-07	1.669E-07	1.255E-07
NNE	263	7.957E-06	3.400E-06	1.486E-06	9.111E-07	6.410E-07	3.849E-07	2.667E-07	2.007E-07
NE	319	1.182E-05	5.123E-06	2.220E-06	1.370E-06	9.684E-07	5.913E-07	4.151E-07	3.157E-07
NNE	234	1.020E-05	4.380E-06	1.907E-06	1.175E-06	8.307E-07	5.061E-07	3.544E-07	2.688E-07
E	283	1.022E-05	4.367E-06	1.899E-06	1.158E-06	8.111E-07	4.843E-07	3.344E-07	2.510E-07
ESE	188	6.505E-06	2.746E-06	1.167E-06	7.013E-07	4.898E-07	2.908E-07	2.000E-07	1.496E-07
SE	164	5.390E-06	2.242E-06	9.259E-07	5.473E-07	3.819E-07	2.263E-07	1.552E-07	1.157E-07
SSE	104	3.225E-06	1.327E-06	5.399E-07	3.147E-07	2.182E-07	1.283E-07	8.765E-08	6.523E-08
S	76	3.301E-06	1.351E-06	4.993E-07	2.911E-07	2.021E-07	1.192E-07	8.167E-08	6.103E-08
SSW	145	5.386E-06	2.221E-06	8.168E-07	4.751E-07	3.298E-07	1.938E-07	1.321E-07	9.794E-08
SW	106	2.923E-06	1.238E-06	4.724E-07	2.778E-07	1.907E-07	1.102E-07	7.445E-08	5.487E-08
WSW	34	1.157E-06	4.933E-07	1.940E-07	1.165E-07	8.072E-08	4.727E-08	3.217E-08	2.382E-08
W	13	4.298E-07	1.826E-07	7.197E-08	4.744E-08	3.266E-08	1.903E-08	1.178E-08	8.778E-09
WNW	34	9.496E-07	4.135E-07	1.814E-07	1.092E-07	7.529E-08	4.367E-08	3.247E-08	2.387E-08
NW	52	2.600E-06	1.115E-06	4.957E-07	3.049E-07	2.140E-07	1.278E-07	8.815E-08	6.606E-08
NNW	71	3.237E-06	1.389E-06	6.140E-07	3.757E-07	2.628E-07	1.561E-07	1.074E-07	8.025E-08
AVERAGE	2203	5.012E-06	2.131E-06	9.009E-07	5.465E-07	3.831E-07	2.294E-07	1.588E-07	1.193E-07

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	117	9.947E-08	8.167E-08	6.883E-08	5.910E-08	5.159E-08	3.089E-08	2.147E-08	1.281E-08
NNE	263	1.593E-07	1.310E-07	1.105E-07	9.486E-08	8.282E-08	4.960E-08	3.451E-08	2.064E-08
NE	319	2.527E-07	2.092E-07	1.777E-07	1.538E-07	1.351E-07	8.283E-08	5.861E-08	3.595E-08
NNE	234	2.148E-07	1.755E-07	1.505E-07	1.299E-07	1.139E-07	6.930E-08	4.980E-08	2.975E-08
E	283	1.987E-07	1.630E-07	1.372E-07	1.177E-07	1.026E-07	6.119E-08	4.240E-08	2.521E-08
ESE	188	1.180E-07	9.649E-08	8.104E-08	6.935E-08	6.036E-08	3.577E-08	2.464E-08	1.449E-08
SE	164	9.092E-08	7.412E-08	6.830E-08	5.833E-08	5.068E-08	2.712E-08	1.858E-08	1.083E-08
SSE	104	5.122E-08	4.172E-08	3.491E-08	2.978E-08	2.584E-08	1.515E-08	1.034E-08	6.004E-09
S	76	4.816E-08	3.937E-08	3.305E-08	2.826E-08	2.457E-08	1.450E-08	9.968E-09	5.858E-09
SSW	145	7.657E-08	6.214E-08	5.187E-08	4.416E-08	3.826E-08	2.231E-08	1.516E-08	8.715E-09
SW	106	4.262E-08	3.440E-08	2.858E-08	2.424E-08	2.093E-08	1.205E-08	8.085E-09	4.535E-09
WSW	34	1.861E-08	1.509E-08	1.384E-08	1.176E-08	1.018E-08	5.366E-09	3.629E-09	2.070E-09
W	13	6.916E-09	5.646E-09	4.733E-09	4.040E-09	3.508E-09	2.058E-09	1.411E-09	8.259E-10
WNW	34	1.847E-08	1.486E-08	1.119E-08	9.469E-09	8.160E-09	4.667E-09	3.103E-09	1.707E-09
NW	52	5.223E-08	4.278E-08	3.596E-08	3.078E-08	2.680E-08	1.588E-08	1.095E-08	6.460E-09
NNW	71	6.328E-08	5.171E-08	4.339E-08	3.709E-08	3.224E-08	1.902E-08	1.306E-08	7.643E-09
AVERAGE	2203	9.450E-08	7.754E-08	6.572E-08	5.641E-08	4.923E-08	2.923E-08	2.029E-08	1.209E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	117	8.916E-09	6.754E-09	5.413E-09	4.493E-09	3.807E-09	3.299E-09	2.898E-09	
NNE	263	1.438E-08	1.090E-08	8.741E-09	7.258E-09	6.152E-09	5.334E-09	4.688E-09	
NE	319	2.545E-08	1.952E-08	1.579E-08	1.321E-08	1.127E-08	9.815E-09	8.663E-09	
NNE	234	2.098E-08	1.605E-08	1.296E-08	1.082E-08	9.218E-09	8.023E-09	7.077E-09	
E	283	1.750E-08	1.324E-08	1.059E-08	8.786E-09	7.439E-09	6.444E-09	5.659E-09	
ESE	188	1.000E-08	7.533E-09	6.009E-09	4.969E-09	4.197E-09	3.629E-09	3.181E-09	
SE	164	7.441E-09	5.584E-09	4.444E-09	3.669E-09	3.094E-09	2.672E-09	2.340E-09	
SSE	104	4.114E-09	3.082E-09	2.449E-09	2.019E-09	1.702E-09	1.470E-09	1.287E-09	
S	76	4.041E-09	3.042E-09	2.426E-09	2.006E-09	1.695E-09	1.467E-09	1.288E-09	
SSW	145	5.944E-09	4.437E-09	3.519E-09	2.890E-09	2.438E-09	2.102E-09	1.838E-09	
SW	106	3.046E-09	2.248E-09	1.766E-09	1.442E-09	1.205E-09	1.032E-09	8.976E-10	
WSW	34	1.403E-09	1.042E-09	8.229E-10	6.749E-10	5.659E-10	4.868E-10	4.246E-10	
W	13	5.680E-10	4.265E-10	3.397E-10	2.806E-10	2.368E-10	2.049E-10	1.797E-10	
WNW	34	1.132E-09	8.271E-10	6.441E-10	5.219E-10	4.327E-10	3.683E-10	3.182E-10	
NW	52	4.462E-09	3.361E-09	2.680E-09	2.216E-09	1.871E-09	1.619E-09	1.419E-09	
NNW	71	5.257E-09	3.947E-09	3.140E-09	2.591E-09	2.184E-09	1.886E-09	1.651E-09	
AVERAGE	2203	8.415E-09	6.374E-09	5.108E-09	4.241E-09	3.594E-09	3.116E-09	2.738E-09	

Table B-3

Gamma X/Q Factors for Reactor Building Vent

BECO 1994 General Ground Level X/Q's

GROUND RELEASE: AVERAGE GAMMA DILUTION FACTORS (MET. AND ATOMIC ENERGY 1966 FINITE CLOUD SECTOR AVERAGE MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	723	5.393E-06	2.280E-06	9.661E-07	5.797E-07	4.059E-07	2.428E-07	1.681E-07	1.264E-07
NNE	1435	9.756E-06	4.134E-06	1.765E-06	1.064E-06	7.458E-07	4.464E-07	3.091E-07	2.324E-07
NE	1195	9.842E-06	4.216E-06	1.798E-06	1.094E-06	7.716E-07	4.705E-07	3.305E-07	2.515E-07
ENE	856	7.850E-06	3.341E-06	1.434E-06	8.732E-07	6.159E-07	3.738E-07	2.615E-07	1.983E-07
E	977	7.807E-06	3.310E-06	1.417E-06	8.558E-07	6.005E-07	3.600E-07	2.495E-07	1.878E-07
ESE	633	5.121E-06	2.144E-06	8.954E-07	5.323E-07	3.726E-07	2.225E-07	1.538E-07	1.156E-07
SE	462	3.959E-06	1.650E-06	6.852E-07	4.047E-07	2.828E-07	1.683E-07	1.160E-07	8.691E-08
SSE	338	2.841E-06	1.173E-06	4.773E-07	2.785E-07	1.944E-07	1.155E-07	7.962E-08	5.968E-08
S	358	3.359E-06	1.366E-06	4.896E-07	2.792E-07	1.939E-07	1.148E-07	7.895E-08	5.918E-08
SSW	450	3.347E-06	1.367E-06	4.880E-07	2.776E-07	1.927E-07	1.138E-07	7.815E-08	5.839E-08
SW	316	2.186E-06	9.085E-07	3.329E-07	1.916E-07	1.322E-07	7.730E-08	5.263E-08	3.905E-08
WSW	196	1.555E-06	6.546E-07	2.481E-07	1.463E-07	1.014E-07	5.960E-08	4.072E-08	3.031E-08
W	82	7.757E-07	3.316E-07	1.302E-07	8.629E-08	6.016E-08	3.566E-08	2.228E-08	1.664E-08
WNW	155	1.245E-06	5.223E-07	2.193E-07	1.302E-07	9.085E-08	5.390E-08	4.079E-08	3.052E-08
NW	179	1.886E-06	7.946E-07	3.399E-07	2.046E-07	1.433E-07	8.548E-08	5.903E-08	4.432E-08
NNW	255	2.565E-06	1.093E-06	4.739E-07	2.885E-07	2.027E-07	1.214E-07	8.408E-08	6.322E-08
AVERAGE	8610	4.343E-06	1.830E-06	7.599E-07	4.554E-07	3.192E-07	1.914E-07	1.328E-07	1.000E-07

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	723	1.001E-07	8.217E-08	6.925E-08	5.947E-08	5.192E-08	3.110E-08	2.159E-08	1.285E-08
NNE	1435	1.842E-07	1.512E-07	1.274E-07	1.094E-07	9.551E-08	5.718E-08	3.969E-08	2.360E-08
NE	1195	2.013E-07	1.668E-07	1.417E-07	1.226E-07	1.078E-07	6.613E-08	4.680E-08	2.871E-08
ENE	856	1.584E-07	1.309E-07	1.109E-07	9.576E-08	8.399E-08	5.111E-08	3.596E-08	2.188E-08
E	977	1.490E-07	1.224E-07	1.032E-07	8.868E-08	7.746E-08	4.646E-08	3.230E-08	1.928E-08
ESE	633	9.152E-08	7.509E-08	6.325E-08	5.428E-08	4.736E-08	2.831E-08	1.963E-08	1.165E-08
SE	462	6.964E-08	5.619E-08	5.196E-08	4.451E-08	3.878E-08	2.095E-08	1.445E-08	8.511E-09
SSE	338	4.715E-08	3.861E-08	3.246E-08	2.782E-08	2.424E-08	1.442E-08	9.955E-09	5.864E-09
S	358	4.678E-08	3.832E-08	3.223E-08	2.763E-08	2.408E-08	1.433E-08	9.906E-09	5.855E-09
SSW	450	4.597E-08	3.754E-08	3.150E-08	2.695E-08	2.346E-08	1.390E-08	9.560E-09	5.596E-09
SW	316	3.053E-08	2.479E-08	2.070E-08	1.764E-08	1.530E-08	8.944E-09	6.078E-09	3.487E-09
WSW	196	2.380E-08	1.939E-08	1.785E-08	1.525E-08	1.324E-08	7.080E-09	4.844E-09	2.816E-09
W	82	1.309E-08	1.068E-08	8.954E-09	7.654E-09	6.655E-09	3.929E-09	2.691E-09	1.564E-09
WNW	155	2.406E-08	1.966E-08	1.500E-08	1.284E-08	1.117E-08	6.611E-09	4.542E-09	2.655E-09
NW	179	3.510E-08	2.879E-08	2.424E-08	2.079E-08	1.812E-08	1.060E-08	7.476E-09	4.434E-09
NNW	255	5.011E-08	4.115E-08	3.468E-08	2.977E-08	2.598E-08	1.554E-08	1.078E-08	6.411E-09
AVERAGE	8610	7.936E-08	6.522E-08	5.533E-08	4.757E-08	4.157E-08	2.480E-08	1.727E-08	1.032E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	723	8.944E-09	6.775E-09	5.429E-09	4.508E-09	3.821E-09	3.313E-09	2.912E-09	
NNE	1435	1.641E-08	1.242E-08	9.945E-09	8.250E-09	6.988E-09	6.056E-09	5.320E-09	
NE	1195	2.035E-08	1.562E-08	1.265E-08	1.059E-08	9.047E-09	7.886E-09	6.968E-09	
ENE	856	1.542E-08	1.179E-08	9.518E-09	7.948E-09	6.771E-09	5.893E-09	5.199E-09	
E	977	1.343E-08	1.018E-08	8.160E-09	6.777E-09	5.745E-09	4.982E-09	4.380E-09	
ESE	633	8.088E-09	6.117E-09	4.895E-09	4.059E-09	3.437E-09	2.978E-09	2.616E-09	
SE	462	5.884E-09	4.435E-09	3.541E-09	2.931E-09	2.477E-09	2.144E-09	1.881E-09	
SSE	338	4.056E-09	3.058E-09	2.441E-09	2.021E-09	1.708E-09	1.478E-09	1.297E-09	
S	358	4.060E-09	3.068E-09	2.454E-09	2.035E-09	1.723E-09	1.494E-09	1.313E-09	
SSW	450	3.861E-09	2.907E-09	2.320E-09	1.920E-09	1.623E-09	1.405E-09	1.233E-09	
SW	316	2.377E-09	1.773E-09	1.406E-09	1.158E-09	9.739E-10	8.394E-10	7.338E-10	
WSW	196	1.933E-09	1.449E-09	1.154E-09	9.532E-10	8.042E-10	6.949E-10	6.088E-10	
W	82	1.073E-09	8.038E-10	6.386E-10	5.264E-10	4.433E-10	3.824E-10	3.345E-10	
WNW	155	1.827E-09	1.372E-09	1.092E-09	9.011E-10	7.599E-10	6.564E-10	5.749E-10	
NW	179	3.076E-09	2.324E-09	1.859E-09	1.541E-09	1.304E-09	1.130E-09	9.925E-10	
NNW	255	4.455E-09	3.369E-09	2.696E-09	2.235E-09	1.892E-09	1.639E-09	1.439E-09	
AVERAGE	8610	7.203E-09	5.467E-09	4.388E-09	3.647E-09	3.095E-09	2.686E-09	2.363E-09	

Deposition D/Q Factors for Reactor Building Vent

SECTOR AVERAGE MODEL

GROUND RELEASE: AVERAGE DEPOSITION RATES (REGULATORY GUIDE 1.111 MODEL) - (1/M2)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	104	8.482E-08	2.852E-08	9.633E-09	5.083E-09	3.145E-09	1.521E-09	9.278E-10	6.323E-10
NNE	177	1.444E-07	4.854E-08	1.639E-08	8.651E-09	5.352E-09	2.588E-09	1.579E-09	1.076E-09
NE	186	1.517E-07	5.101E-08	1.723E-08	9.091E-09	5.625E-09	2.720E-09	1.659E-09	1.131E-09
NNE	250	2.039E-07	6.857E-08	2.316E-08	1.222E-08	7.560E-09	3.656E-09	2.230E-09	1.520E-09
E	376	3.067E-07	1.031E-07	3.483E-08	1.838E-08	1.137E-08	5.498E-09	3.355E-09	2.286E-09
ESE	235	1.917E-07	6.445E-08	2.177E-08	1.149E-08	7.106E-09	3.436E-09	2.097E-09	1.429E-09
SE	145	1.183E-07	3.977E-08	1.343E-08	7.087E-09	4.385E-09	2.120E-09	1.294E-09	8.815E-10
SSE	89	7.259E-08	2.441E-08	8.243E-09	4.350E-09	2.691E-09	1.301E-09	7.940E-10	5.411E-10
S	91	8.164E-08	2.745E-08	8.429E-09	4.448E-09	2.752E-09	1.331E-09	8.119E-10	5.532E-10
SSW	105	9.420E-08	3.168E-08	9.725E-09	5.132E-09	3.175E-09	1.535E-09	9.368E-10	6.384E-10
SW	82	7.356E-08	2.474E-08	7.595E-09	4.008E-09	2.480E-09	1.199E-09	7.316E-10	4.985E-10
WSW	80	7.177E-08	2.414E-08	7.410E-09	3.910E-09	2.419E-09	1.170E-09	7.137E-10	4.864E-10
W	19	1.705E-08	5.732E-09	1.760E-09	1.021E-09	6.320E-10	3.056E-10	1.695E-10	1.155E-10
WNW	27	2.202E-08	7.405E-09	2.501E-09	1.320E-09	8.165E-10	3.948E-10	2.650E-10	1.806E-10
NW	37	3.018E-08	1.015E-08	3.427E-09	1.808E-09	1.119E-09	5.411E-10	3.301E-10	2.249E-10
NNW	71	5.790E-08	1.947E-08	6.576E-09	3.470E-09	2.147E-09	1.038E-09	6.334E-10	4.316E-10

AVERAGE	2074	1.076E-07	3.620E-08	1.201E-08	6.341E-09	3.923E-09	1.897E-09	1.158E-09	7.891E-10
---------	------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	104	4.626E-10	3.539E-10	2.798E-10	2.249E-10	1.855E-10	9.302E-11	5.720E-11	2.822E-11
NNE	177	7.874E-10	6.023E-10	4.762E-10	3.827E-10	3.157E-10	1.583E-10	9.735E-11	4.803E-11
NNE	186	8.274E-10	6.329E-10	5.004E-10	4.022E-10	3.318E-10	1.664E-10	1.023E-10	5.047E-11
NNE	250	1.112E-09	8.507E-10	6.726E-10	5.405E-10	4.460E-10	2.236E-10	1.375E-10	6.784E-11
E	376	1.673E-09	1.279E-09	1.012E-09	8.130E-10	6.707E-10	3.363E-10	2.068E-10	1.020E-10
ESE	235	1.045E-09	7.996E-10	6.323E-10	5.081E-10	4.192E-10	2.102E-10	1.292E-10	6.377E-11
SE	145	6.450E-10	4.934E-10	4.291E-10	3.449E-10	2.845E-10	1.297E-10	7.975E-11	3.935E-11
SSE	89	3.959E-10	3.028E-10	2.395E-10	1.924E-10	1.588E-10	7.960E-11	4.895E-11	2.415E-11
S	91	4.048E-10	3.096E-10	2.448E-10	1.968E-10	1.623E-10	8.139E-11	5.005E-11	2.469E-11
SSW	105	4.671E-10	3.573E-10	2.825E-10	2.270E-10	1.873E-10	9.391E-11	5.775E-11	2.849E-11
SW	82	3.648E-10	2.790E-10	2.206E-10	1.773E-10	1.463E-10	7.334E-11	4.510E-11	2.225E-11
WSW	80	3.559E-10	2.722E-10	2.368E-10	1.903E-10	1.570E-10	7.155E-11	4.400E-11	2.171E-11
W	19	8.452E-11	6.465E-11	5.112E-11	4.108E-11	3.389E-11	1.699E-11	1.045E-11	5.156E-12
WNW	27	1.321E-10	1.011E-10	7.264E-11	5.838E-11	4.817E-11	2.415E-11	1.485E-11	7.327E-12
NW	37	1.646E-10	1.259E-10	9.955E-11	8.000E-11	6.600E-11	3.309E-11	2.035E-11	1.004E-11
NNW	71	3.158E-10	2.416E-10	1.910E-10	1.535E-10	1.267E-10	6.350E-11	3.905E-11	1.927E-11

AVERAGE	2074	5.774E-10	4.416E-10	3.525E-10	2.833E-10	2.337E-10	1.159E-10	7.129E-11	3.518E-11
---------	------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)						
		20.00	25.00	30.00	34.95	40.00	45.00	50.00
N	104	1.735E-11	1.168E-11	8.229E-12	6.170E-12	4.800E-12	3.925E-12	3.259E-12
NNE	177	2.952E-11	1.980E-11	1.400E-11	1.050E-11	8.169E-12	6.681E-12	5.547E-12
NE	186	3.102E-11	2.089E-11	1.472E-11	1.104E-11	8.584E-12	7.020E-12	5.829E-12
ENE	250	4.170E-11	2.807E-11	1.978E-11	1.483E-11	1.154E-11	9.436E-12	7.835E-12
E	376	6.271E-11	4.222E-11	2.975E-11	2.231E-11	1.735E-11	1.419E-11	1.178E-11
ESE	235	3.920E-11	2.639E-11	1.859E-11	1.394E-11	1.085E-11	8.870E-12	7.365E-12
SE	145	2.418E-11	1.628E-11	1.147E-11	8.603E-12	6.692E-12	5.473E-12	4.544E-12
SSE	89	1.484E-11	9.994E-12	7.042E-12	5.280E-12	4.107E-12	3.359E-12	2.789E-12
S	91	1.518E-11	1.022E-11	7.200E-12	5.399E-12	4.200E-12	3.435E-12	2.852E-12
SSW	105	1.751E-11	1.179E-11	8.308E-12	6.229E-12	4.846E-12	3.963E-12	3.291E-12
SW	82	1.368E-11	9.206E-12	6.486E-12	4.865E-12	3.784E-12	3.095E-12	2.570E-12
WSW	80	1.334E-11	8.984E-12	6.330E-12	4.746E-12	3.692E-12	3.019E-12	2.507E-12
W	19	3.169E-12	2.134E-12	1.503E-12	1.127E-12	8.769E-13	7.171E-13	5.955E-13
WNW	27	4.503E-12	3.032E-12	2.136E-12	1.602E-12	1.246E-12	1.019E-12	8.462E-13
NW	37	6.171E-12	4.155E-12	2.928E-12	2.195E-12	1.708E-12	1.397E-12	1.160E-12
NNW	71	1.184E-11	7.973E-12	5.618E-12	4.212E-12	3.277E-12	2.680E-12	2.225E-12

AVERAGE	2074	2.162E-11	1.456E-11	1.026E-11	7.690E-12	5.982E-12	4.892E-12	4.062E-12
---------	------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

Table B-4

Deposition D/Q Factors for Reactor Building Vent

BECo 2nd Quarter 1994 General Ground Level X/Q's
 GROUND RELEASE: AVERAGE DEPOSITION RATES (REGULATORY GUIDE 1.111 MODEL) - (1/M2) SECTOR AVERAGE MODEL

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	317	2.474E-07	8.321E-08	2.810E-08	1.483E-08	9.175E-09	4.437E-09	2.707E-09	1.845E-09
NNE	476	3.715E-07	1.249E-07	4.220E-08	2.227E-08	1.378E-08	6.662E-09	4.064E-09	2.770E-09
NE	256	1.998E-07	6.720E-08	2.269E-08	1.198E-08	7.409E-09	3.583E-09	2.186E-09	1.490E-09
ENE	171	1.335E-07	4.489E-08	1.516E-08	7.999E-09	4.949E-09	2.393E-09	1.460E-09	9.950E-10
E	184	1.436E-07	4.830E-08	1.631E-08	8.607E-09	5.325E-09	2.575E-09	1.571E-09	1.071E-09
ESE	119	9.289E-08	3.124E-08	1.055E-08	5.567E-09	3.444E-09	1.665E-09	1.016E-09	6.924E-10
SE	79	6.166E-08	2.074E-08	7.703E-09	4.065E-09	2.515E-09	1.216E-09	6.746E-10	4.597E-10
SSE	74	6.354E-08	2.137E-08	7.216E-09	3.462E-09	2.142E-09	1.036E-09	6.319E-10	4.306E-10
S	76	7.306E-08	2.457E-08	6.914E-09	3.649E-09	2.257E-09	1.092E-09	6.660E-10	4.539E-10
SSW	94	8.071E-08	2.714E-08	8.333E-09	4.397E-09	2.721E-09	1.316E-09	8.026E-10	5.470E-10
SW	64	5.495E-08	1.848E-08	5.673E-09	2.994E-09	1.852E-09	8.957E-10	5.465E-10	3.724E-10
WSW	39	3.349E-08	1.126E-08	3.457E-09	1.824E-09	1.129E-09	5.458E-10	3.330E-10	2.269E-10
W	25	2.147E-08	7.219E-09	2.216E-09	1.286E-09	7.959E-10	3.849E-10	2.135E-10	1.455E-10
WSW	56	4.371E-08	1.470E-08	4.964E-09	2.620E-09	1.621E-09	7.838E-10	5.260E-10	3.564E-10
NW	58	4.527E-08	1.522E-08	5.141E-09	2.713E-09	1.679E-09	8.117E-10	4.952E-10	3.375E-10
NNW	77	6.010E-08	2.021E-08	6.826E-09	3.602E-09	2.229E-09	1.078E-09	6.575E-10	4.480E-10
AVERAGE	2167	1.079E-07	3.629E-08	1.209E-08	6.366E-09	3.939E-09	1.905E-09	1.159E-09	7.901E-10

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	317	1.350E-09	1.032E-09	8.163E-10	6.560E-10	5.412E-10	2.714E-10	1.669E-10	8.233E-11
NNE	476	2.027E-09	1.550E-09	1.226E-09	9.850E-10	8.127E-10	4.075E-10	2.506E-10	1.236E-10
NE	256	1.090E-09	8.337E-10	6.592E-10	5.297E-10	4.371E-10	2.191E-10	1.348E-10	6.649E-11
ENE	171	7.281E-10	5.569E-10	4.403E-10	3.539E-10	2.920E-10	1.464E-10	9.001E-11	4.441E-11
E	184	7.834E-10	5.992E-10	4.738E-10	3.808E-10	3.142E-10	1.575E-10	9.686E-11	4.779E-11
ESE	119	5.067E-10	3.875E-10	3.064E-10	2.462E-10	2.032E-10	1.019E-10	6.264E-11	3.091E-11
SE	79	3.364E-10	2.573E-10	2.239E-10	1.798E-10	1.484E-10	7.439E-11	4.574E-11	2.257E-11
SSE	74	3.151E-10	2.410E-10	1.906E-10	1.531E-10	1.263E-10	6.335E-11	3.895E-11	1.922E-11
S	76	3.321E-10	2.540E-10	2.009E-10	1.614E-10	1.332E-10	6.677E-11	4.106E-11	2.026E-11
SSW	94	4.002E-10	3.061E-10	2.421E-10	1.945E-10	1.605E-10	8.047E-11	4.948E-11	2.441E-11
SW	64	2.725E-10	2.084E-10	1.648E-10	1.324E-10	1.093E-10	5.479E-11	3.369E-11	1.662E-11
WSW	39	1.660E-10	1.270E-10	1.105E-10	8.877E-11	7.324E-11	3.339E-11	2.053E-11	1.013E-11
W	25	1.064E-10	8.141E-11	6.439E-11	5.173E-11	4.268E-11	2.140E-11	1.316E-11	6.493E-12
WSW	56	2.623E-10	2.006E-10	1.442E-10	1.159E-10	9.561E-11	4.794E-11	2.948E-11	1.454E-11
NW	58	2.469E-10	1.889E-10	1.494E-10	1.200E-10	9.903E-11	4.965E-11	3.053E-11	1.506E-11
NNW	77	3.278E-10	2.508E-10	1.983E-10	1.593E-10	1.315E-10	6.591E-11	4.053E-11	2.000E-11
AVERAGE	2167	5.781E-10	4.422E-10	3.507E-10	2.818E-10	2.325E-10	1.164E-10	7.155E-11	3.530E-11

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	317	5.060E-11	3.407E-11	2.401E-11	1.800E-11	1.400E-11	1.145E-11	9.508E-12	
NNE	476	7.598E-11	5.116E-11	3.605E-11	2.703E-11	2.103E-11	1.719E-11	1.428E-11	
NE	256	4.087E-11	2.751E-11	1.939E-11	1.454E-11	1.131E-11	9.248E-12	7.679E-12	
ENE	171	2.730E-11	1.838E-11	1.295E-11	9.710E-12	7.553E-12	6.177E-12	5.129E-12	
E	184	2.937E-11	1.978E-11	1.393E-11	1.045E-11	8.127E-12	6.647E-12	5.519E-12	
ESE	119	1.900E-11	1.279E-11	9.012E-12	6.757E-12	5.256E-12	4.299E-12	3.569E-12	
SE	79	1.387E-11	9.340E-12	6.581E-12	4.934E-12	3.838E-12	3.139E-12	2.607E-12	
SSE	74	1.181E-11	7.953E-12	5.604E-12	4.202E-12	3.269E-12	2.673E-12	2.220E-12	
S	76	1.245E-11	8.383E-12	5.907E-12	4.429E-12	3.445E-12	2.818E-12	2.340E-12	
SSW	94	1.501E-11	1.010E-11	7.118E-12	5.338E-12	4.152E-12	3.396E-12	2.819E-12	
SW	64	1.022E-11	6.878E-12	4.847E-12	3.634E-12	2.827E-12	2.312E-12	1.920E-12	
WSW	39	6.226E-12	4.192E-12	2.953E-12	2.215E-12	1.723E-12	1.409E-12	1.170E-12	
W	25	3.991E-12	2.687E-12	1.893E-12	1.420E-12	1.104E-12	9.031E-13	7.499E-13	
WSW	56	8.939E-12	6.019E-12	4.241E-12	3.180E-12	2.474E-12	2.023E-12	1.680E-12	
NW	58	9.259E-12	6.234E-12	4.392E-12	3.293E-12	2.562E-12	2.095E-12	1.740E-12	
NNW	77	1.229E-11	8.276E-12	5.831E-12	4.372E-12	3.401E-12	2.782E-12	2.310E-12	
AVERAGE	2167	2.170E-11	1.461E-11	1.029E-11	7.718E-12	6.004E-12	4.910E-12	4.077E-12	

Table B-4

Deposition D/Q Factors for Reactor Building Vent

RECo 3rd Quarter 1994 Genral Ground Level X/Q's

SECTOR AVERAGE MODEL

GROUND RELEASE: AVERAGE DEPOSITION RATES (REGULATORY GUIDE 1.111 MODEL) - (1/M2)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	185	1.445E-07	4.858E-08	1.641E-08	8.658E-09	5.757E-09	2.590E-09	1.580E-09	1.077E-09
NNE	519	4.053E-07	1.363E-07	4.603E-08	2.429E-08	1.53E-08	7.267E-09	4.434E-09	3.021E-09
NE	434	3.389E-07	1.140E-07	3.849E-08	2.031E-08	1.25E-08	6.077E-09	3.708E-09	2.526E-09
ENE	201	1.570E-07	5.279E-08	1.783E-08	9.407E-09	5.820E-09	2.814E-09	1.717E-09	1.170E-09
E	134	1.046E-07	3.519E-08	1.188E-08	6.271E-09	3.880E-09	1.876E-09	1.145E-09	7.801E-10
ESE	91	7.106E-08	2.390E-08	8.071E-09	4.259E-09	2.635E-09	1.274E-09	7.774E-10	5.297E-10
SE	74	5.779E-08	1.943E-08	7.219E-09	3.809E-09	2.357E-09	1.140E-09	6.322E-10	4.308E-10
SSE	71	6.099E-08	2.051E-08	6.926E-09	3.323E-09	2.056E-09	9.942E-10	6.065E-10	4.133E-10
S	113	1.059E-07	3.561E-08	1.002E-08	5.288E-09	3.272E-09	1.582E-09	9.653E-10	6.578E-10
SSW	106	9.106E-08	3.062E-08	9.401E-09	4.961E-09	3.069E-09	1.484E-09	9.055E-10	6.171E-10
SW	64	5.498E-08	1.849E-08	5.676E-09	2.995E-09	1.853E-09	8.961E-10	5.467E-10	3.726E-10
WSW	43	3.694E-08	1.242E-08	3.814E-09	2.012E-09	1.245E-09	6.021E-10	3.673E-10	2.503E-10
W	25	2.148E-08	7.222E-09	2.217E-09	1.287E-09	7.963E-10	3.851E-10	2.136E-10	1.455E-10
WNW	36	2.968E-08	9.979E-09	3.370E-09	1.778E-09	1.100E-09	5.321E-10	3.571E-10	2.433E-10
NW	32	2.499E-08	8.404E-09	2.838E-09	1.498E-09	9.266E-10	4.481E-10	2.734E-10	1.863E-10
NNW	36	2.811E-08	9.454E-09	3.193E-09	1.685E-09	1.042E-09	5.041E-10	3.075E-10	2.096E-10
AVERAGE	2166	1.583E-07	3.643E-08	1.209E-08	6.364E-09	3.938E-09	1.904E-09	1.158E-09	7.894E-10

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	185	7.880E-10	6.027E-10	4.766E-10	3.830E-10	3.160E-10	1.584E-10	9.743E-11	4.607E-11
NNE	519	2.211E-09	1.691E-09	1.337E-09	1.074E-09	8.865E-10	4.445E-10	2.733E-10	1.349E-10
NE	434	1.849E-09	1.414E-09	1.118E-09	8.985E-10	7.413E-10	3.717E-10	2.286E-10	1.128E-10
ENE	201	8.562E-10	6.549E-10	5.178E-10	4.161E-10	3.433E-10	1.721E-10	1.059E-10	5.223E-11
E	134	5.708E-10	4.366E-10	3.452E-10	2.774E-10	2.289E-10	1.148E-10	7.057E-11	3.482E-11
ESE	91	3.876E-10	2.965E-10	2.344E-10	1.884E-10	1.554E-10	7.793E-11	4.792E-11	2.365E-11
SE	74	3.152E-10	2.411E-10	2.097E-10	1.685E-10	1.390E-10	6.971E-11	4.287E-11	2.115E-11
SSE	71	3.024E-10	2.313E-10	1.829E-10	1.470E-10	1.213E-10	6.081E-11	3.739E-11	1.845E-11
S	113	4.813E-10	3.682E-10	2.911E-10	2.339E-10	1.930E-10	9.678E-11	5.951E-11	2.936E-11
SSW	106	4.515E-10	3.454E-10	2.731E-10	2.194E-10	1.811E-10	9.078E-11	5.582E-11	2.754E-11
SW	64	2.726E-10	2.085E-10	1.649E-10	1.325E-10	1.093E-10	5.481E-11	3.370E-11	1.663E-11
WSW	43	1.832E-10	1.401E-10	1.219E-10	9.792E-11	8.079E-11	3.683E-11	2.265E-11	1.117E-11
W	25	1.065E-10	8.145E-11	6.441E-11	5.176E-11	4.270E-11	2.141E-11	1.317E-11	6.496E-12
WNW	38	1.781E-10	1.362E-10	9.790E-11	7.867E-11	6.491E-11	3.254E-11	2.001E-11	9.874E-12
NW	32	1.363E-10	1.043E-10	8.244E-11	6.625E-11	5.466E-11	2.741E-11	1.685E-11	8.315E-12
NNW	36	1.533E-10	1.173E-10	9.277E-11	7.453E-11	6.149E-11	3.083E-11	1.896E-11	9.354E-12
AVERAGE	2166	5.777E-10	4.418E-10	3.506E-10	2.818E-10	2.325E-10	1.163E-10	7.154E-11	3.530E-11

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	185	2.955E-11	1.989E-11	1.402E-11	1.051E-11	8.175E-12	6.686E-12	5.552E-12	
NNE	519	8.289E-11	5.581E-11	3.932E-11	2.948E-11	2.293E-11	1.876E-11	1.557E-11	
NE	434	6.931E-11	4.667E-11	3.288E-11	2.465E-11	1.918E-11	1.568E-11	1.302E-11	
ENE	201	3.210E-11	2.161E-11	1.523E-11	1.142E-11	8.882E-12	7.264E-12	6.032E-12	
E	134	2.140E-11	1.441E-11	1.015E-11	7.612E-12	5.922E-12	4.843E-12	4.021E-12	
ESE	91	1.453E-11	9.785E-12	6.894E-12	5.170E-12	4.021E-12	3.289E-12	2.731E-12	
SE	74	1.300E-11	8.753E-12	6.167E-12	4.624E-12	3.597E-12	2.942E-12	2.443E-12	
SSE	71	1.134E-11	7.634E-12	5.379E-12	4.033E-12	3.138E-12	2.566E-12	2.131E-12	
S	113	1.805E-11	1.215E-11	8.561E-12	6.419E-12	4.994E-12	4.084E-12	3.391E-12	
SSW	106	1.693E-11	1.140E-11	8.031E-12	6.022E-12	4.684E-12	3.831E-12	3.181E-12	
SW	64	1.022E-11	6.882E-12	4.849E-12	3.636E-12	2.828E-12	2.313E-12	1.921E-12	
WSW	43	6.867E-12	4.624E-12	3.258E-12	2.443E-12	1.900E-12	1.554E-12	1.290E-12	
W	25	3.993E-12	2.688E-12	1.894E-12	1.420E-12	1.105E-12	9.035E-13	7.502E-13	
WNW	38	6.069E-12	4.086E-12	2.879E-12	2.159E-12	1.679E-12	1.373E-12	1.140E-12	
NW	32	5.111E-12	3.441E-12	2.424E-12	1.818E-12	1.414E-12	1.156E-12	9.603E-13	
NNW	36	5.749E-12	3.871E-12	2.727E-12	2.045E-12	1.591E-12	1.301E-12	1.080E-12	
AVERAGE	2166	2.169E-11	1.461E-11	1.029E-11	7.717E-12	6.003E-12	4.909E-12	4.076E-12	

Table B-4

Deposition D/Q Factors for Reactor Building Vent

BECo 4th Quarter 1994 General Ground Level X/Q's
 GROUND RELEASE: AVERAGE DEPOSITION RATES (REGULATORY GUIDE 1.111 MODEL) - (1/M2) SECTOR AVERAGE MODEL

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		12	25	50	75	1.00	1.50	2.00	2.50
N	117	8.983E-08	3.021E-08	1.020E-08	5.384E-09	3.331E-09	1.611E-09	9.827E-10	6.697E-10
NNE	263	2.019E-07	6.791E-08	2.293E-08	1.210E-08	7.487E-09	3.621E-09	2.209E-09	1.505E-09
NE	319	2.449E-07	8.237E-08	2.782E-08	1.548E-08	9.082E-09	4.392E-09	2.679E-09	1.826E-09
ENE	234	1.797E-07	6.042E-08	2.040E-08	1.071E-08	6.662E-09	3.221E-09	1.965E-09	1.339E-09
E	283	2.173E-07	7.307E-08	2.468E-08	1.372E-08	8.057E-09	3.896E-09	2.377E-09	1.620E-09
ESE	188	1.443E-07	4.854E-08	1.639E-08	8.750E-09	5.352E-09	2.588E-09	1.579E-09	1.076E-09
SE	164	1.259E-07	4.235E-08	1.430E-08	7.546E-09	4.669E-09	2.258E-09	1.377E-09	9.387E-10
SSE	104	7.985E-08	2.685E-08	9.069E-09	4.785E-09	2.961E-09	1.432E-09	8.735E-10	5.953E-10
S	76	6.419E-08	2.159E-08	6.627E-09	3.497E-09	2.164E-09	1.046E-09	6.383E-10	4.350E-10
SSW	145	1.225E-07	4.118E-08	1.264E-08	6.672E-09	4.128E-09	1.996E-09	1.218E-09	8.299E-10
SW	106	8.953E-08	3.011E-08	9.243E-09	4.877E-09	3.018E-09	1.459E-09	8.903E-10	6.067E-10
WSW	34	2.872E-08	9.657E-09	2.965E-09	1.564E-09	9.679E-10	4.681E-10	2.856E-10	1.946E-10
W	13	1.098E-08	3.692E-09	1.134E-09	6.580E-10	4.071E-10	1.969E-10	1.092E-10	7.441E-11
WNW	34	2.611E-08	8.779E-09	2.965E-09	1.564E-09	9.679E-10	4.681E-10	3.141E-10	2.141E-10
NW	52	3.593E-08	1.343E-08	4.534E-09	2.393E-09	1.480E-09	7.159E-10	4.368E-10	2.976E-10
NNW	71	5.451E-08	1.833E-08	6.191E-09	3.267E-09	2.021E-09	9.775E-10	5.963E-10	4.064E-10

AVERAGE 2203 1.075E-07 3.616E-08 1.201E-08 6.339E-09 3.922E-09 1.897E-09 1.158E-09 7.893E-10

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	117	4.900E-10	3.748E-10	2.964E-10	2.382E-10	1.965E-10	9.852E-11	6.058E-11	2.989E-11
NNE	263	1.101E-09	8.425E-10	6.662E-10	5.353E-10	4.417E-10	2.215E-10	1.362E-10	6.719E-11
NE	319	1.336E-09	1.022E-09	8.080E-10	6.493E-10	5.357E-10	2.686E-10	1.652E-10	8.150E-11
ENE	234	9.800E-10	7.496E-10	5.927E-10	4.763E-10	3.930E-10	1.970E-10	1.212E-10	5.978E-11
E	283	1.185E-09	9.066E-10	7.166E-10	5.760E-10	4.753E-10	2.383E-10	1.465E-10	7.230E-11
ESE	188	7.874E-10	6.022E-10	4.762E-10	3.827E-10	3.157E-10	1.583E-10	9.734E-11	4.803E-11
SE	164	6.868E-10	5.254E-10	4.569E-10	3.672E-10	3.030E-10	1.381E-10	8.492E-11	4.190E-11
SSE	104	4.356E-10	3.332E-10	2.634E-10	2.117E-10	1.747E-10	8.757E-11	5.385E-11	2.657E-11
S	76	3.183E-10	2.435E-10	1.925E-10	1.547E-10	1.276E-10	6.400E-11	3.935E-11	1.942E-11
SSW	145	6.073E-10	4.645E-10	3.673E-10	2.951E-10	2.435E-10	1.221E-10	7.508E-11	3.704E-11
SW	106	4.439E-10	3.396E-10	2.685E-10	2.158E-10	1.780E-10	8.926E-11	5.489E-11	2.708E-11
WSW	34	1.424E-10	1.089E-10	9.473E-11	7.613E-11	6.281E-11	2.863E-11	1.760E-11	8.686E-12
W	13	5.444E-11	4.164E-11	3.293E-11	2.646E-11	2.183E-11	1.095E-11	6.731E-12	3.321E-12
WNW	34	1.566E-10	1.198E-10	8.612E-11	6.921E-11	5.710E-11	2.863E-11	1.760E-11	8.686E-12
NW	52	2.178E-10	1.666E-10	1.317E-10	1.058E-10	8.733E-11	4.379E-11	2.692E-11	1.328E-11
NNW	71	2.974E-10	2.274E-10	1.798E-10	1.445E-10	1.192E-10	5.979E-11	3.676E-11	1.814E-11

AVERAGE 2203 5.775E-10 4.417E-10 3.519E-10 2.828E-10 2.333E-10 1.159E-10 7.129E-11 3.518E-11

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	117	1.837E-11	1.237E-11	8.715E-12	6.535E-12	5.083E-12	4.157E-12	3.452E-12	
NNE	263	4.130E-11	2.780E-11	1.959E-11	1.469E-11	1.143E-11	9.345E-12	7.760E-12	
NE	319	5.009E-11	3.372E-11	2.376E-11	1.782E-11	1.386E-11	1.134E-11	9.412E-12	
ENE	234	3.674E-11	2.474E-11	1.743E-11	1.307E-11	1.017E-11	8.315E-12	6.904E-12	
E	283	4.444E-11	2.992E-11	2.108E-11	1.581E-11	1.230E-11	1.006E-11	8.350E-12	
ESE	188	2.952E-11	1.988E-11	1.400E-11	1.050E-11	8.168E-12	6.680E-12	5.547E-12	
SE	164	2.575E-11	1.734E-11	1.222E-11	9.160E-12	7.126E-12	5.827E-12	4.839E-12	
SSE	104	1.633E-11	1.099E-11	7.747E-12	5.809E-12	4.519E-12	3.695E-12	3.068E-12	
S	76	1.193E-11	8.035E-12	5.661E-12	4.245E-12	3.302E-12	2.701E-12	2.242E-12	
SSW	145	2.277E-11	1.533E-11	1.080E-11	8.099E-12	6.300E-12	5.152E-12	4.278E-12	
SW	106	1.664E-11	1.121E-11	7.896E-12	5.921E-12	4.606E-12	3.767E-12	3.127E-12	
WSW	34	5.339E-12	3.594E-12	2.533E-12	1.899E-12	1.477E-12	1.208E-12	1.003E-12	
W	13	2.041E-12	1.374E-12	9.684E-13	7.261E-13	5.648E-13	4.619E-13	3.836E-13	
WNW	34	5.339E-12	3.594E-12	2.533E-12	1.899E-12	1.477E-12	1.208E-12	1.003E-12	
NW	52	8.165E-12	5.497E-12	3.873E-12	2.904E-12	2.259E-12	1.848E-12	1.534E-12	
NNW	71	1.115E-11	7.506E-12	5.289E-12	3.966E-12	3.085E-12	2.523E-12	2.095E-12	

AVERAGE 2203 2.162E-11 1.456E-11 1.026E-11 7.690E-12 5.982E-12 4.892E-12 4.062E-12

Table B-4

Deposition D/Q Factors for Reactor Building Vent

BECo 1994 General Ground Level X/Q's
GROUND RELEASE: AVERAGE DEPOSITION RATES (REGULATORY GUIDE 1.111 MODEL) - (1/M2) SECTOR AVERAGE MODEL

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	723	1.420E-07	4.777E-08	1.613E-08	8.512E-09	5.266E-09	2.547E-09	1.554E-09	1.059E-09
NNE	1435	2.819E-07	9.480E-08	3.202E-08	1.689E-08	1.045E-08	5.055E-09	3.084E-09	2.102E-09
NE	1195	2.348E-07	7.895E-08	2.666E-08	1.407E-08	8.705E-09	4.209E-09	2.568E-09	1.750E-09
ENE	856	1.682E-07	5.655E-08	1.910E-08	1.008E-08	6.235E-09	3.015E-09	1.840E-09	1.254E-09
E	977	1.919E-07	6.455E-08	2.180E-08	1.150E-08	7.117E-09	3.441E-09	2.100E-09	1.431E-09
ESE	633	1.244E-07	4.182E-08	1.412E-08	7.452E-09	4.611E-09	2.230E-09	1.360E-09	9.270E-10
SE	462	9.076E-08	3.052E-08	1.031E-08	5.439E-09	3.365E-09	1.627E-09	9.929E-10	6.766E-10
SSE	338	6.640E-08	2.233E-08	7.541E-09	3.979E-09	2.462E-09	1.191E-09	7.264E-10	4.950E-10
S	358	7.736E-08	2.602E-08	7.987E-09	4.215E-09	2.608E-09	1.261E-09	7.694E-10	5.243E-10
SSW	450	9.725E-08	3.270E-08	1.004E-08	5.298E-09	3.278E-09	1.585E-09	9.671E-10	6.590E-10
SW	316	6.829E-08	2.296E-08	7.050E-09	3.720E-09	2.302E-09	1.113E-09	6.791E-10	4.628E-10
WSW	196	4.236E-08	1.424E-08	4.373E-09	2.308E-09	1.428E-09	6.904E-10	4.212E-10	2.870E-10
W	82	1.772E-08	5.959E-09	1.829E-09	1.062E-09	6.570E-10	3.177E-10	1.762E-10	1.201E-10
WNW	155	3.045E-08	1.024E-08	3.459E-09	1.825E-09	1.129E-09	5.460E-10	3.664E-10	2.497E-10
NW	179	3.517E-08	1.183E-08	3.994E-09	2.107E-09	1.304E-09	6.305E-10	3.847E-10	2.621E-10
NNW	255	5.010E-08	1.685E-08	5.689E-09	3.002E-09	1.857E-09	8.982E-10	5.480E-10	3.734E-10

AVERAGE 8610 1.074E-07 3.613E-08 1.201E-08 6.341E-09 3.924E-09 1.897E-09 1.159E-09 7.895E-10

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	723	7.747E-10	5.926E-10	4.686E-10	3.765E-10	3.107E-10	1.558E-10	9.579E-11	4.726E-11
NNE	1435	1.538E-09	1.176E-09	9.300E-10	7.474E-10	6.166E-10	3.092E-10	1.901E-10	9.380E-11
NE	1195	1.281E-09	9.795E-10	7.745E-10	6.224E-10	5.135E-10	2.575E-10	1.583E-10	7.811E-11
ENE	856	9.173E-10	7.016E-10	5.548E-10	4.458E-10	3.678E-10	1.844E-10	1.134E-10	5.595E-11
E	977	1.047E-09	8.008E-10	6.332E-10	5.088E-10	4.198E-10	2.105E-10	1.294E-10	6.386E-11
ESE	633	6.783E-10	5.188E-10	4.102E-10	3.297E-10	2.720E-10	1.364E-10	8.386E-11	4.138E-11
SE	462	4.951E-10	3.787E-10	3.294E-10	2.647E-10	2.184E-10	9.954E-11	6.121E-11	3.020E-11
SSE	338	3.622E-10	2.770E-10	2.191E-10	1.760E-10	1.452E-10	7.282E-11	4.478E-11	2.209E-11
S	358	3.836E-10	2.934E-10	2.320E-10	1.865E-10	1.538E-10	7.713E-11	4.743E-11	2.340E-11
SSW	450	4.822E-10	3.688E-10	2.916E-10	2.344E-10	1.934E-10	9.695E-11	5.962E-11	2.942E-11
SW	316	3.386E-10	2.590E-10	2.048E-10	1.646E-10	1.358E-10	6.808E-11	4.186E-11	2.066E-11
WSW	196	2.100E-10	1.606E-10	1.397E-10	1.123E-10	9.265E-11	4.223E-11	2.597E-11	1.281E-11
W	82	8.787E-11	6.721E-11	5.314E-11	4.271E-11	3.524E-11	1.767E-11	1.086E-11	5.360E-12
WNW	155	1.827E-10	1.397E-10	1.005E-10	8.073E-11	6.660E-11	3.339E-11	2.053E-11	1.013E-11
NW	179	1.918E-10	1.467E-10	1.160E-10	9.323E-11	7.692E-11	3.857E-11	2.371E-11	1.170E-11
NNW	255	2.733E-10	2.090E-10	1.653E-10	1.328E-10	1.096E-10	5.494E-11	3.378E-11	1.667E-11

AVERAGE 8610 5.777E-10 4.419E-10 3.514E-10 2.824E-10 2.330E-10 1.159E-10 7.129E-11 3.518E-11

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	723	2.905E-11	1.956E-11	1.378E-11	1.033E-11	8.038E-12	6.573E-12	5.458E-12	
NNE	1435	5.765E-11	3.882E-11	2.735E-11	2.051E-11	1.595E-11	1.305E-11	1.083E-11	
NE	1195	4.801E-11	3.232E-11	2.278E-11	1.708E-11	1.328E-11	1.086E-11	9.021E-12	
ENE	856	3.439E-11	2.315E-11	1.631E-11	1.223E-11	9.516E-12	7.783E-12	6.462E-12	
E	977	3.925E-11	2.643E-11	1.862E-11	1.396E-11	1.086E-11	8.883E-12	7.376E-12	
ESE	633	2.543E-11	1.712E-11	1.206E-11	9.046E-12	7.037E-12	5.755E-12	4.779E-12	
SE	462	1.856E-11	1.250E-11	8.805E-12	6.603E-12	5.136E-12	4.200E-12	3.488E-12	
SSE	338	1.358E-11	9.143E-12	6.442E-12	4.830E-12	3.758E-12	3.073E-12	2.552E-12	
S	358	1.438E-11	9.684E-12	6.823E-12	5.116E-12	3.980E-12	3.255E-12	2.703E-12	
SSW	450	1.808E-11	1.217E-11	8.577E-12	6.431E-12	5.003E-12	4.091E-12	3.397E-12	
SW	316	1.270E-11	8.548E-12	6.023E-12	4.516E-12	3.513E-12	2.873E-12	2.386E-12	
WSW	196	7.875E-12	5.302E-12	3.736E-12	2.801E-12	2.179E-12	1.782E-12	1.480E-12	
W	82	3.295E-12	2.218E-12	1.563E-12	1.172E-12	9.116E-13	7.455E-13	6.190E-13	
WNW	155	6.227E-12	4.193E-12	2.954E-12	2.215E-12	1.723E-12	1.409E-12	1.170E-12	
NW	179	7.192E-12	4.842E-12	3.412E-12	2.558E-12	1.990E-12	1.627E-12	1.351E-12	
NNW	255	1.025E-11	6.898E-12	4.860E-12	3.644E-12	2.835E-12	2.318E-12	1.925E-12	

AVERAGE 8610 2.162E-11 1.456E-11 1.026E-11 7.690E-12 5.982E-12 4.892E-12 4.062E-12

Table B-5

Undepleted X/Q Factors for Main Stack

BECO 1st Quarter 1994 General x/q's - elevated

SECTOR AVERAGE MODEL

STACK RELEASE: GROUND-LEVEL AVERAGE CHI/Q BEFORE DEPLETION - (SEC/MB)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	67	3.369E-10	9.268E-09	7.495E-09	6.099E-09	6.264E-09	7.592E-09	8.022E-09	7.769E-09
NNE	149	1.227E-09	3.734E-08	1.754E-08	1.251E-08	1.401E-08	1.810E-08	1.921E-08	1.854E-08
NE	189	1.422E-09	4.944E-08	2.465E-08	1.482E-08	1.495E-08	1.878E-08	2.039E-08	2.008E-08
ENE	210	1.398E-09	4.723E-08	3.090E-08	2.150E-08	2.216E-08	2.734E-08	2.861E-08	2.733E-08
E	347	1.519E-09	4.514E-08	3.204E-08	2.720E-08	3.115E-08	3.988E-08	4.144E-08	3.932E-08
ESE	293	2.592E-09	7.559E-08	3.863E-08	2.843E-08	3.015E-08	3.471E-08	3.451E-08	3.209E-08
SE	167	2.365E-09	7.574E-08	4.599E-08	2.621E-08	2.410E-08	2.932E-08	2.325E-08	2.201E-08
SSE	116	4.129E-09	1.202E-07	7.175E-08	5.438E-08	5.620E-08	4.384E-08	3.399E-08	2.701E-08
S	100	4.566E-09	9.709E-08	8.929E-08	1.215E-07	9.810E-08	7.997E-08	5.962E-08	4.424E-08
SSW	104	3.042E-09	5.031E-08	8.077E-08	1.064E-07	1.457E-07	1.084E-07	6.885E-08	4.876E-08
SW	83	6.433E-09	4.796E-08	5.616E-08	7.699E-08	6.905E-08	5.476E-08	4.071E-08	3.154E-08
WSW	95	7.911E-09	4.694E-08	3.732E-08	3.801E-08	5.037E-08	4.877E-08	3.755E-08	2.966E-08
W	49	2.584E-09	3.080E-08	3.447E-08	3.069E-08	3.148E-08	2.816E-08	2.115E-08	1.742E-08
WNW	28	5.970E-10	8.706E-09	9.609E-09	8.699E-09	1.108E-08	1.217E-08	1.029E-08	9.030E-09
NW	65	1.492E-09	2.015E-08	9.358E-09	6.300E-09	7.135E-09	9.307E-09	9.757E-09	9.303E-09
NNW	56	2.392E-10	6.768E-09	4.277E-09	2.725E-09	3.077E-09	4.873E-09	5.846E-09	6.034E-09
AVERAGE	2118	2.616E-09	4.804E-08	3.689E-08	3.640E-08	3.944E-08	3.537E-08	2.895E-08	2.438E-08
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	67	7.221E-09	6.633E-09	6.080E-09	5.591E-09	5.144E-09	3.568E-09	2.672E-09	1.729E-09
NNE	149	1.714E-08	1.566E-08	1.428E-08	1.307E-08	1.196E-08	8.109E-09	5.959E-09	3.742E-09
NE	189	1.887E-08	1.751E-08	1.620E-08	1.503E-08	1.392E-08	9.838E-09	7.445E-09	4.891E-09
ENE	210	2.510E-08	2.279E-08	2.067E-08	1.882E-08	1.716E-08	1.153E-08	8.432E-09	5.261E-09
E	347	3.589E-08	3.246E-08	2.937E-08	2.670E-08	2.432E-08	1.629E-08	1.188E-08	7.394E-09
ESE	293	2.901E-08	2.613E-08	2.360E-08	2.145E-08	1.954E-08	1.313E-08	9.633E-09	6.070E-09
SE	167	2.006E-08	1.818E-08	1.649E-08	1.504E-08	1.372E-08	9.239E-09	6.768E-09	4.246E-09
SSE	116	2.208E-08	1.850E-08	1.582E-08	1.373E-08	1.206E-08	7.307E-09	5.102E-09	3.160E-09
S	100	3.425E-08	2.764E-08	2.299E-08	1.954E-08	1.687E-08	9.793E-09	6.710E-09	3.959E-09
SSW	104	3.691E-08	2.926E-08	2.399E-08	2.013E-08	1.724E-08	9.710E-09	6.505E-09	3.714E-09
SW	83	2.530E-08	2.088E-08	1.764E-08	1.516E-08	1.322E-08	7.861E-09	5.424E-09	3.197E-09
WSW	95	2.409E-08	2.007E-08	1.707E-08	1.475E-08	1.292E-08	7.772E-09	5.400E-09	3.214E-09
W	49	1.452E-08	1.234E-08	1.065E-08	9.320E-09	8.240E-09	6.145E-09	4.181E-09	2.432E-09
WNW	28	7.835E-09	6.855E-09	6.053E-09	5.394E-09	4.839E-09	2.979E-09	2.383E-09	1.449E-09
NW	65	8.528E-09	7.757E-09	7.058E-09	6.450E-09	5.903E-09	5.201E-09	3.716E-09	2.493E-09
NNW	56	5.802E-09	5.468E-09	5.113E-09	4.781E-09	4.456E-09	3.193E-09	2.615E-09	3.153E-09
AVERAGE	2118	2.079E-08	1.801E-08	1.582E-08	1.406E-08	1.259E-08	8.228E-09	5.927E-09	3.756E-09
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	67	1.264E-09	9.879E-10	8.072E-10	6.814E-10	5.864E-10	7.265E-10	6.388E-10	
NNE	149	2.674E-09	2.057E-09	1.662E-09	1.390E-09	1.185E-09	1.034E-09	9.144E-10	
NE	189	3.606E-09	2.836E-09	2.327E-09	1.971E-09	1.701E-09	1.499E-09	1.336E-09	
ENE	210	3.751E-09	2.936E-09	2.505E-09	2.083E-09	1.769E-09	1.538E-09	1.355E-09	
E	347	5.261E-09	4.035E-09	3.677E-09	3.049E-09	2.584E-09	2.242E-09	1.973E-09	
ESE	293	4.361E-09	3.664E-09	2.957E-09	2.470E-09	2.106E-09	1.837E-09	1.624E-09	
SE	167	3.034E-09	2.640E-09	2.111E-09	1.751E-09	1.483E-09	1.287E-09	1.132E-09	
SSE	116	2.200E-09	1.669E-09	1.339E-09	1.113E-09	9.457E-10	8.227E-10	7.256E-10	
S	100	2.751E-09	2.086E-09	1.675E-09	1.393E-09	1.184E-09	1.030E-09	9.088E-10	
SSW	104	2.526E-09	1.886E-09	1.497E-09	1.234E-09	1.041E-09	8.990E-10	7.882E-10	
SW	83	2.215E-09	1.673E-09	1.337E-09	1.108E-09	9.578E-10	8.287E-10	7.275E-10	
WSW	95	2.234E-09	1.708E-09	1.453E-09	1.199E-09	1.010E-09	8.794E-10	7.695E-10	
W	49	1.670E-09	1.254E-09	9.980E-10	8.245E-10	7.180E-10	6.201E-10	5.433E-10	
WNW	28	1.019E-09	8.140E-10	7.004E-10	5.935E-10	4.996E-10	4.310E-10	3.772E-10	
NW	65	1.741E-09	1.354E-09	1.095E-09	8.879E-10	8.311E-10	7.163E-10	6.264E-10	
NNW	56	2.192E-09	1.660E-09	1.330E-09	1.105E-09	9.365E-10	8.124E-10	7.145E-10	
AVERAGE	2118	2.656E-09	2.079E-09	1.717E-09	1.435E-09	1.221E-09	1.075E-09	9.472E-10	

Table B-5
Undepleted X/Q Factors for Main Stack

BECo 2nd Quarter 1994 General x/q's - elevated

SECTOR AVERAGE MODEL

STACK RELEASE: GROUND-LEVEL AVERAGE CHI/Q BEFORE DEPLETION - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	201	2.801E-09	7.994E-08	4.081E-08	2.798E-08	2.600E-08	2.668E-08	2.523E-08	2.286E-08
NNE	525	4.105E-09	1.220E-07	7.227E-08	5.366E-08	5.610E-08	6.361E-08	6.230E-08	5.723E-08
NE	204	1.611E-09	5.072E-08	2.750E-08	1.786E-08	1.741E-08	1.971E-08	2.019E-08	1.927E-08
NNE	112	1.003E-09	3.629E-08	2.535E-08	1.530E-08	1.250E-08	1.176E-08	1.144E-08	1.067E-08
E	206	1.528E-09	4.581E-08	2.903E-08	1.882E-08	1.667E-08	1.784E-08	1.877E-08	1.835E-08
ESE	152	1.561E-09	4.631E-08	2.316E-08	1.442E-08	1.314E-08	1.380E-08	1.384E-08	1.314E-08
SE	76	1.605E-09	4.984E-08	3.257E-08	2.049E-08	1.676E-08	1.861E-08	1.314E-08	1.220E-08
SSE	76	2.196E-09	5.067E-08	5.642E-08	5.655E-08	5.915E-08	4.598E-08	3.554E-08	2.820E-08
S	94	3.814E-09	7.140E-08	7.347E-08	1.117E-07	9.350E-08	8.644E-08	7.116E-08	5.491E-08
SSW	104	1.016E-08	1.305E-07	8.412E-08	8.678E-08	1.287E-07	1.076E-07	6.928E-08	4.959E-08
SW	54	5.508E-09	4.365E-08	7.206E-08	6.009E-08	4.914E-08	3.662E-08	2.685E-08	2.064E-08
WSW	47	4.199E-09	3.338E-08	4.419E-08	3.622E-08	4.121E-08	3.622E-08	2.719E-08	2.124E-08
W	71	5.021E-09	6.069E-08	4.674E-08	3.744E-08	3.889E-08	3.507E-08	2.670E-08	2.233E-08
WNW	86	3.320E-09	3.987E-08	3.465E-08	3.077E-08	3.659E-08	3.663E-08	2.979E-08	2.555E-08
NW	82	1.430E-09	2.445E-08	1.432E-08	1.348E-08	1.507E-08	1.685E-08	1.602E-08	1.446E-08
NNW	64	3.875E-10	1.288E-08	1.395E-08	1.216E-08	1.107E-08	1.072E-08	1.032E-08	9.552E-09
AVERAGE	2154	3.141E-09	5.620E-08	4.316E-08	3.830E-08	3.950E-08	3.652E-08	2.986E-08	2.501E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	201	2.039E-08	1.816E-08	1.625E-08	1.466E-08	1.325E-08	8.745E-09	6.374E-09	3.991E-09
NNE	525	5.130E-08	4.578E-08	4.099E-08	3.695E-08	3.341E-08	2.197E-08	1.592E-08	9.851E-09
NE	204	1.777E-08	1.628E-08	1.491E-08	1.372E-08	1.262E-08	8.780E-09	6.601E-09	4.311E-09
NNE	112	9.746E-09	8.883E-09	8.119E-09	7.466E-09	6.873E-09	4.323E-09	3.670E-09	2.451E-09
E	206	1.722E-08	1.600E-08	1.484E-08	1.381E-08	1.282E-08	9.149E-09	6.977E-09	4.638E-09
ESE	152	1.215E-08	1.118E-08	1.031E-08	9.546E-09	8.833E-09	6.284E-09	4.816E-09	3.243E-09
SE	76	1.105E-08	9.970E-09	9.015E-09	8.198E-09	7.477E-09	5.072E-09	3.765E-09	2.419E-09
SSE	76	2.296E-08	1.915E-08	1.631E-08	1.411E-08	1.237E-08	7.466E-09	5.190E-09	3.263E-09
S	94	4.287E-08	3.475E-08	2.897E-08	2.463E-08	2.132E-08	1.242E-08	8.517E-09	5.033E-09
SSW	104	3.805E-08	3.048E-08	2.520E-08	2.130E-08	1.833E-08	1.053E-08	7.162E-09	4.182E-09
SW	54	1.649E-08	1.358E-08	1.145E-08	9.826E-09	8.560E-09	5.077E-09	3.522E-09	2.108E-09
WSW	47	1.718E-08	1.431E-08	1.218E-08	1.054E-08	9.244E-09	5.625E-09	3.951E-09	2.391E-09
W	71	1.886E-08	1.620E-08	1.412E-08	1.245E-08	1.108E-08	9.011E-09	6.191E-09	3.638E-09
WNW	86	2.187E-08	1.896E-08	1.525E-08	1.353E-08	1.209E-08	8.139E-09	5.953E-09	3.653E-09
NW	82	1.284E-08	1.139E-08	1.017E-08	9.152E-09	8.273E-09	6.914E-09	4.924E-09	3.363E-09
NNW	64	8.648E-09	7.800E-09	7.051E-09	6.412E-09	5.846E-09	3.940E-09	3.061E-09	2.586E-09
AVERAGE	2154	2.121E-08	1.830E-08	1.595E-08	1.414E-08	1.265E-08	8.371E-09	6.037E-09	3.820E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	201	2.864E-09	2.213E-09	1.796E-09	1.508E-09	1.291E-09	1.380E-09	1.216E-09	
NNE	525	7.006E-09	5.376E-09	4.339E-09	3.626E-09	3.093E-09	2.698E-09	2.387E-09	
NE	204	3.174E-09	2.496E-09	2.049E-09	1.737E-09	1.500E-09	1.322E-09	1.180E-09	
NNE	112	1.835E-09	1.518E-09	1.428E-09	1.214E-09	1.051E-09	9.272E-10	8.285E-10	
E	206	3.444E-09	2.722E-09	2.818E-09	2.373E-09	2.036E-09	1.785E-09	1.585E-09	
ESE	152	2.433E-09	2.263E-09	1.859E-09	1.576E-09	1.361E-09	1.198E-09	1.068E-09	
SE	76	1.764E-09	1.751E-09	1.413E-09	1.180E-09	1.006E-09	8.761E-10	7.735E-10	
SSE	76	2.251E-09	1.694E-09	1.351E-09	1.117E-09	9.437E-10	8.162E-10	7.161E-10	
S	94	3.486E-09	2.637E-09	2.113E-09	1.756E-09	1.489E-09	1.293E-09	1.138E-09	
SSW	104	2.883E-09	2.174E-09	1.738E-09	1.440E-09	1.220E-09	1.057E-09	9.293E-10	
SW	54	1.475E-09	1.123E-09	9.024E-10	7.516E-10	6.487E-10	5.642E-10	4.974E-10	
WSW	47	1.684E-09	1.311E-09	1.209E-09	1.002E-09	8.487E-10	7.617E-10	6.688E-10	
W	71	2.513E-09	1.894E-09	1.512E-09	1.252E-09	1.107E-09	9.556E-10	8.366E-10	
WNW	86	2.595E-09	2.152E-09	2.025E-09	1.808E-09	1.529E-09	1.324E-09	1.163E-09	
NW	82	2.367E-09	1.877E-09	1.536E-09	1.532E-09	1.293E-09	1.116E-09	9.781E-10	
NNW	64	1.771E-09	1.328E-09	1.056E-09	8.719E-10	7.357E-10	6.360E-10	5.578E-10	
AVERAGE	2154	2.722E-09	2.158E-09	1.822E-09	1.546E-09	1.322E-09	1.169E-09	1.033E-09	

Table B-5

Undepleted X/Q Factors for Main Stack

BECO 3rd Quarter 1994 Elevated General x/q's

SECTOR AVERAGE MODEL

STACK RELEASE: GROUND-LEVEL AVERAGE CHI/Q BEFORE DEFLECTION - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	107	8.725E-10	2.839E-08	2.080E-08	1.519E-08	1.484E-08	1.680E-08	1.701E-08	1.600E-08
NNE	464	1.359E-09	4.878E-08	5.200E-08	4.617E-08	5.252E-08	6.721E-08	6.889E-08	6.446E-08
NE	341	1.214E-09	4.756E-08	5.367E-08	4.138E-08	3.850E-08	4.163E-08	4.198E-08	3.951E-08
ENE	192	8.634E-10	3.133E-08	2.792E-08	2.072E-08	1.847E-08	1.938E-08	2.006E-08	1.948E-08
E	194	6.630E-10	2.684E-08	2.075E-08	1.684E-08	1.721E-08	2.037E-08	2.143E-08	2.082E-08
ESE	125	8.507E-10	2.725E-08	1.400E-08	9.992E-09	1.129E-08	1.521E-08	1.646E-08	1.604E-08
SE	85	1.349E-09	6.170E-08	3.800E-08	2.073E-08	1.724E-08	2.001E-08	1.367E-08	1.296E-08
SSE	91	4.098E-09	1.234E-07	7.578E-08	6.340E-08	6.993E-08	5.681E-08	4.496E-08	3.627E-08
S	109	6.140E-09	1.182E-07	9.053E-08	1.405E-07	1.180E-07	1.138E-07	1.002E-07	7.933E-08
SSW	77	3.295E-09	6.536E-08	8.615E-08	1.090E-07	1.529E-07	1.154E-07	7.350E-08	5.207E-08
SW	58	4.846E-09	4.599E-08	6.924E-08	8.273E-08	7.374E-08	5.662E-08	4.103E-08	3.117E-08
WSW	75	4.341E-09	3.369E-08	4.505E-08	6.144E-08	9.265E-08	9.000E-08	6.849E-08	5.353E-08
W	67	1.219E-09	2.175E-08	4.484E-08	4.879E-08	5.256E-08	4.803E-08	3.575E-08	2.906E-08
WNW	96	5.785E-10	7.972E-09	1.819E-08	3.532E-08	5.277E-08	6.009E-08	5.057E-08	4.402E-08
NW	43	2.721E-10	3.699E-11	1.160E-09	2.643E-09	4.424E-09	7.146E-09	7.920E-09	7.793E-09
NNW	42	9.585E-11	3.224E-09	2.064E-09	1.643E-09	2.533E-09	4.896E-09	6.103E-09	6.397E-09
AVERAGE	2166	1.987E-09	4.322E-08	4.125E-08	4.477E-08	4.935E-08	4.708E-08	3.925E-08	3.306E-08
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	107	1.458E-08	1.317E-08	1.190E-08	1.081E-08	9.834E-09	6.591E-09	4.830E-09	3.033E-09
NNE	464	5.825E-08	5.214E-08	4.671E-08	4.207E-08	3.804E-08	2.492E-08	1.794E-08	1.095E-08
NE	341	3.602E-08	3.264E-08	2.961E-08	2.701E-08	2.470E-08	1.683E-08	1.249E-08	8.000E-09
ENE	192	1.825E-08	1.697E-08	1.576E-08	1.468E-08	1.367E-08	9.897E-09	7.654E-09	5.204E-09
E	194	1.945E-08	1.801E-08	1.666E-08	1.547E-08	1.435E-08	1.028E-08	7.884E-09	5.298E-09
ESE	125	1.493E-08	1.374E-08	1.261E-08	1.161E-08	1.069E-08	7.413E-09	5.543E-09	3.580E-09
SE	85	1.186E-08	1.080E-08	9.847E-09	9.021E-09	8.273E-09	5.690E-09	4.246E-09	2.746E-09
SSE	91	2.995E-08	2.533E-08	2.183E-08	1.908E-08	1.688E-08	1.056E-08	7.522E-09	5.163E-09
S	109	6.229E-08	5.071E-08	4.244E-08	3.625E-08	3.148E-08	1.854E-08	1.276E-08	7.552E-09
SSW	77	3.944E-08	3.126E-08	2.562E-08	2.148E-08	1.838E-08	1.034E-08	6.895E-09	3.891E-09
SW	58	2.462E-08	2.008E-08	1.680E-08	1.433E-08	1.242E-08	7.255E-09	4.940E-09	2.850E-09
WSW	75	4.308E-08	3.564E-08	3.014E-08	2.591E-08	2.261E-08	1.345E-08	9.219E-09	5.343E-09
W	67	2.391E-08	2.004E-08	1.710E-08	1.481E-08	1.299E-08	9.369E-09	6.296E-09	3.560E-09
WNW	96	3.796E-08	3.302E-08	2.660E-08	2.360E-08	2.112E-08	1.423E-08	1.030E-08	6.181E-09
NW	43	7.298E-09	6.763E-09	6.254E-09	5.799E-09	5.380E-09	5.683E-09	4.212E-09	3.264E-09
NNW	42	6.198E-09	5.867E-09	5.503E-09	5.157E-09	4.817E-09	3.469E-09	2.849E-09	3.402E-09
AVERAGE	2166	2.801E-08	2.414E-08	2.096E-08	1.857E-08	1.660E-08	1.091E-08	7.849E-09	5.001E-09
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	107	2.179E-09	1.685E-09	1.367E-09	1.148E-09	9.833E-10	1.276E-09	1.127E-09	
NNE	464	7.710E-09	5.874E-09	4.714E-09	3.921E-09	3.331E-09	2.896E-09	2.555E-09	
NE	341	5.822E-09	4.543E-09	3.708E-09	3.129E-09	2.692E-09	2.366E-09	2.107E-09	
ENE	192	3.931E-09	3.286E-09	3.157E-09	2.685E-09	2.325E-09	2.054E-09	1.836E-09	
E	194	3.972E-09	3.162E-09	3.496E-09	2.953E-09	2.542E-09	2.232E-09	1.986E-09	
ESE	125	2.613E-09	2.315E-09	1.881E-09	1.581E-09	1.355E-09	1.186E-09	1.052E-09	
SE	85	2.011E-09	2.141E-09	1.741E-09	1.465E-09	1.256E-09	1.101E-09	9.773E-10	
SSE	91	3.645E-09	2.789E-09	2.249E-09	1.877E-09	1.600E-09	1.393E-09	1.231E-09	
S	109	5.238E-09	3.965E-09	3.180E-09	2.642E-09	2.242E-09	1.944E-09	1.711E-09	
SSW	77	2.632E-09	1.957E-09	1.547E-09	1.271E-09	1.068E-09	9.203E-10	8.051E-10	
SW	58	1.957E-09	1.469E-09	1.169E-09	9.653E-10	8.389E-10	7.259E-10	6.376E-10	
WSW	75	3.665E-09	2.786E-09	2.458E-09	2.016E-09	1.695E-09	1.503E-09	1.313E-09	
W	67	2.409E-09	1.789E-09	1.412E-09	1.158E-09	1.036E-09	8.903E-10	7.771E-10	
WNW	96	4.313E-09	3.455E-09	3.004E-09	2.555E-09	2.141E-09	1.839E-09	1.603E-09	
NW	43	2.353E-09	1.940E-09	1.619E-09	1.799E-09	1.520E-09	1.312E-09	1.150E-09	
NNW	42	2.358E-09	1.781E-09	1.425E-09	1.181E-09	1.000E-09	8.668E-10	7.616E-10	
AVERAGE	2166	3.550E-09	2.809E-09	2.383E-09	2.022E-09	1.726E-09	1.532E-09	1.352E-09	

Table B-5
Undepleted X/Q Factors for Main Stack

BECo 4th Quarter 1994 Elevated General X/Q's
STACK RELEASE: GROUND-LEVEL AVERAGE CHI/Q BEFORE DEPLETION - (SEC/M3) SECTOR AVERAGE MODEL

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	67	4.104E-11	1.494E-09	4.315E-09	5.727E-09	7.004E-09	9.322E-09	9.955E-09	9.653E-09
NNE	230	3.835E-10	1.264E-08	1.441E-08	1.382E-08	1.623E-08	2.265E-08	2.514E-08	2.484E-08
NE	279	1.282E-10	8.087E-09	2.200E-08	2.064E-08	2.060E-08	2.414E-08	2.543E-08	2.465E-08
ENE	150	1.529E-10	8.884E-09	1.764E-08	1.446E-08	1.305E-08	1.437E-08	1.527E-08	1.496E-08
E	251	4.455E-10	1.549E-08	1.130E-08	1.083E-08	1.420E-08	2.120E-08	2.363E-08	2.336E-08
ESE	310	1.691E-09	4.958E-08	3.011E-08	2.488E-08	2.706E-08	3.339E-08	3.478E-08	3.322E-08
SE	211	1.895E-09	5.449E-08	3.072E-08	2.433E-08	2.622E-08	3.376E-08	2.647E-08	2.490E-08
SSE	117	2.367E-09	6.646E-08	5.160E-08	5.244E-08	5.456E-08	4.375E-08	3.555E-08	2.938E-08
S	96	3.854E-09	6.106E-08	6.936E-08	9.986E-08	8.287E-08	7.768E-08	6.867E-08	5.489E-08
SSW	138	3.552E-09	6.094E-08	1.260E-07	1.457E-07	2.069E-07	1.724E-07	1.099E-07	7.802E-08
SW	63	1.654E-09	1.368E-08	3.171E-08	5.625E-08	5.090E-08	4.020E-08	2.984E-08	2.308E-08
WSW	63	7.427E-12	2.948E-09	3.352E-08	4.397E-08	5.762E-08	5.120E-08	3.812E-08	2.947E-08
W	41	2.410E-10	3.021E-09	1.567E-08	2.038E-08	2.299E-08	2.156E-08	1.633E-08	1.345E-08
WNW	49	6.807E-13	9.723E-10	1.156E-08	1.731E-08	2.264E-08	2.280E-08	1.818E-08	1.549E-08
NW	68	5.020E-13	6.444E-10	3.770E-09	6.390E-09	9.493E-09	1.342E-08	1.378E-08	1.285E-08
NNW	70	4.597E-11	2.427E-09	4.293E-09	3.650E-09	4.769E-09	7.907E-09	9.260E-09	9.353E-09
AVERAGE	2203	1.031E-09	2.268E-08	2.987E-08	3.504E-08	3.982E-08	3.811E-08	3.127E-08	2.635E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	67	8.946E-09	8.205E-09	7.515E-09	6.910E-09	6.361E-09	4.412E-09	3.300E-09	2.131E-09
NNE	230	2.322E-08	2.143E-08	1.970E-08	1.817E-08	1.675E-08	1.159E-08	8.615E-09	5.489E-09
NE	279	2.294E-08	2.120E-08	1.958E-08	1.815E-08	1.684E-08	1.203E-08	9.212E-09	6.173E-09
ENE	150	1.403E-08	1.303E-08	1.208E-08	1.123E-08	1.044E-08	7.486E-09	5.732E-09	3.834E-09
E	251	2.189E-08	2.025E-08	1.867E-08	1.726E-08	1.596E-08	1.122E-08	8.455E-09	5.526E-09
ESE	310	3.052E-08	2.784E-08	2.540E-08	2.328E-08	2.135E-08	1.465E-08	1.090E-08	6.998E-09
SE	211	2.272E-08	2.065E-08	1.882E-08	1.725E-08	1.584E-08	1.100E-08	8.283E-09	5.442E-09
SSE	117	2.474E-08	2.124E-08	1.853E-08	1.636E-08	1.459E-08	9.343E-09	6.749E-09	4.737E-09
S	96	4.325E-08	3.529E-08	2.957E-08	2.528E-08	2.197E-08	1.295E-08	8.950E-09	5.345E-09
SSW	138	5.937E-08	4.724E-08	3.884E-08	3.267E-08	2.803E-08	1.594E-08	1.075E-08	6.172E-09
SW	63	1.844E-08	1.517E-08	1.278E-08	1.096E-08	9.543E-09	5.639E-09	3.850E-09	2.220E-09
WSW	63	2.353E-08	1.936E-08	1.630E-08	1.396E-08	1.214E-08	7.141E-09	4.860E-09	2.794E-09
W	41	1.119E-08	9.478E-09	8.160E-09	7.117E-09	6.280E-09	4.652E-09	3.137E-09	1.795E-09
WNW	49	1.322E-08	1.143E-08	1.002E-08	8.871E-09	7.933E-09	4.910E-09	3.948E-09	2.394E-09
NW	68	1.157E-08	1.035E-08	9.287E-09	8.380E-09	7.595E-09	6.332E-09	4.437E-09	2.861E-09
NNW	70	8.854E-09	8.234E-09	7.616E-09	7.054E-09	6.529E-09	4.583E-09	3.682E-09	3.558E-09
AVERAGE	2203	2.240E-08	1.940E-08	1.705E-08	1.518E-08	1.363E-08	8.993E-09	6.553E-09	4.217E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	67	1.556E-09	1.215E-09	9.927E-10	8.378E-10	7.208E-10	9.991E-10	8.813E-10	
NNE	230	3.956E-09	3.059E-09	2.481E-09	2.080E-09	1.778E-09	1.554E-09	1.377E-09	
NE	279	4.612E-09	3.659E-09	3.020E-09	2.571E-09	2.228E-09	1.969E-09	1.761E-09	
ENE	150	2.860E-09	2.354E-09	2.188E-09	1.849E-09	1.592E-09	1.399E-09	1.245E-09	
E	251	4.068E-09	3.197E-09	3.422E-09	2.880E-09	2.471E-09	2.167E-09	1.924E-09	
ESE	310	5.086E-09	4.440E-09	3.601E-09	3.021E-09	2.585E-09	2.262E-09	2.004E-09	
SE	211	4.004E-09	4.207E-09	3.405E-09	2.850E-09	2.433E-09	2.122E-09	1.875E-09	
SSE	117	3.358E-09	2.576E-09	2.081E-09	1.740E-09	1.484E-09	1.292E-09	1.141E-09	
S	96	3.727E-09	2.833E-09	2.280E-09	1.900E-09	1.617E-09	1.406E-09	1.241E-09	
SSW	138	4.209E-09	3.147E-09	2.500E-09	2.060E-09	1.735E-09	1.496E-09	1.309E-09	
SW	63	1.517E-09	1.134E-09	8.986E-10	7.394E-10	6.374E-10	5.485E-10	4.791E-10	
WSW	63	1.903E-09	1.431E-09	1.192E-09	9.753E-10	8.164E-10	7.100E-10	6.186E-10	
W	41	1.219E-09	9.077E-10	7.179E-10	5.898E-10	5.110E-10	4.396E-10	3.837E-10	
WNW	49	1.684E-09	1.375E-09	1.227E-09	1.058E-09	8.871E-10	7.615E-10	6.636E-10	
NW	68	1.967E-09	1.508E-09	1.208E-09	1.070E-09	8.954E-10	7.689E-10	6.701E-10	
NNW	70	2.429E-09	1.815E-09	1.440E-09	1.186E-09	9.980E-10	8.606E-10	7.526E-10	
AVERAGE	2203	3.011E-09	2.429E-09	2.041E-09	1.713E-09	1.462E-09	1.297E-09	1.145E-09	

Table B-5

Undepleted X/Q Factors for Main Stack

BECo 1994 General Elevated X/Q's

SECTOR AVERAGE MODEL

STACK RELEASE: GROUND-LEVEL AVERAGE CHI/Q BEFORE DEPLETION - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	442	1.010E-09	2.970E-08	1.833E-08	1.351E-08	1.352E-08	1.510E-08	1.505E-08	1.407E-08
NNE	1368	1.763E-09	5.522E-08	3.902E-08	3.154E-08	3.472E-08	4.291E-08	4.392E-08	4.130E-08
NE	1013	1.087E-09	3.874E-08	3.196E-08	2.372E-08	2.291E-08	2.611E-08	2.704E-08	2.591E-08
ENE	664	8.479E-10	3.074E-08	2.539E-08	1.796E-08	1.651E-08	1.816E-08	1.878E-08	1.805E-08
E	998	1.033E-09	3.316E-08	2.317E-08	1.834E-08	1.972E-08	2.473E-08	2.623E-08	2.539E-08
ESE	880	1.669E-09	4.955E-08	2.643E-08	1.941E-08	2.039E-08	2.427E-08	2.490E-08	2.363E-08
SE	539	1.531E-09	4.985E-08	3.289E-08	2.146E-08	2.022E-08	2.445E-08	1.915E-08	1.803E-08
SSE	400	2.548E-09	7.197E-08	5.224E-08	5.669E-08	5.996E-08	4.760E-08	3.752E-08	3.023E-08
S	399	4.211E-09	7.934E-08	8.058E-08	1.183E-07	9.809E-08	8.947E-08	7.498E-08	5.841E-08
SSW	423	4.800E-09	7.372E-08	9.447E-08	1.122E-07	1.589E-07	1.263E-07	8.058E-08	5.726E-08
SW	258	4.401E-09	3.605E-08	5.423E-08	6.893E-08	6.063E-08	4.699E-08	3.457E-08	2.658E-08
WSW	280	3.693E-09	2.602E-08	3.829E-08	4.496E-08	6.053E-08	5.660E-08	4.287E-08	3.350E-08
W	228	2.252E-09	2.890E-08	3.370E-08	3.396E-08	3.645E-08	3.318E-08	2.497E-08	2.055E-08
WNW	259	1.119E-09	1.432E-08	1.748E-08	2.169E-08	2.912E-08	3.113E-08	2.558E-08	2.212E-08
NW	258	7.224E-10	1.121E-08	7.118E-09	7.195E-09	9.035E-09	1.170E-08	1.188E-08	1.112E-08
NNW	232	1.910E-10	6.297E-09	6.138E-09	5.041E-09	5.365E-09	7.111E-09	7.897E-09	7.848E-09
AVERAGE	8641	2.055E-09	3.967E-08	3.634E-08	3.843E-08	4.163E-08	3.911E-08	3.225E-08	2.713E-08
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	442	1.279E-08	1.155E-08	1.044E-08	9.494E-09	8.651E-09	5.831E-09	4.296E-09	2.721E-09
NNE	1368	3.751E-08	3.378E-08	3.045E-08	2.759E-08	2.506E-08	1.667E-08	1.212E-08	7.516E-09
NE	1013	2.393E-08	2.194E-08	2.010E-08	1.850E-08	1.704E-08	1.189E-08	8.949E-09	5.853E-09
ENE	664	1.673E-08	1.537E-08	1.412E-08	1.302E-08	1.201E-08	8.417E-09	6.361E-09	4.182E-09
E	998	2.354E-08	2.162E-08	1.984E-08	1.826E-08	1.682E-08	1.171E-08	8.784E-09	5.705E-09
ESE	880	2.166E-08	1.973E-08	1.799E-08	1.648E-08	1.511E-08	1.038E-08	7.729E-09	4.978E-09
SE	539	1.644E-08	1.491E-08	1.356E-08	1.239E-08	1.134E-08	7.758E-09	5.773E-09	3.720E-09
SSE	400	2.495E-08	2.107E-08	1.814E-08	1.584E-08	1.399E-08	8.681E-09	6.151E-09	4.090E-09
S	399	4.572E-08	3.715E-08	3.103E-08	2.646E-08	2.294E-08	1.345E-08	9.249E-09	5.481E-09
SSW	423	4.356E-08	3.465E-08	2.848E-08	2.396E-08	2.055E-08	1.166E-08	7.848E-09	4.502E-09
SW	258	2.118E-08	1.740E-08	1.465E-08	1.255E-08	1.092E-08	6.449E-09	4.427E-09	2.590E-09
WSW	280	2.699E-08	2.235E-08	1.893E-08	1.629E-08	1.423E-08	8.499E-09	5.858E-09	3.436E-09
W	228	1.711E-08	1.450E-08	1.250E-08	1.092E-08	9.639E-09	7.287E-09	4.946E-09	2.853E-09
WNW	259	1.901E-08	1.651E-08	1.450E-08	1.287E-08	1.152E-08	7.070E-09	5.657E-09	3.425E-09
NW	258	1.007E-08	9.077E-09	8.201E-09	7.452E-09	6.794E-09	6.037E-09	4.325E-09	2.997E-09
NNW	232	7.389E-09	6.855E-09	6.332E-09	5.861E-09	5.421E-09	3.803E-09	3.057E-09	3.177E-09
AVERAGE	8641	2.304E-08	1.991E-08	1.745E-08	1.550E-08	1.388E-08	9.098E-09	6.596E-09	4.202E-09
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	442	1.966E-09	1.526E-09	1.241E-09	1.044E-09	8.959E-10	1.097E-09	9.667E-10	
NNE	1368	5.343E-09	4.097E-09	3.303E-09	2.758E-09	2.350E-09	2.048E-09	1.810E-09	
NE	1013	4.310E-09	3.389E-09	2.781E-09	2.356E-09	2.034E-09	1.792E-09	1.599E-09	
ENE	664	3.091E-09	2.522E-09	2.319E-09	1.958E-09	1.684E-09	1.480E-09	1.316E-09	
E	998	4.181E-09	3.275E-09	3.353E-09	2.813E-09	2.408E-09	2.106E-09	1.867E-09	
ESE	880	3.627E-09	3.174E-09	2.578E-09	2.165E-09	1.854E-09	1.623E-09	1.439E-09	
SE	539	2.713E-09	2.693E-09	2.174E-09	1.817E-09	1.549E-09	1.351E-09	1.193E-09	
SSE	400	2.870E-09	2.187E-09	1.759E-09	1.466E-09	1.246E-09	1.084E-09	9.556E-10	
S	399	3.806E-09	2.885E-09	2.316E-09	1.926E-09	1.636E-09	1.421E-09	1.252E-09	
SSW	423	3.071E-09	2.297E-09	1.825E-09	1.505E-09	1.269E-09	1.096E-09	9.605E-10	
SW	258	1.788E-09	1.347E-09	1.075E-09	8.893E-10	7.693E-10	6.656E-10	5.843E-10	
WSW	280	2.371E-09	1.809E-09	1.578E-09	1.298E-09	1.092E-09	9.631E-10	8.421E-10	
W	228	1.950E-09	1.459E-09	1.159E-09	9.549E-10	8.420E-10	7.254E-10	6.343E-10	
WNW	259	2.407E-09	1.953E-09	1.742E-09	1.506E-09	1.266E-09	1.091E-09	9.533E-10	
NW	258	2.108E-09	1.671E-09	1.365E-09	1.148E-09	1.135E-09	9.788E-10	8.564E-10	
NNW	232	2.189E-09	1.647E-09	1.314E-09	1.087E-09	9.181E-10	7.944E-10	6.970E-10	
AVERAGE	8641	2.987E-09	2.371E-09	1.993E-09	1.681E-09	1.434E-09	1.270E-09	1.120E-09	

Table B-6

Depleted X/Q Factors for Main Stack

EECo 1st Quarter 1994 General x/q's - elevated

SECTOR AVERAGE MODEL

STACK RELEASE: GROUND-LEVEL AVERAGE CHI/Q AFTER DEPLETION (MET. AND ATOMIC ENERGY 1968 DEPLETION MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	67	3.369E-10	9.264E-09	7.482E-09	6.081E-09	6.242E-09	7.555E-09	7.955E-09	7.664E-09
NNE	149	1.227E-09	3.732E-08	1.750E-08	1.247E-08	1.396E-08	1.802E-08	1.907E-08	1.834E-08
NE	189	1.422E-09	4.940E-08	2.457E-08	1.476E-08	1.489E-08	1.870E-08	2.024E-08	1.987E-08
ENE	210	1.398E-09	4.720E-08	3.082E-08	2.142E-08	2.208E-08	2.722E-08	2.839E-08	2.700E-08
E	347	1.519E-09	4.511E-08	3.198E-08	2.713E-08	3.106E-08	3.973E-08	4.118E-08	3.895E-08
ESE	293	2.592E-09	7.555E-08	3.853E-08	2.833E-08	3.004E-08	3.456E-08	3.429E-08	3.179E-08
SE	167	2.365E-09	7.568E-08	4.584E-08	2.609E-08	2.401E-08	2.920E-08	2.309E-08	2.178E-08
SSE	116	4.129E-09	1.201E-07	7.147E-08	5.421E-08	5.600E-08	4.353E-08	3.355E-08	2.648E-08
S	100	4.566E-09	9.697E-08	8.874E-08	1.209E-07	9.737E-08	7.872E-08	5.793E-08	4.238E-08
SSW	104	3.042E-09	5.026E-08	8.061E-08	1.062E-07	1.450E-07	1.066E-07	6.703E-08	4.699E-08
SW	83	6.433E-09	4.790E-08	5.601E-08	7.673E-08	6.867E-08	5.409E-08	3.060E-08	3.060E-08
WSW	95	7.911E-09	4.690E-08	3.725E-08	3.792E-08	5.019E-08	4.836E-08	3.698E-08	2.897E-08
W	49	2.584E-09	3.077E-08	3.438E-08	3.058E-08	3.134E-08	2.792E-08	2.084E-08	1.703E-08
WNW	28	5.970E-10	8.700E-09	9.583E-09	8.676E-09	1.104E-08	1.210E-08	1.017E-08	8.870E-09
NW	65	1.492E-09	2.014E-08	9.338E-09	6.283E-09	7.117E-09	9.269E-09	9.679E-09	7.117E-09
NNW	56	2.392E-10	6.765E-09	4.267E-09	2.716E-09	3.069E-09	4.857E-09	5.807E-09	5.966E-09
AVERAGE	2118	2.616E-09	4.800E-08	3.677E-08	3.628E-08	3.826E-08	3.503E-08	2.851E-08	2.387E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	67	7.078E-09	6.457E-09	5.876E-09	5.364E-09	4.899E-09	3.277E-09	2.373E-09	1.447E-09
NNE	149	1.686E-08	1.533E-08	1.390E-08	1.265E-08	1.151E-08	7.588E-09	5.426E-09	3.241E-09
NE	189	1.859E-08	1.717E-08	1.581E-08	1.460E-08	1.345E-08	9.262E-09	6.833E-09	4.276E-09
ENE	210	2.466E-08	2.226E-08	2.006E-08	1.815E-08	1.645E-08	1.071E-08	7.609E-09	4.510E-09
E	347	3.542E-08	3.191E-08	2.874E-08	2.601E-08	2.358E-08	1.543E-08	1.100E-08	6.541E-09
ESE	293	2.863E-08	2.568E-08	2.310E-08	2.090E-08	1.894E-08	1.239E-08	8.857E-09	5.302E-09
SE	167	1.977E-08	1.783E-08	1.609E-08	1.459E-08	1.324E-08	8.659E-09	6.159E-09	3.652E-09
SSE	116	2.148E-08	1.787E-08	1.516E-08	1.306E-08	1.138E-08	6.646E-09	4.485E-09	2.579E-09
S	100	3.239E-08	2.579E-08	2.117E-08	1.776E-08	1.514E-08	8.269E-09	5.355E-09	2.856E-09
SSW	104	3.523E-08	2.767E-08	2.248E-08	1.871E-08	1.588E-08	8.620E-09	5.587E-09	3.015E-09
SW	83	2.431E-08	1.987E-08	1.663E-08	1.416E-08	1.223E-08	6.936E-09	4.577E-09	2.487E-09
WSW	95	2.332E-08	1.925E-08	1.623E-08	1.389E-08	1.206E-08	6.940E-09	4.630E-09	2.564E-09
W	49	1.407E-08	1.184E-08	1.012E-08	8.766E-09	7.670E-09	5.183E-09	3.307E-09	1.708E-09
WNW	28	7.638E-09	6.628E-09	5.804E-09	5.127E-09	4.559E-09	2.671E-09	2.034E-09	1.133E-09
NW	65	8.368E-09	7.564E-09	6.839E-09	6.210E-09	5.646E-09	4.735E-09	3.255E-09	1.973E-09
NNW	56	5.705E-09	5.343E-09	4.964E-09	4.610E-09	4.266E-09	2.946E-09	2.313E-09	2.431E-09
AVERAGE	2118	2.022E-08	1.740E-08	1.519E-08	1.341E-08	1.193E-08	7.517E-09	5.237E-09	3.107E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	67	1.003E-09	7.452E-10	5.800E-10	4.675E-10	3.843E-10	3.959E-10	3.299E-10	
NNE	149	2.211E-09	1.628E-09	1.262E-09	1.017E-09	8.322E-10	6.995E-10	5.968E-10	
NE	189	3.008E-09	2.260E-09	1.773E-09	1.437E-09	1.189E-09	1.004E-09	8.593E-10	
ENE	210	3.072E-09	2.296E-09	1.850E-09	1.478E-09	1.207E-09	1.010E-09	8.586E-10	
E	347	4.463E-09	3.288E-09	2.777E-09	2.212E-09	1.800E-09	1.504E-09	1.275E-09	
ESE	293	3.631E-09	2.852E-09	2.200E-09	1.763E-09	1.443E-09	1.211E-09	1.031E-09	
SE	167	2.477E-09	1.958E-09	1.490E-09	1.180E-09	9.557E-10	7.954E-10	6.725E-10	
SSE	116	1.700E-09	1.228E-09	9.414E-10	7.513E-10	6.138E-10	5.148E-10	4.387E-10	
S	100	1.818E-09	1.277E-09	9.575E-10	7.500E-10	6.032E-10	4.994E-10	4.211E-10	
SSW	104	1.948E-09	1.388E-09	1.054E-09	8.329E-10	6.737E-10	5.594E-10	4.720E-10	
SW	83	1.599E-09	1.129E-09	8.478E-10	6.642E-10	5.320E-10	4.388E-10	3.685E-10	
WSW	95	1.673E-09	1.203E-09	9.250E-10	7.250E-10	5.820E-10	4.646E-10	3.892E-10	
W	49	1.055E-09	7.206E-10	5.266E-10	4.030E-10	2.940E-10	2.242E-10	1.870E-10	
WNW	28	7.334E-10	5.264E-10	3.864E-10	2.581E-10	1.945E-10	1.547E-10	1.287E-10	
NW	65	1.271E-09	9.012E-10	6.712E-10	4.136E-10	3.280E-10	2.681E-10	2.232E-10	
NNW	56	1.547E-09	1.074E-09	7.913E-10	6.060E-10	4.743E-10	3.811E-10	3.114E-10	
AVERAGE	2118	2.076E-09	1.530E-09	1.190E-09	9.348E-10	7.567E-10	6.329E-10	5.352E-10	

Table B-6
Depleted X/Q Factors for Main Stack

RECO 2nd Quarter 1994 General x/q's - elevated
STACK RELEASE: GROUND-LEVEL AVERAGE CHI/Q AFTER DEPLETION (MET. AND ATOMIC ENERGY 1968 DEPLETION MODEL) - (SEC/M3)

		SECTOR AVERAGE MODEL							
		DISTANCE FROM RELEASE POINT (MILES)							
DOWNWIND SECTOR	NO. OBS	.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	201	2.801E-09	7.990E-08	4.072E-08	2.698E-08	2.590E-08	2.654E-08	2.503E-08	2.259E-08
NNE	525	4.105E-09	1.228E-07	7.208E-08	5.348E-08	5.590E-08	6.333E-08	6.188E-08	5.666E-08
NE	204	1.611E-09	5.068E-08	2.742E-08	1.779E-08	1.732E-08	1.960E-08	2.003E-08	1.905E-08
ENE	112	1.003E-09	3.626E-08	2.527E-08	1.522E-08	1.243E-08	1.169E-08	1.135E-08	1.055E-08
E	206	1.528E-09	4.578E-08	2.896E-08	1.874E-08	1.659E-08	1.775E-08	1.864E-08	1.817E-08
ESE	152	1.561E-09	4.628E-08	2.310E-08	1.436E-08	1.307E-08	1.372E-08	1.372E-08	1.290E-08
SE	76	1.605E-09	4.981E-08	3.247E-08	2.039E-08	1.666E-08	1.846E-08	1.296E-08	1.195E-08
SSE	76	2.198E-09	6.065E-08	5.632E-08	5.636E-08	5.881E-08	4.540E-08	3.477E-08	2.731E-08
S	94	3.314E-09	7.104E-08	7.327E-08	1.114E-07	9.322E-08	8.543E-08	6.945E-08	5.288E-08
SSW	104	1.016E-09	1.100E-07	8.350E-08	8.654E-08	1.280E-07	1.055E-07	6.665E-08	4.679E-08
SW	54	5.508E-09	4.182E-08	7.183E-08	5.974E-08	4.875E-08	3.609E-08	2.621E-08	1.994E-08
WSW	47	4.199E-09	3.325E-08	4.410E-08	3.609E-08	4.100E-08	3.582E-08	2.667E-08	2.063E-08
W	71	5.021E-09	6.060E-08	4.661E-08	3.734E-08	3.875E-08	3.480E-08	2.632E-08	2.185E-08
WNW	86	3.320E-09	3.984E-08	3.457E-08	3.069E-08	3.648E-08	3.642E-08	2.946E-08	2.510E-08
NW	82	1.430E-09	2.443E-08	1.430E-08	1.344E-08	1.502E-08	1.675E-08	1.585E-08	1.424E-08
NNW	64	3.875E-10	1.287E-08	1.393E-08	1.211E-08	1.101E-08	1.064E-08	1.020E-08	9.393E-09
AVERAGE	2154	3.141E-09	5.616E-08	4.305E-08	3.817E-08	3.931E-08	3.612E-08	2.932E-08	2.438E-08
		DISTANCE FROM RELEASE POINT (MILES)							
DOWNWIND SECTOR	NO. OBS	3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	201	2.007E-08	1.779E-08	1.585E-08	1.422E-08	1.279E-08	8.221E-09	5.839E-09	3.485E-09
NNE	525	5.061E-08	4.500E-08	4.014E-08	3.604E-08	3.246E-08	2.093E-08	1.488E-08	8.893E-09
NE	204	1.751E-08	1.597E-08	1.456E-08	1.334E-08	1.221E-08	8.296E-09	6.093E-09	3.806E-09
ENE	112	9.998E-09	8.712E-09	7.929E-09	7.260E-09	6.653E-09	4.565E-09	3.397E-09	2.174E-09
E	206	1.698E-08	1.572E-08	1.452E-08	1.344E-08	1.242E-08	8.651E-09	6.437E-09	4.085E-09
ESE	152	1.195E-08	1.095E-08	1.005E-08	9.264E-09	8.534E-09	5.938E-09	4.457E-09	2.885E-09
SE	76	1.074E-08	9.599E-09	8.603E-09	7.754E-09	7.012E-09	4.562E-09	3.260E-09	1.961E-09
SSE	76	2.190E-08	1.814E-08	1.528E-08	1.307E-08	1.134E-08	6.477E-09	4.272E-09	2.373E-09
S	94	4.075E-08	3.260E-08	2.682E-08	2.251E-08	1.922E-08	1.047E-08	6.699E-09	3.443E-09
SSW	104	3.519E-08	2.764E-08	2.240E-08	1.857E-08	1.568E-08	8.235E-09	5.170E-09	2.629E-09
SW	54	1.575E-08	1.282E-08	1.068E-08	9.063E-09	7.802E-09	4.369E-09	2.874E-09	1.567E-09
WSW	47	1.652E-08	1.360E-08	1.145E-08	9.793E-09	8.495E-09	4.887E-09	3.253E-09	1.778E-09
W	71	1.830E-08	1.557E-08	1.345E-08	1.175E-08	1.036E-08	7.678E-09	4.950E-09	2.578E-09
WNW	86	2.134E-08	1.835E-08	1.464E-08	1.288E-08	1.141E-08	7.322E-09	5.119E-09	2.901E-09
NW	82	1.255E-08	1.107E-08	9.811E-09	8.766E-09	7.868E-09	6.261E-09	4.297E-09	2.690E-09
NNW	64	8.449E-09	7.568E-09	6.791E-09	6.129E-09	5.545E-09	3.598E-09	2.686E-09	1.975E-09
AVERAGE	2154	2.052E-08	1.757E-08	1.519E-08	1.337E-08	1.186E-08	7.529E-09	5.230E-09	3.077E-09
		DISTANCE FROM RELEASE POINT (MILES)							
DOWNWIND SECTOR	NO. OBS	20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	201	2.394E-09	1.777E-09	1.388E-09	1.125E-09	9.311E-10	8.490E-10	7.227E-10	
NNE	525	6.120E-09	4.551E-09	3.563E-09	2.891E-09	2.396E-09	2.032E-09	1.749E-09	
NE	204	2.688E-09	2.030E-09	1.602E-09	1.308E-09	1.089E-09	9.260E-10	7.985E-10	
ENE	112	1.562E-09	1.233E-09	1.088E-09	8.847E-10	7.327E-10	6.199E-10	5.315E-10	
E	206	2.900E-09	2.195E-09	2.086E-09	1.676E-09	1.373E-09	1.151E-09	9.787E-10	
ESE	152	2.082E-09	1.819E-09	1.429E-09	1.159E-09	9.571E-10	8.071E-10	6.895E-10	
SE	76	1.347E-09	1.202E-09	9.084E-10	7.131E-10	5.719E-10	4.700E-10	3.925E-10	
SSE	76	1.484E-09	1.021E-09	7.489E-10	5.737E-10	4.510E-10	3.652E-10	3.015E-10	
S	94	2.084E-09	1.389E-09	9.923E-10	7.447E-10	5.765E-10	4.620E-10	3.791E-10	
SSW	104	1.621E-09	1.114E-09	8.227E-10	6.386E-10	5.111E-10	4.222E-10	3.563E-10	
SW	54	1.012E-09	7.168E-10	5.399E-10	4.242E-10	3.393E-10	2.807E-10	2.364E-10	
WSW	47	1.140E-09	8.033E-10	5.899E-10	4.418E-10	3.398E-10	2.462E-10	2.004E-10	
W	71	1.597E-09	1.090E-09	7.951E-10	6.069E-10	4.319E-10	3.214E-10	2.675E-10	
WNW	86	1.917E-09	1.459E-09	1.183E-09	7.287E-10	5.331E-10	4.289E-10	3.528E-10	
NW	82	1.760E-09	1.277E-09	9.591E-10	5.232E-10	4.138E-10	3.377E-10	2.812E-10	
NNW	64	1.261E-09	8.871E-10	6.651E-10	5.199E-10	4.163E-10	3.427E-10	2.870E-10	
AVERAGE	2154	2.060E-09	1.535E-09	1.210E-09	9.349E-10	7.539E-10	6.289E-10	5.328E-10	

Table B-6

Depleted X/Q Factors for Main Stack

BECo 3rd Quarter 1994 Elevated General x/q's
 STACK RELEASE: GROUND-LEVEL AVERAGE CHI/Q AFTER DEPLETION (MET. AND ATOMIC ENERGY 1968 DEPLETION MODEL) - (SEC/M3)

		SECTOR AVERAGE MODEL							
		DISTANCE FROM RELEASE POINT (MILES)							
DOWNWIND SECTOR	NO. OBS	.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	107	8.725E-10	2.838E-08	2.076E-08	1.513E-08	1.477E-08	1.671E-08	1.685E-08	1.577E-08
NNE	464	1.359E-09	4.876E-08	5.189E-08	4.603E-08	5.236E-08	6.693E-08	6.838E-08	6.371E-08
NE	341	1.214E-09	4.753E-08	5.354E-08	4.121E-08	3.831E-08	4.139E-08	4.164E-08	3.904E-08
ENE	192	8.634E-10	3.131E-08	2.785E-08	2.061E-08	1.835E-08	1.922E-08	1.983E-08	1.918E-08
E	194	6.630E-10	2.682E-08	2.068E-08	1.677E-08	1.711E-08	2.022E-08	2.121E-08	2.053E-08
ESE	125	8.507E-10	2.724E-08	1.396E-08	9.951E-09	1.125E-08	1.513E-08	1.631E-08	1.582E-08
SE	85	1.349E-09	6.164E-08	3.784E-08	2.059E-08	1.713E-08	1.986E-08	1.352E-08	1.276E-08
SSE	91	4.098E-09	1.233E-07	7.554E-08	6.321E-08	6.961E-08	5.620E-08	4.410E-08	3.524E-08
S	109	6.140E-09	1.181E-07	9.025E-08	1.401E-07	1.175E-07	1.122E-07	9.759E-08	7.611E-08
SSW	77	3.295E-09	6.528E-08	8.592E-08	1.086E-07	1.519E-07	1.121E-07	6.987E-08	4.836E-08
SW	58	4.846E-09	4.593E-08	6.904E-08	8.239E-08	7.325E-08	5.567E-08	3.978E-08	2.976E-08
WSW	75	4.341E-09	3.366E-08	4.497E-08	6.133E-08	9.232E-08	8.878E-08	6.663E-08	5.124E-08
W	67	1.219E-09	2.173E-08	4.470E-08	4.867E-08	5.239E-08	4.758E-08	3.508E-08	2.820E-08
WNW	96	5.785E-10	7.966E-09	1.817E-08	3.529E-08	5.268E-08	5.971E-08	4.988E-08	4.306E-08
NW	43	2.721E-18	3.699E-11	1.159E-09	2.636E-09	4.409E-09	7.105E-09	7.838E-09	7.668E-09
NNW	42	9.585E-11	3.222E-09	2.058E-09	1.638E-09	2.528E-09	4.879E-09	6.058E-09	6.316E-09
AVERAGE	2166	1.987E-09	4.318E-08	4.115E-08	4.464E-08	4.911E-08	4.648E-08	3.841E-08	3.205E-08
		DISTANCE FROM RELEASE POINT (MILES)							
DOWNWIND SECTOR	NO. OBS	3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	107	1.427E-08	1.280E-08	1.148E-08	1.035E-08	9.348E-09	6.035E-09	4.269E-09	2.516E-09
NNE	464	5.728E-08	5.100E-08	4.544E-08	4.070E-08	3.659E-08	2.330E-08	1.633E-08	9.494E-09
NE	341	3.544E-08	3.197E-08	2.887E-08	2.621E-08	2.386E-08	1.587E-08	1.150E-08	7.055E-09
ENE	192	1.787E-08	1.652E-08	1.525E-08	1.412E-08	1.307E-08	9.168E-09	6.879E-09	4.427E-09
E	194	1.908E-08	1.757E-08	1.616E-08	1.492E-08	1.376E-08	9.554E-09	7.111E-09	4.515E-09
ESE	125	1.464E-08	1.338E-08	1.220E-08	1.115E-08	1.020E-08	6.821E-09	4.927E-09	2.987E-09
SE	85	1.162E-08	1.051E-08	9.518E-09	8.660E-09	7.885E-09	5.224E-09	3.757E-09	2.267E-09
SSE	91	2.881E-08	2.411E-08	2.056E-08	1.779E-08	1.557E-08	9.246E-09	6.263E-09	3.795E-09
S	109	5.881E-08	4.706E-08	3.867E-08	3.242E-08	2.761E-08	1.471E-08	9.167E-09	4.508E-09
SSW	77	3.578E-08	2.772E-08	2.222E-08	1.825E-08	1.529E-08	7.850E-09	4.843E-09	2.408E-09
SW	58	2.314E-08	1.858E-08	1.531E-08	1.287E-08	1.099E-08	6.021E-09	3.879E-09	2.047E-09
WSW	75	4.053E-08	3.294E-08	2.738E-08	2.313E-08	1.984E-08	1.088E-08	6.921E-09	3.518E-09
W	67	2.292E-08	1.898E-08	1.601E-08	1.369E-08	1.187E-08	7.875E-09	5.009E-09	2.569E-09
WNW	96	3.678E-08	3.167E-08	2.526E-08	2.219E-08	1.965E-08	1.251E-08	8.550E-09	4.613E-09
NW	43	7.132E-09	6.562E-09	6.024E-09	5.545E-09	5.107E-09	5.131E-09	3.642E-09	2.526E-09
NNW	42	6.080E-09	5.716E-09	5.321E-09	4.950E-09	4.586E-09	3.166E-09	2.475E-09	2.508E-09
AVERAGE	2166	2.689E-08	2.294E-08	1.973E-08	1.731E-08	1.533E-08	9.585E-09	6.595E-09	3.859E-09
		DISTANCE FROM RELEASE POINT (MILES)							
DOWNWIND SECTOR	NO. OBS	20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	107	1.706E-09	1.250E-09	9.631E-10	7.703E-10	6.295E-10	6.264E-10	5.175E-10	
NNE	464	6.397E-09	4.676E-09	3.608E-09	2.891E-09	2.368E-09	1.989E-09	1.696E-09	
NE	341	4.927E-09	3.695E-09	2.902E-09	2.358E-09	1.955E-09	1.657E-09	1.424E-09	
ENE	192	3.176E-09	2.518E-09	2.268E-09	1.835E-09	1.512E-09	1.272E-09	1.085E-09	
E	194	3.206E-09	2.420E-09	2.417E-09	1.928E-09	1.568E-09	1.304E-09	1.100E-09	
ESE	125	2.056E-09	1.691E-09	1.300E-09	1.036E-09	8.428E-10	7.022E-10	5.936E-10	
SE	85	1.557E-09	1.508E-09	1.150E-09	9.100E-10	7.342E-10	6.063E-10	5.080E-10	
SSE	91	2.404E-09	1.654E-09	1.205E-09	9.148E-10	7.113E-10	5.694E-10	4.647E-10	
S	109	2.656E-09	1.744E-09	1.235E-09	9.224E-10	7.121E-10	5.696E-10	4.668E-10	
SSW	77	1.473E-09	1.007E-09	7.397E-10	5.700E-10	4.517E-10	3.692E-10	3.078E-10	
SW	58	1.304E-09	9.153E-10	6.841E-10	5.335E-10	4.284E-10	3.506E-10	2.921E-10	
WSW	75	2.150E-09	1.460E-09	1.048E-09	7.691E-10	5.796E-10	4.089E-10	3.245E-10	
W	67	1.590E-09	1.086E-09	7.914E-10	6.022E-10	4.201E-10	3.018E-10	2.479E-10	
WNW	96	2.902E-09	2.022E-09	1.417E-09	8.706E-10	6.284E-10	4.920E-10	3.937E-10	
NW	43	1.646E-09	1.194E-09	8.757E-10	3.296E-10	2.444E-10	1.878E-10	1.478E-10	
NNW	42	1.560E-09	1.072E-09	7.775E-10	5.866E-10	4.519E-10	3.574E-10	2.872E-10	
AVERAGE	2166	2.545E-09	1.869E-09	1.461E-09	1.114E-09	8.898E-10	7.352E-10	6.160E-10	

Table B-6

Depleted X/Q Factors for Main Stack

BECo 4th Quarter 1994 Elevated General X/Q's

SECTOR AVERAGE MODEL

STACK RELEASE: GROUND-LEVEL AVERAGE CHI/Q AFTER DEPLETION (MET. AND ATOMIC ENERGY 1968 DEPLETION MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	67	4.104E-11	1.493E-09	4.310E-09	5.710E-09	6.975E-09	9.267E-09	9.867E-09	9.527E-09
NNE	230	3.835E-10	1.263E-08	1.439E-08	1.378E-08	1.618E-08	2.256E-08	2.499E-08	2.461E-08
NE	279	1.282E-10	8.085E-09	2.197E-08	2.056E-08	2.050E-08	2.400E-08	2.522E-08	2.438E-08
NNE	150	1.529E-10	8.879E-09	1.760E-08	1.440E-08	1.298E-08	1.429E-08	1.515E-08	1.478E-08
E	251	4.455E-10	1.548E-08	1.126E-08	1.080E-08	1.416E-08	2.112E-08	2.349E-08	2.316E-08
ESE	310	1.691E-09	4.955E-08	3.005E-08	2.481E-08	2.698E-08	3.325E-08	3.455E-08	3.289E-08
SE	211	1.895E-09	5.446E-08	3.063E-08	2.425E-08	2.614E-08	3.362E-08	2.628E-08	2.463E-08
SSE	117	2.367E-09	6.642E-08	5.142E-08	5.231E-08	5.441E-08	4.348E-08	3.516E-08	2.889E-08
S	96	3.894E-09	6.101E-08	6.915E-08	9.952E-08	8.246E-08	7.678E-08	6.721E-08	5.319E-08
SSW	138	3.552E-09	6.088E-08	1.257E-07	1.453E-07	2.059E-07	1.694E-07	1.064E-07	7.435E-08
SW	63	1.654E-09	1.367E-08	3.168E-08	5.618E-08	5.076E-08	3.980E-08	2.929E-08	2.243E-08
WSW	63	7.427E-12	2.948E-09	3.349E-08	4.392E-08	5.747E-08	5.073E-08	3.741E-08	2.857E-08
W	41	2.410E-10	3.020E-09	1.565E-08	2.034E-08	2.293E-08	2.142E-08	1.612E-08	1.319E-08
WNW	49	6.807E-13	9.722E-10	1.154E-08	1.728E-08	2.259E-08	2.266E-08	1.796E-08	1.520E-08
NW	68	5.020E-13	6.443E-10	3.765E-09	6.376E-09	9.468E-09	1.336E-08	1.366E-08	1.267E-08
NNW	70	4.597E-11	2.426E-09	4.282E-09	3.636E-09	4.756E-09	7.883E-09	9.205E-09	9.260E-09
AVERAGE	2203	1.031E-09	2.266E-08	2.980E-08	3.495E-08	3.966E-08	3.772E-08	3.075E-08	2.573E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	67	8.785E-09	8.014E-09	7.297E-09	6.668E-09	6.100E-09	4.091E-09	2.956E-09	1.784E-09
NNE	230	2.292E-08	2.106E-08	1.927E-08	1.768E-08	1.621E-08	1.091E-08	7.876E-09	4.744E-09
NE	279	2.262E-08	2.082E-08	1.916E-08	1.769E-08	1.635E-08	1.145E-08	8.597E-09	5.538E-09
NNE	150	1.379E-08	1.274E-08	1.174E-08	1.085E-08	1.002E-08	6.941E-09	5.138E-09	3.229E-09
E	251	2.162E-08	1.992E-08	1.830E-08	1.685E-08	1.551E-08	1.066E-08	7.855E-09	4.910E-09
ESE	310	3.008E-08	2.731E-08	2.480E-08	2.262E-08	2.064E-08	1.380E-08	1.001E-08	6.116E-09
SE	211	2.237E-08	2.024E-08	1.836E-08	1.674E-08	1.530E-08	1.035E-08	7.585E-09	4.700E-09
SSE	117	2.416E-08	2.060E-08	1.785E-08	1.563E-08	1.383E-08	8.490E-09	5.863E-09	3.638E-09
S	96	4.149E-08	3.351E-08	2.779E-08	2.350E-08	2.021E-08	1.125E-08	7.295E-09	3.803E-09
SSW	138	5.561E-08	4.347E-08	3.511E-08	2.902E-08	2.446E-08	1.276E-08	7.941E-09	3.949E-09
SW	63	1.774E-08	1.445E-08	1.205E-08	1.022E-08	8.809E-09	4.943E-09	3.210E-09	1.680E-09
WSW	63	2.250E-08	1.824E-08	1.512E-08	1.275E-08	1.091E-08	5.915E-09	3.717E-09	1.840E-09
W	41	1.087E-08	9.128E-09	7.786E-09	6.725E-09	5.876E-09	3.979E-09	2.530E-09	1.299E-09
WNW	49	1.288E-08	1.105E-08	9.602E-09	8.436E-09	7.480E-09	4.407E-09	3.357E-09	1.826E-09
NW	68	1.134E-08	1.009E-08	8.988E-09	8.056E-09	7.253E-09	5.758E-09	3.887E-09	2.287E-09
NNW	70	8.725E-09	8.073E-09	7.427E-09	6.840E-09	6.294E-09	4.282E-09	3.313E-09	2.669E-09
AVERAGE	2203	2.172E-08	1.867E-08	1.629E-08	1.439E-08	1.283E-08	8.125E-09	5.695E-09	3.376E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	67	1.220E-09	8.942E-10	6.860E-10	5.450E-10	4.415E-10	4.680E-10	3.818E-10	
NNE	230	3.246E-09	2.391E-09	1.852E-09	1.488E-09	1.220E-09	1.025E-09	8.744E-10	
NE	279	3.976E-09	3.030E-09	2.401E-09	1.963E-09	1.633E-09	1.386E-09	1.191E-09	
NNE	150	2.274E-09	1.762E-09	1.513E-09	1.213E-09	9.914E-10	8.295E-10	7.039E-10	
E	251	3.457E-09	2.599E-09	2.540E-09	2.033E-09	1.659E-09	1.385E-09	1.172E-09	
ESE	310	4.238E-09	3.449E-09	2.661E-09	2.127E-09	1.735E-09	1.449E-09	1.227E-09	
SE	211	3.262E-09	2.844E-09	2.121E-09	1.645E-09	1.304E-09	1.062E-09	8.797E-10	
SSE	117	2.335E-09	1.630E-09	1.206E-09	9.296E-10	7.344E-10	5.967E-10	4.940E-10	
S	96	2.302E-09	1.524E-09	1.077E-09	7.991E-10	6.110E-10	4.839E-10	3.929E-10	
SSW	138	2.384E-09	1.605E-09	1.164E-09	8.873E-10	6.971E-10	5.662E-10	4.700E-10	
SW	63	1.047E-09	7.176E-10	5.243E-10	4.000E-10	3.097E-10	2.495E-10	2.051E-10	
WSW	63	1.100E-09	7.296E-10	4.996E-10	3.768E-10	2.937E-10	2.304E-10	1.908E-10	
W	41	8.001E-10	5.454E-10	3.980E-10	3.038E-10	2.215E-10	1.674E-10	1.386E-10	
WNW	49	1.150E-09	7.957E-10	5.471E-10	3.384E-10	2.508E-10	2.004E-10	1.638E-10	
NW	68	1.461E-09	1.030E-09	7.638E-10	4.577E-10	3.564E-10	2.864E-10	2.346E-10	
NNW	70	1.653E-09	1.127E-09	8.198E-10	6.222E-10	4.839E-10	3.877E-10	3.162E-10	
AVERAGE	2203	2.244E-09	1.667E-09	1.298E-09	1.008E-09	8.089E-10	6.734E-10	5.648E-10	

Table B-6

Depleted X/Q Factors for Main Stack

BECo 1994 General Elevated X/Q's
 STACK RELEASE: GROUND-LEVEL AVERAGE CHI/Q AFTER DEPLETION (MET. AND ATOMIC ENERGY 1968 DEPLETION MODEL) - (SEC/M3)

		SECTOR AVERAGE MODEL							
		DISTANCE FROM RELEASE POINT (MILES)							
DOWNWIND SECTOR	NO. OBS	.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	442	1.010E-09	2.968E-09	1.829E-08	1.346E-08	1.347E-08	1.502E-08	1.493E-08	1.389E-08
NNE	1368	1.763E-09	5.519E-09	3.893E-08	3.144E-08	3.461E-08	4.273E-08	4.361E-08	4.086E-08
NE	1013	1.087E-09	3.872E-08	3.188E-08	2.362E-08	2.280E-08	2.596E-08	2.682E-08	2.562E-08
ENE	664	8.479E-10	3.072E-08	2.532E-08	1.788E-08	1.642E-08	1.805E-08	1.862E-08	1.782E-08
E	998	1.033E-09	3.314E-08	2.312E-08	1.828E-08	1.965E-08	2.462E-08	2.605E-08	2.513E-08
ESE	880	1.669E-09	4.951E-08	2.636E-08	1.934E-08	2.032E-08	2.416E-08	2.472E-08	2.338E-08
SE	539	1.531E-09	4.982E-08	3.278E-08	2.137E-08	2.013E-08	2.431E-08	1.898E-08	1.779E-08
SSE	400	2.548E-09	7.192E-08	5.207E-08	5.652E-08	5.971E-08	4.716E-08	3.691E-08	2.949E-08
S	399	4.211E-09	7.927E-08	8.027E-08	1.179E-07	9.757E-08	8.829E-08	7.311E-08	5.621E-08
SSW	423	4.800E-09	7.365E-08	9.425E-08	1.119E-07	1.580E-07	1.237E-07	7.769E-08	5.426E-08
SW	258	4.401E-09	3.601E-08	5.408E-08	6.868E-08	6.028E-08	4.636E-08	3.375E-08	2.565E-08
WSW	280	3.693E-09	2.600E-08	3.822E-08	4.486E-08	6.032E-08	5.597E-08	4.195E-08	2.377E-08
W	228	2.252E-09	2.887E-08	3.361E-08	3.387E-08	3.632E-08	3.291E-08	2.457E-08	2.005E-08
WNW	259	1.119E-09	1.431E-08	1.745E-08	2.166E-08	2.905E-08	3.094E-08	2.527E-08	2.168E-08
NW	258	7.224E-10	1.120E-08	7.103E-09	7.176E-09	9.007E-09	1.163E-08	1.177E-08	1.095E-08
NNW	232	1.910E-10	6.293E-09	6.125E-09	5.022E-09	5.342E-09	7.075E-09	7.832E-09	7.748E-09
AVERAGE	8641	2.055E-09	3.964E-08	3.624E-08	3.831E-08	4.144E-08	3.868E-08	3.166E-08	2.643E-08
		DISTANCE FROM RELEASE POINT (MILES)							
DOWNWIND SECTOR	NO. OBS	3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	442	1.256E-08	1.127E-08	1.013E-08	9.153E-09	8.288E-09	5.408E-09	3.861E-09	2.309E-09
NNE	1368	3.695E-08	3.313E-08	2.972E-08	2.679E-08	2.422E-08	1.570E-08	1.114E-08	6.600E-09
NE	1013	2.357E-08	2.151E-08	1.963E-08	1.798E-08	1.649E-08	1.124E-08	8.268E-09	5.177E-09
ENE	664	1.643E-08	1.502E-08	1.371E-08	1.257E-08	1.152E-08	7.831E-09	5.746E-09	3.580E-09
E	998	2.321E-08	2.122E-08	1.938E-08	1.776E-08	1.628E-08	1.105E-08	8.085E-09	5.005E-09
ESE	880	2.133E-08	1.934E-08	1.755E-08	1.599E-08	1.459E-08	9.748E-09	7.068E-09	4.327E-09
SE	539	1.614E-08	1.456E-08	1.316E-08	1.195E-08	1.087E-08	7.208E-09	5.198E-09	3.150E-09
SSE	400	2.413E-08	2.020E-08	1.723E-08	1.491E-08	1.305E-08	7.726E-09	5.229E-09	3.102E-09
S	399	4.342E-08	3.479E-08	2.865E-08	2.408E-08	2.058E-08	1.119E-08	7.140E-09	3.658E-09
SSW	423	4.056E-08	3.171E-08	2.562E-08	2.119E-08	1.787E-08	9.388E-09	5.897E-09	3.005E-09
SW	258	2.021E-08	1.641E-08	1.365E-08	1.156E-08	9.943E-09	5.559E-09	3.629E-09	1.942E-09
WSW	280	2.573E-08	2.102E-08	1.755E-08	1.489E-08	1.283E-08	7.153E-09	4.628E-09	2.423E-09
W	228	1.653E-08	1.387E-08	1.183E-08	1.023E-08	8.935E-09	6.173E-09	3.945E-09	2.036E-09
WNW	259	1.848E-08	1.591E-08	1.385E-08	1.218E-08	1.079E-08	6.288E-09	4.773E-09	2.623E-09
NW	258	9.860E-09	8.829E-09	7.923E-09	7.151E-09	6.474E-09	5.476E-09	3.773E-09	2.371E-09
NNW	232	7.253E-09	6.687E-09	6.137E-09	5.642E-09	5.182E-09	3.504E-09	2.702E-09	2.397E-09
AVERAGE	8641	2.227E-08	1.909E-08	1.661E-08	1.463E-08	1.299E-08	8.165E-09	5.693E-09	3.357E-09
		DISTANCE FROM RELEASE POINT (MILES)							
DOWNWIND SECTOR	NO. OBS	20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	442	1.581E-09	1.167E-09	9.044E-10	7.270E-10	5.967E-10	5.850E-10	4.881E-10	
NNE	1368	4.498E-09	3.315E-09	2.574E-09	2.073E-09	1.706E-09	1.438E-09	1.230E-09	
NE	1013	3.656E-09	2.759E-09	2.173E-09	1.770E-09	1.469E-09	1.246E-09	1.070E-09	
ENE	664	2.518E-09	1.951E-09	1.679E-09	1.352E-09	1.110E-09	9.325E-10	7.943E-10	
E	998	3.502E-09	2.622E-09	2.454E-09	1.961E-09	1.599E-09	1.335E-09	1.131E-09	
ESE	880	3.005E-09	2.456E-09	1.900E-09	1.523E-09	1.246E-09	1.043E-09	8.864E-10	
SE	539	2.165E-09	1.882E-09	1.421E-09	1.114E-09	8.935E-10	7.349E-10	6.143E-10	
SSE	400	1.985E-09	1.386E-09	1.027E-09	7.935E-10	6.284E-10	5.121E-10	4.251E-10	
S	399	2.218E-09	1.485E-09	1.066E-09	8.044E-10	6.258E-10	5.037E-10	4.149E-10	
SSW	423	1.859E-09	1.280E-09	9.456E-10	7.324E-10	5.835E-10	4.792E-10	4.015E-10	
SW	258	1.238E-09	8.677E-10	6.475E-10	5.043E-10	4.013E-10	3.290E-10	2.747E-10	
WSW	280	1.513E-09	1.147E-09	7.638E-10	5.767E-10	4.475E-10	3.365E-10	2.753E-10	
W	228	1.259E-09	8.595E-10	6.271E-10	4.785E-10	3.415E-10	2.534E-10	2.100E-10	
WNW	259	1.678E-09	1.202E-09	8.845E-10	5.494E-10	4.020E-10	3.197E-10	2.600E-10	
NW	258	1.535E-09	1.101E-09	8.178E-10	4.311E-10	3.357E-10	2.700E-10	2.217E-10	
NNW	232	1.508E-09	1.041E-09	7.637E-10	5.838E-10	4.567E-10	3.673E-10	3.005E-10	
AVERAGE	8641	2.232E-09	1.651E-09	1.291E-09	9.985E-10	8.027E-10	6.679E-10	5.624E-10	

Table B-7

Gamma X/Q Factors for Main Stack

BECO 1st Quarter 1994 General x/q's - elevated

STACK RELEASE: AVERAGE GAMMA DILUTION FACTORS (MET. AND ATOMIC ENERGY 1968 FINITE CLOUD SECTOR AVERAGE MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	67	1.842E-07	9.553E-08	4.730E-08	3.085E-08	2.356E-08	1.631E-08	1.257E-08	1.025E-08
NNE	149	3.921E-07	2.081E-07	9.765E-08	6.052E-08	4.669E-08	3.286E-08	2.553E-08	2.085E-08
NE	189	5.328E-07	2.824E-07	1.326E-07	8.136E-08	6.202E-08	4.301E-08	3.328E-08	2.724E-08
ENE	210	5.649E-07	2.988E-07	1.438E-07	9.011E-08	6.873E-08	4.765E-08	3.677E-08	3.002E-08
E	347	7.763E-07	4.048E-07	1.992E-07	1.294E-07	9.949E-08	6.942E-08	5.357E-08	4.360E-08
ESE	293	6.678E-07	3.577E-07	1.658E-07	1.047E-07	8.006E-08	5.542E-08	4.254E-08	3.452E-08
SE	167	6.463E-07	3.472E-07	1.922E-07	1.029E-07	6.803E-08	4.715E-08	2.794E-08	2.276E-08
SSE	116	6.034E-07	3.378E-07	1.595E-07	6.353E-08	4.836E-08	3.114E-08	2.258E-08	1.763E-08
S	100	5.222E-07	2.874E-07	1.365E-07	8.468E-08	6.226E-08	4.267E-08	3.122E-08	2.386E-08
SSW	104	4.600E-07	2.447E-07	1.236E-07	8.385E-08	7.314E-08	4.846E-08	3.339E-08	2.505E-08
SW	83	4.302E-07	2.270E-07	1.199E-07	7.690E-08	5.748E-08	3.819E-08	2.750E-08	2.118E-08
WSW	95	4.559E-07	2.381E-07	1.084E-07	6.388E-08	4.897E-08	3.425E-08	2.494E-08	1.936E-08
W	49	3.217E-07	1.695E-07	9.254E-08	5.022E-08	3.812E-08	2.550E-08	1.715E-08	1.347E-08
WNW	28	1.124E-07	5.872E-08	4.216E-08	2.498E-08	2.075E-08	1.415E-08	9.802E-09	7.847E-09
NW	65	2.051E-07	1.079E-07	5.056E-08	3.153E-08	2.413E-08	1.680E-08	1.297E-08	1.058E-08
NNW	56	1.615E-07	8.317E-08	4.102E-08	2.677E-08	2.044E-08	1.423E-08	1.106E-08	9.097E-09
AVERAGE	2118	4.398E-07	2.343E-07	1.158E-07	6.914E-08	5.264E-08	3.607E-08	2.643E-08	2.108E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	67	8.629E-09	7.429E-09	6.507E-09	5.777E-09	5.184E-09	3.379E-09	2.464E-09	1.554E-09
NNE	149	1.754E-08	1.509E-08	1.320E-08	1.170E-08	1.048E-08	6.784E-09	4.912E-09	3.060E-09
NE	189	2.300E-08	1.987E-08	1.746E-08	1.555E-08	1.400E-08	9.226E-09	6.787E-09	4.341E-09
ENE	210	2.525E-08	2.171E-08	1.897E-08	1.680E-08	1.504E-08	9.702E-09	7.004E-09	4.337E-09
E	347	3.657E-08	3.136E-08	2.737E-08	2.421E-08	2.165E-08	1.392E-08	1.004E-08	6.213E-09
ESE	293	2.890E-08	2.477E-08	2.161E-08	1.912E-08	1.711E-08	1.104E-08	7.993E-09	4.990E-09
SE	167	1.911E-08	1.641E-08	1.434E-08	1.271E-08	1.138E-08	7.366E-09	5.339E-09	3.337E-09
SSE	116	1.435E-08	1.203E-08	1.030E-08	8.972E-09	7.922E-09	4.913E-09	3.485E-09	2.175E-09
S	100	1.903E-08	1.570E-08	1.330E-08	1.147E-08	1.005E-08	6.106E-09	4.284E-09	2.591E-09
SSW	104	1.980E-08	1.622E-08	1.366E-08	1.172E-08	1.022E-08	6.111E-09	4.231E-09	2.502E-09
SW	83	1.703E-08	1.413E-08	1.200E-08	1.038E-08	9.110E-09	5.537E-09	3.868E-09	2.312E-09
WSW	95	1.568E-08	1.309E-08	1.118E-08	9.710E-09	8.556E-09	5.270E-09	3.720E-09	2.261E-09
W	49	1.099E-08	9.225E-09	7.912E-09	6.896E-09	6.092E-09	4.170E-09	2.906E-09	1.737E-09
WNW	28	6.500E-09	5.523E-09	4.784E-09	4.206E-09	3.742E-09	2.218E-09	1.765E-09	1.087E-09
NW	65	8.895E-09	7.648E-09	6.690E-09	5.933E-09	5.318E-09	3.956E-09	2.831E-09	1.832E-09
NNW	56	7.707E-09	6.676E-09	5.881E-09	5.249E-09	4.733E-09	3.136E-09	2.416E-09	2.068E-09
AVERAGE	2118	1.744E-08	1.480E-08	1.282E-08	1.128E-08	1.004E-08	6.427E-09	4.628E-09	2.900E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	67	1.120E-09	8.675E-10	7.058E-10	5.934E-10	5.085E-10	5.333E-10	4.702E-10	
NNE	149	2.183E-09	1.679E-09	1.358E-09	1.136E-09	9.686E-10	8.442E-10	7.455E-10	
NE	189	3.155E-09	2.460E-09	2.010E-09	1.696E-09	1.458E-09	1.279E-09	1.136E-09	
ENE	210	3.083E-09	2.393E-09	2.000E-09	1.665E-09	1.415E-09	1.229E-09	1.082E-09	
E	347	4.416E-09	3.387E-09	2.955E-09	2.459E-09	2.088E-09	1.813E-09	1.596E-09	
ESE	293	3.570E-09	2.902E-09	2.346E-09	1.962E-09	1.674E-09	1.459E-09	1.289E-09	
SE	167	2.386E-09	1.993E-09	1.605E-09	1.337E-09	1.137E-09	9.892E-10	8.720E-10	
SSE	116	1.535E-09	1.174E-09	9.469E-10	7.906E-10	6.737E-10	5.870E-10	5.183E-10	
S	100	1.824E-09	1.394E-09	1.124E-09	9.389E-10	8.002E-10	6.972E-10	6.157E-10	
SSW	104	1.736E-09	1.312E-09	1.049E-09	8.697E-10	7.363E-10	6.378E-10	5.604E-10	
SW	83	1.614E-09	1.224E-09	9.829E-10	8.175E-10	7.023E-10	6.092E-10	5.357E-10	
WSW	95	1.593E-09	1.224E-09	1.021E-09	8.495E-10	7.216E-10	6.300E-10	5.544E-10	
W	49	1.212E-09	9.196E-10	7.382E-10	6.139E-10	5.310E-10	4.608E-10	4.053E-10	
WNW	28	7.715E-10	6.086E-10	5.114E-10	4.323E-10	3.669E-10	3.187E-10	2.805E-10	
NW	65	1.294E-09	1.003E-09	8.123E-10	7.093E-10	6.016E-10	5.219E-10	4.590E-10	
NNW	56	1.465E-09	1.124E-09	9.084E-10	7.596E-10	6.480E-10	5.649E-10	4.990E-10	
AVERAGE	2118	2.060E-09	1.604E-09	1.317E-09	1.102E-09	9.394E-10	8.234E-10	7.262E-10	

Table B-7

Gamma X/Q Factors for Main Stack

RECo 2nd Quarter 1994 General x/q's - elevated

STACK RELEASE: AVERAGE GAMMA DILUTION FACTORS (MET. AND ATOMIC ENERGY 1968 FINITE CLOUD SECTOR AVERAGE MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	201	5.131E-07	2.804E-07	1.255E-07	7.204E-08	5.472E-08	3.749E-08	2.856E-08	2.307E-08
NNE	525	1.156E-06	6.180E-07	2.909E-07	1.780E-07	1.362E-07	9.424E-08	7.217E-08	5.842E-08
NE	204	5.094E-07	2.707E-07	1.269E-07	7.747E-08	5.884E-08	4.043E-08	3.104E-08	2.527E-08
ENE	112	3.187E-07	1.711E-07	8.039E-08	4.777E-08	3.544E-08	2.354E-08	1.778E-08	1.443E-08
E	206	5.163E-07	2.728E-07	1.298E-07	8.017E-08	6.049E-08	4.119E-08	3.155E-08	2.574E-08
ESE	152	3.717E-07	1.997E-07	9.109E-08	5.593E-08	4.225E-08	2.883E-08	2.206E-08	1.794E-08
SE	76	5.741E-07	3.037E-07	1.454E-07	7.523E-08	4.709E-08	3.230E-08	1.763E-08	1.429E-08
SSE	76	7.403E-07	3.876E-07	2.050E-07	7.063E-08	5.492E-08	3.593E-08	2.613E-08	2.027E-08
S	94	5.438E-07	2.918E-07	1.328E-07	9.385E-08	6.868E-08	4.803E-08	3.584E-08	2.771E-08
SSW	104	6.279E-07	3.451E-07	1.334E-07	8.175E-08	7.357E-08	4.907E-08	3.396E-08	2.562E-08
SW	54	3.535E-07	1.879E-07	1.017E-07	5.686E-08	4.102E-08	2.598E-08	1.826E-08	1.393E-08
WSW	47	4.259E-07	2.222E-07	9.635E-08	5.288E-08	3.966E-08	2.720E-08	1.962E-08	1.515E-08
W	71	4.582E-07	2.442E-07	1.346E-07	6.554E-08	4.985E-08	3.357E-08	2.274E-08	1.796E-08
WNW	86	3.269E-07	1.734E-07	1.261E-07	7.239E-08	5.991E-08	4.085E-08	2.838E-08	2.260E-08
NW	82	2.997E-07	1.573E-07	7.532E-08	4.813E-08	3.715E-08	2.584E-08	1.975E-08	1.590E-08
NNW	64	2.021E-07	1.061E-07	5.298E-08	3.425E-08	2.594E-08	1.759E-08	1.332E-08	1.075E-08
AVERAGE	2154	4.961E-07	2.645E-07	1.280E-07	7.268E-08	5.524E-08	3.763E-08	2.742E-08	2.182E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	201	1.925E-08	1.644E-08	1.430E-08	1.262E-08	1.126E-08	7.200E-09	5.181E-09	3.205E-09
NNE	525	4.879E-08	4.169E-08	3.626E-08	3.198E-08	2.853E-08	1.820E-08	1.306E-08	8.032E-09
NE	204	2.125E-08	1.830E-08	1.603E-08	1.424E-08	1.260E-08	8.384E-09	6.147E-09	3.918E-09
ENE	112	1.213E-08	1.045E-08	9.159E-09	8.143E-09	7.320E-09	4.820E-09	3.553E-09	2.866E-09
E	206	2.169E-08	1.872E-08	1.645E-08	1.465E-08	1.319E-08	8.710E-09	6.424E-09	4.134E-09
ESE	152	1.509E-08	1.300E-08	1.141E-08	1.015E-08	9.129E-09	6.019E-09	4.441E-09	2.865E-09
SE	76	1.196E-08	1.025E-08	8.940E-09	7.908E-09	7.075E-09	4.569E-09	3.314E-09	2.077E-09
SSE	76	1.637E-08	1.363E-08	1.162E-08	1.007E-08	8.857E-09	5.413E-09	3.792E-09	2.337E-09
S	94	2.220E-08	1.840E-08	1.563E-08	1.352E-08	1.187E-08	7.259E-09	5.122E-09	3.127E-09
SSW	104	2.038E-08	1.679E-08	1.420E-08	1.223E-08	1.071E-08	6.480E-09	4.537E-09	2.736E-09
SW	54	1.115E-08	9.213E-09	7.805E-09	6.732E-09	5.897E-09	3.552E-09	2.473E-09	1.481E-09
WSW	47	1.222E-08	1.017E-08	8.662E-09	7.510E-09	6.607E-09	4.049E-09	2.852E-09	1.731E-09
W	71	1.473E-08	1.242E-08	1.069E-08	9.347E-09	8.283E-09	5.853E-09	4.112E-09	2.483E-09
WNW	86	1.864E-08	1.579E-08	1.251E-08	1.097E-08	9.751E-09	6.341E-09	4.589E-09	2.829E-09
NW	82	1.322E-08	1.127E-08	9.782E-09	8.618E-09	7.682E-09	5.575E-09	3.959E-09	2.549E-09
NNW	64	8.967E-09	7.663E-09	6.669E-09	5.888E-09	5.258E-09	3.363E-09	2.496E-09	1.821E-09
AVERAGE	2154	1.800E-08	1.526E-08	1.313E-08	1.154E-08	1.026E-08	6.612E-09	4.753E-09	2.976E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	201	2.282E-09	1.753E-09	1.419E-09	1.188E-09	1.014E-09	9.951E-10	8.764E-10	
NNE	525	5.691E-09	4.357E-09	3.515E-09	2.934E-09	2.498E-09	2.174E-09	1.917E-09	
NE	204	2.844E-09	2.217E-09	1.811E-09	1.528E-09	1.314E-09	1.153E-09	1.025E-09	
ENE	112	1.672E-09	1.340E-09	1.179E-09	9.964E-10	8.579E-10	7.534E-10	6.702E-10	
E	206	3.017E-09	2.360E-09	2.196E-09	1.849E-09	1.587E-09	1.390E-09	1.234E-09	
ESE	152	2.096E-09	1.788E-09	1.463E-09	1.235E-09	1.063E-09	9.335E-10	8.300E-10	
SE	76	1.491E-09	1.307E-09	1.057E-09	8.839E-10	7.539E-10	6.569E-10	5.800E-10	
SSE	76	1.629E-09	1.234E-09	9.902E-10	8.229E-10	6.980E-10	6.054E-10	5.323E-10	
S	94	2.211E-09	1.694E-09	1.369E-09	1.145E-09	9.772E-10	8.522E-10	7.532E-10	
SSW	104	1.921E-09	1.465E-09	1.181E-09	9.847E-10	8.382E-10	7.295E-10	6.434E-10	
SW	54	1.035E-09	7.871E-10	6.353E-10	5.307E-10	4.567E-10	3.978E-10	3.511E-10	
WSW	47	1.220E-09	9.404E-10	8.026E-10	6.697E-10	5.703E-10	5.032E-10	4.438E-10	
W	71	1.744E-09	1.329E-09	1.070E-09	8.911E-10	7.766E-10	6.741E-10	5.932E-10	
WNW	86	2.012E-09	1.603E-09	1.380E-09	1.183E-09	1.007E-09	8.765E-10	7.731E-10	
NW	82	1.795E-09	1.394E-09	1.132E-09	1.015E-09	8.613E-10	7.475E-10	6.578E-10	
NNW	64	1.266E-09	9.578E-10	7.682E-10	6.388E-10	5.414E-10	4.697E-10	4.132E-10	
AVERAGE	2154	2.120E-09	1.658E-09	1.373E-09	1.156E-09	9.885E-10	8.695E-10	7.693E-10	

Table B-7

Gamma X/Q Factors for Main Stack

BECO 3rd Quarter 1994 Elevated General x/q's

STACK RELEASE: AVERAGE GAMMA DILUTION FACTORS (MET. AND ATOMIC ENERGY 1968 FINITE CLOUD SECTOR AVERAGE MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	107	3.612E-07	1.902E-07	9.224E-08	5.816E-08	4.415E-08	3.028E-08	2.318E-08	1.884E-08
NNE	464	1.192E-06	6.168E-07	3.113E-07	2.061E-07	1.579E-07	1.096E-07	8.424E-08	6.844E-08
NE	341	9.296E-07	4.837E-07	2.426E-07	1.573E-07	1.185E-07	8.019E-08	6.095E-08	4.942E-08
ENE	192	6.071E-07	3.150E-07	1.558E-07	1.004E-07	7.573E-08	5.137E-08	3.919E-08	3.188E-08
E	194	5.897E-07	3.051E-07	1.508E-07	9.810E-08	7.478E-08	5.148E-08	3.954E-08	3.219E-08
ESE	125	3.680E-07	1.929E-07	9.228E-08	6.078E-08	4.655E-08	3.242E-08	2.509E-08	2.050E-08
SE	85	7.819E-07	4.126E-07	1.832E-07	9.165E-08	5.783E-08	3.952E-08	2.015E-08	1.637E-08
SSE	91	1.239E-06	6.581E-07	3.251E-07	9.276E-08	7.271E-08	4.824E-08	3.553E-08	2.783E-08
S	109	8.089E-07	4.364E-07	1.799E-07	1.267E-07	9.387E-08	6.718E-08	5.109E-08	3.976E-08
SSW	77	5.683E-07	3.034E-07	1.392E-07	9.382E-08	8.219E-08	5.535E-08	3.812E-08	2.856E-08
SW	58	4.678E-07	2.464E-07	1.353E-07	7.987E-08	5.940E-08	3.898E-08	2.781E-08	2.129E-08
WSW	75	9.383E-07	4.805E-07	2.055E-07	1.184E-07	9.196E-08	6.500E-08	4.750E-08	3.690E-08
W	67	4.685E-07	2.420E-07	1.527E-07	8.252E-08	6.104E-08	4.083E-08	2.746E-08	2.160E-08
WNW	96	4.430E-07	2.253E-07	1.866E-07	1.182E-07	9.928E-08	6.897E-08	4.842E-08	3.876E-08
NW	43	2.045E-07	1.030E-07	5.267E-08	3.611E-08	2.785E-08	1.947E-08	1.507E-08	1.229E-08
NNW	42	1.660E-07	8.447E-08	4.239E-08	2.839E-08	2.182E-08	1.533E-08	1.197E-08	9.852E-09
AVERAGE	2166	6.334E-07	3.310E-07	1.655E-07	9.683E-08	7.410E-08	5.089E-08	3.721E-08	2.966E-08
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	107	1.581E-08	1.356E-08	1.184E-08	1.048E-08	9.381E-09	6.058E-09	4.387E-09	2.737E-09
NNE	464	5.731E-08	4.904E-08	4.269E-08	3.767E-08	3.362E-08	2.145E-08	1.537E-08	9.410E-09
NE	341	4.143E-08	3.555E-08	3.106E-08	2.752E-08	2.466E-08	1.601E-08	1.166E-08	7.352E-09
ENE	192	2.683E-08	2.314E-08	2.032E-08	1.809E-08	1.629E-08	1.078E-08	7.971E-09	5.161E-09
E	194	2.709E-08	2.335E-08	2.049E-08	1.823E-08	1.640E-08	1.081E-08	7.966E-09	5.127E-09
ESE	125	1.727E-08	1.488E-08	1.305E-08	1.160E-08	1.042E-08	6.818E-09	4.989E-09	3.166E-09
SE	85	1.375E-08	1.182E-08	1.035E-08	9.189E-09	8.248E-09	5.393E-09	3.949E-09	2.514E-09
SSE	91	2.270E-08	1.905E-08	1.636E-08	1.427E-08	1.262E-08	7.888E-09	5.621E-09	3.615E-09
S	109	3.189E-08	2.645E-08	2.249E-08	1.947E-08	1.713E-08	1.052E-08	7.434E-09	4.533E-09
SSW	77	2.253E-08	1.843E-08	1.549E-08	1.328E-08	1.157E-08	6.889E-09	4.746E-09	2.779E-09
SW	58	1.702E-08	1.405E-08	1.188E-08	1.024E-08	8.954E-09	5.371E-09	3.707E-09	2.169E-09
WSW	75	2.983E-08	2.485E-08	2.118E-08	1.835E-08	1.614E-08	9.862E-09	6.895E-09	4.103E-09
W	67	1.762E-08	1.477E-08	1.264E-08	1.100E-08	9.698E-09	6.540E-09	4.525E-09	2.653E-09
WNW	96	3.205E-08	2.718E-08	2.155E-08	1.891E-08	1.680E-08	1.090E-08	7.849E-09	4.782E-09
NW	43	1.034E-08	8.914E-09	7.821E-09	6.957E-09	6.257E-09	4.952E-09	3.602E-09	2.472E-09
NNW	42	8.352E-09	7.238E-09	6.379E-09	5.695E-09	5.136E-09	3.405E-09	2.622E-09	2.226E-09
AVERAGE	2166	2.449E-08	2.077E-08	1.785E-08	1.568E-08	1.396E-08	8.978E-09	6.456E-09	4.050E-09
DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	107	1.959E-09	1.511E-09	1.225E-09	1.027E-09	8.785E-10	9.325E-10	8.229E-10	
NNE	464	6.643E-09	5.069E-09	4.078E-09	3.395E-09	2.883E-09	2.504E-09	2.204E-09	
NE	341	5.301E-09	4.113E-09	3.350E-09	2.820E-09	2.420E-09	2.120E-09	1.881E-09	
ENE	192	3.788E-09	3.050E-09	2.708E-09	2.291E-09	1.975E-09	1.737E-09	1.546E-09	
E	194	3.747E-09	2.935E-09	2.795E-09	2.357E-09	2.025E-09	1.775E-09	1.576E-09	
ESE	125	2.289E-09	1.910E-09	1.552E-09	1.304E-09	1.116E-09	9.763E-10	8.649E-10	
SE	85	1.824E-09	1.661E-09	1.351E-09	1.135E-09	9.732E-10	8.517E-10	7.551E-10	
SSE	91	2.563E-09	1.966E-09	1.591E-09	1.331E-09	1.136E-09	9.910E-10	8.759E-10	
S	109	3.205E-09	2.456E-09	1.984E-09	1.659E-09	1.415E-09	1.233E-09	1.089E-09	
SSW	77	1.916E-09	1.441E-09	1.148E-09	9.488E-10	8.009E-10	6.920E-10	6.463E-10	
SW	58	1.494E-09	1.123E-09	8.956E-10	7.406E-10	6.326E-10	5.468E-10	4.792E-10	
WSW	75	2.853E-09	2.170E-09	1.805E-09	1.492E-09	1.260E-09	1.101E-09	9.641E-10	
W	67	1.830E-09	1.375E-09	1.093E-09	9.013E-10	7.767E-10	6.695E-10	5.854E-10	
WNW	96	3.370E-09	2.649E-09	2.225E-09	1.878E-09	1.588E-09	1.375E-09	1.206E-09	
NW	43	1.777E-09	1.413E-09	1.162E-09	1.092E-09	9.318E-10	8.117E-10	7.168E-10	
NNW	42	1.575E-09	1.207E-09	9.744E-10	8.142E-10	6.940E-10	6.047E-10	5.338E-10	
AVERAGE	2166	2.883E-09	2.253E-09	1.871E-09	1.574E-09	1.344E-09	1.182E-09	1.044E-09	

Table B-7

Gamma X/Q Factors for Main Stack

BECo 4th Quarter 1994 Elevated General X/Q's

STACK RELEASE: AVERAGE GAMMA DILUTION FACTORS (MET. AND ATOMIC ENERGY 1968 FINITE CLOUD SECTOR AVERAGE MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	67	2.246E-07	1.137E-07	5.835E-08	3.987E-08	3.064E-08	2.127E-08	1.637E-08	1.330E-08
NNE	230	5.292E-07	2.703E-07	1.368E-07	9.166E-08	7.023E-08	4.878E-08	3.766E-08	3.072E-08
NE	279	6.326E-07	3.217E-07	1.656E-07	1.118E-07	8.471E-08	5.771E-08	4.406E-08	3.578E-08
ENE	150	4.014E-07	2.052E-07	1.050E-07	6.989E-08	5.263E-08	3.559E-08	2.712E-08	2.205E-08
E	251	5.919E-07	3.021E-07	1.510E-07	1.005E-07	7.709E-08	5.361E-08	4.139E-08	3.375E-08
ESE	310	7.234E-07	3.770E-07	1.822E-07	1.211E-07	9.247E-08	6.389E-08	4.906E-08	3.985E-08
SE	211	8.248E-07	4.289E-07	2.471E-07	1.412E-07	9.403E-08	6.539E-08	3.869E-08	3.140E-08
SSE	117	6.032E-07	3.205E-07	1.691E-07	7.590E-08	5.839E-08	3.820E-08	2.813E-08	2.219E-08
S	96	4.552E-07	2.428E-07	1.228E-07	6.622E-08	5.362E-08	4.501E-08	3.412E-08	2.655E-08
SSW	138	6.961E-07	3.655E-07	1.850E-07	1.256E-07	1.091E-07	7.420E-08	5.120E-08	3.853E-08
SW	63	2.695E-07	1.386E-07	7.850E-08	5.320E-08	4.010E-08	2.688E-08	1.948E-08	1.506E-08
WSW	63	3.919E-07	1.984E-07	1.020E-07	6.455E-08	4.929E-08	3.410E-08	2.473E-08	1.912E-08
W	41	2.029E-07	1.031E-07	6.194E-08	3.600E-08	2.758E-08	1.864E-08	1.261E-08	9.934E-09
WNW	49	1.778E-07	9.006E-08	6.994E-08	4.410E-08	3.690E-08	2.516E-08	1.734E-08	1.380E-08
NW	68	2.223E-07	1.125E-07	5.818E-08	4.019E-08	3.114E-08	2.184E-08	1.683E-08	1.363E-08
NNW	70	2.060E-07	1.045E-07	5.342E-08	3.608E-08	2.757E-08	1.917E-08	1.487E-08	1.219E-08
AVERAGE	2203	4.470E-07	2.309E-07	1.217E-07	7.736E-08	5.909E-08	4.059E-08	2.960E-08	2.362E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	67	1.116E-08	9.585E-09	8.384E-09	7.437E-09	6.670E-09	4.345E-09	3.171E-09	2.007E-09
NNE	230	2.584E-08	2.225E-08	1.949E-08	1.731E-08	1.553E-08	1.012E-08	7.376E-09	4.649E-09
NE	279	3.005E-08	2.585E-08	2.265E-08	2.013E-08	1.809E-08	1.187E-08	8.720E-09	5.587E-09
ENE	150	1.855E-08	1.598E-08	1.402E-08	1.247E-08	1.122E-08	7.386E-09	5.438E-09	3.493E-09
E	251	2.841E-08	2.448E-08	2.147E-08	1.909E-08	1.716E-08	1.127E-08	8.277E-09	5.289E-09
ESE	310	3.342E-08	2.870E-08	2.509E-08	2.225E-08	1.995E-08	1.297E-08	9.460E-09	5.980E-09
SE	211	2.632E-08	2.259E-08	1.975E-08	1.752E-08	1.571E-08	1.024E-08	7.493E-09	4.766E-09
SSE	117	1.822E-08	1.539E-08	1.328E-08	1.164E-08	1.034E-08	6.559E-09	4.728E-09	3.098E-09
S	96	2.130E-08	1.767E-08	1.503E-08	1.301E-08	1.144E-08	7.024E-09	4.967E-09	3.043E-09
SSW	138	3.056E-08	2.512E-08	2.120E-08	1.824E-08	1.595E-08	9.617E-09	6.703E-09	4.005E-09
SW	63	1.212E-08	1.007E-08	8.564E-09	7.411E-09	6.510E-09	3.968E-09	2.769E-09	1.643E-09
WSW	63	1.542E-08	1.282E-08	1.091E-08	9.443E-09	8.296E-09	5.056E-09	3.531E-09	2.100E-09
W	41	8.122E-09	6.827E-09	5.861E-09	5.111E-09	4.518E-09	3.089E-09	2.153E-09	1.284E-09
WNW	49	1.137E-08	9.615E-09	8.299E-09	7.274E-09	6.459E-09	3.807E-09	3.019E-09	1.842E-09
NW	68	1.138E-08	9.728E-09	8.463E-09	7.467E-09	6.663E-09	4.792E-09	3.390E-09	2.136E-09
NNW	70	1.030E-08	8.893E-09	7.811E-09	6.952E-09	6.252E-09	4.102E-09	3.115E-09	2.424E-09
AVERAGE	2203	1.953E-08	1.660E-08	1.439E-08	1.267E-08	1.130E-08	7.264E-09	5.269E-09	3.334E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	67	1.450E-09	1.126E-09	9.177E-10	7.728E-10	6.634E-10	7.204E-10	6.368E-10	
NNE	230	3.342E-09	2.584E-09	2.099E-09	1.762E-09	1.508E-09	1.318E-09	1.167E-09	
NE	279	4.069E-09	3.179E-09	2.603E-09	2.200E-09	1.895E-09	1.664E-09	1.481E-09	
ENE	150	2.547E-09	2.032E-09	1.772E-09	1.494E-09	1.284E-09	1.126E-09	9.999E-10	
E	251	3.844E-09	2.998E-09	2.808E-09	2.362E-09	2.025E-09	1.773E-09	1.572E-09	
ESE	310	4.314E-09	3.570E-09	2.899E-09	2.434E-09	2.083E-09	1.821E-09	1.613E-09	
SE	211	3.456E-09	3.096E-09	2.513E-09	2.108E-09	1.803E-09	1.575E-09	1.393E-09	
SSE	117	2.216E-09	1.712E-09	1.390E-09	1.167E-09	9.993E-10	8.733E-10	7.733E-10	
S	96	2.158E-09	1.658E-09	1.344E-09	1.127E-09	9.635E-10	8.415E-10	7.449E-10	
SSW	138	2.796E-09	2.122E-09	1.704E-09	1.417E-09	1.203E-09	1.044E-09	9.179E-10	
SW	63	1.140E-09	8.609E-10	6.872E-10	5.685E-10	4.860E-10	4.197E-10	3.676E-10	
WSW	63	1.459E-09	1.107E-09	9.093E-10	7.511E-10	6.337E-10	5.512E-10	4.826E-10	
W	41	8.941E-10	6.769E-10	5.417E-10	4.493E-10	3.870E-10	3.352E-10	2.942E-10	
WNW	49	1.301E-09	1.029E-09	8.719E-10	7.402E-10	6.266E-10	5.424E-10	4.761E-10	
NW	68	1.492E-09	1.144E-09	9.202E-10	7.976E-10	6.696E-10	5.789E-10	5.075E-10	
NNW	70	1.701E-09	1.295E-09	1.040E-09	8.672E-10	7.346E-10	6.379E-10	5.613E-10	
AVERAGE	2203	2.386E-09	1.887E-09	1.564E-09	1.313E-09	1.123E-09	9.888E-10	8.743E-10	

Table B-7

Gamma X/Q Factors for Main Stack

BRCO 1994 General Elevated X/Q's

STACK RELEASE: AVERAGE GAMMA DILUTION FACTORS (MET. AND ATOMIC ENERGY 1968 FINITE CLOUD SECTOR AVERAGE MODEL) - (SEC/M3)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	442	3.212E-07	1.700E-07	8.089E-08	5.027E-08	3.829E-08	2.634E-08	2.017E-08	1.636E-08
NNE	1368	9.195E-07	4.290E-07	2.096E-07	1.344E-07	1.029E-07	7.143E-08	5.492E-08	4.462E-08
NE	1013	6.530E-07	3.403E-07	1.674E-07	1.073E-07	8.126E-08	5.547E-08	4.242E-08	3.449E-08
ENE	664	4.731E-07	2.473E-07	1.212E-07	7.701E-08	5.809E-08	3.948E-08	3.016E-08	2.454E-08
E	998	6.181E-07	3.207E-07	1.575E-07	1.019E-07	7.782E-08	5.380E-08	4.140E-08	3.372E-08
ESE	880	5.331E-07	2.818E-07	1.329E-07	8.569E-08	6.539E-08	4.517E-08	3.471E-08	2.822E-08
SE	539	5.795E-07	3.056E-07	1.742E-07	9.691E-08	6.411E-08	4.429E-08	2.615E-08	2.125E-08
SSE	400	5.969E-07	3.200E-07	1.678E-07	7.568E-08	5.656E-08	3.836E-08	2.808E-08	2.197E-08
S	399	5.305E-07	2.861E-07	1.426E-07	9.759E-08	7.192E-08	5.059E-08	3.798E-08	2.941E-08
SSW	423	5.707E-07	3.050E-07	1.456E-07	9.641E-08	6.411E-08	5.687E-08	3.924E-08	2.950E-08
SW	258	3.648E-07	1.916E-07	1.034E-07	6.635E-08	4.924E-08	3.234E-08	2.315E-08	1.778E-08
WSW	280	4.894E-07	2.520E-07	1.222E-07	7.490E-08	5.740E-08	4.007E-08	2.915E-08	2.260E-08
W	228	3.624E-07	1.893E-07	1.049E-07	5.780E-08	4.397E-08	2.950E-08	1.990E-08	1.567E-08
WNW	259	2.659E-07	1.372E-07	1.004E-07	6.108E-08	5.125E-08	3.522E-08	2.442E-08	1.949E-08
NW	258	2.330E-07	1.201E-07	5.921E-08	3.904E-08	3.010E-08	2.100E-08	1.616E-08	1.311E-08
NNW	232	1.843E-07	9.470E-08	4.753E-08	3.143E-08	2.399E-08	1.660E-08	1.282E-08	1.049E-08
AVERAGE	8641	4.747E-07	2.494E-07	1.273E-07	7.836E-08	5.990E-08	4.103E-08	3.005E-08	2.395E-08

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	442	1.370E-08	1.175E-08	1.025E-08	9.072E-09	8.118E-09	5.242E-09	3.799E-09	2.375E-09
NNE	1368	3.737E-08	3.201E-08	2.791E-08	2.466E-08	2.204E-08	1.414E-08	1.018E-08	6.290E-09
NE	1013	2.898E-08	2.493E-08	2.184E-08	1.939E-08	1.741E-08	1.139E-08	8.339E-09	5.307E-09
ENE	664	2.065E-08	1.778E-08	1.558E-08	1.385E-08	1.244E-08	8.153E-09	5.980E-09	3.814E-09
E	998	2.835E-08	2.440E-08	2.138E-08	1.899E-08	1.705E-08	1.115E-08	8.155E-09	5.179E-09
ESE	880	2.369E-08	2.035E-08	1.780E-08	1.579E-08	1.416E-08	9.219E-09	6.726E-09	4.254E-09
SE	539	1.782E-08	1.530E-08	1.337E-08	1.185E-08	1.062E-08	6.907E-09	5.035E-09	3.182E-09
SSE	400	1.791E-08	1.503E-08	1.289E-08	1.124E-08	9.941E-09	6.200E-09	4.412E-09	2.812E-09
S	399	2.356E-08	1.952E-08	1.658E-08	1.435E-08	1.261E-08	7.721E-09	5.448E-09	3.322E-09
SSW	423	2.336E-08	1.918E-08	1.617E-08	1.390E-08	1.214E-08	7.291E-09	5.066E-09	3.013E-09
SW	258	1.426E-08	1.181E-08	1.002E-08	8.650E-09	7.584E-09	4.587E-09	3.191E-09	1.893E-09
WSW	280	1.826E-08	1.521E-08	1.296E-08	1.124E-08	9.883E-09	6.050E-09	4.242E-09	2.544E-09
W	228	1.291E-08	1.076E-08	9.235E-09	8.053E-09	7.117E-09	4.889E-09	3.408E-09	2.031E-09
WNW	259	1.610E-08	1.364E-08	1.179E-08	1.035E-08	9.196E-09	5.428E-09	4.308E-09	2.637E-09
NW	258	1.097E-08	9.392E-09	8.191E-09	7.244E-09	6.480E-09	4.815E-09	3.443E-09	2.244E-09
NNW	232	8.842E-09	7.627E-09	6.692E-09	5.952E-09	5.350E-09	3.505E-09	2.664E-09	2.133E-09
AVERAGE	8641	1.979E-08	1.679E-08	1.454E-08	1.279E-08	1.138E-08	7.293E-09	5.275E-09	3.314E-09

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	442	1.702E-09	1.314E-09	1.067E-09	8.954E-10	7.662E-10	7.954E-10	7.017E-10	
NNE	1368	4.467E-09	3.424E-09	2.764E-09	2.308E-09	1.966E-09	1.711E-09	1.510E-09	
NE	1013	3.848E-09	2.975E-09	2.447E-09	2.064E-09	1.774E-09	1.557E-09	1.383E-09	
ENE	664	2.769E-09	2.202E-09	1.913E-09	1.611E-09	1.382E-09	1.211E-09	1.074E-09	
E	998	3.748E-09	2.915E-09	2.685E-09	2.254E-09	1.929E-09	1.686E-09	1.493E-09	
ESE	880	3.071E-09	2.545E-09	2.067E-09	1.736E-09	1.486E-09	1.299E-09	1.151E-09	
SE	539	2.296E-09	2.022E-09	1.638E-09	1.372E-09	1.172E-09	1.022E-09	9.039E-10	
SSE	400	1.990E-09	1.525E-09	1.233E-09	1.031E-09	8.793E-10	7.664E-10	6.769E-10	
S	399	2.349E-09	1.801E-09	1.456E-09	1.218E-09	1.039E-09	9.063E-10	8.010E-10	
SSW	423	2.098E-09	1.589E-09	1.274E-09	1.058E-09	8.970E-10	7.779E-10	6.839E-10	
SW	258	1.316E-09	9.948E-10	7.972E-10	6.618E-10	5.672E-10	4.915E-10	4.318E-10	
WSW	280	1.778E-09	1.358E-09	1.132E-09	9.385E-10	7.945E-10	6.946E-10	6.098E-10	
W	228	1.414E-09	1.071E-09	8.571E-10	7.110E-10	6.152E-10	5.327E-10	4.676E-10	
WNW	259	1.865E-09	1.473E-09	1.247E-09	1.059E-09	8.976E-10	7.783E-10	6.841E-10	
NW	258	1.587E-09	1.237E-09	1.005E-09	9.002E-10	7.644E-10	6.636E-10	5.840E-10	
NNW	232	1.500E-09	1.145E-09	9.221E-10	7.687E-10	6.540E-10	5.688E-10	5.014E-10	
AVERAGE	8641	2.362E-09	1.851E-09	1.532E-09	1.287E-09	1.099E-09	9.664E-10	8.536E-10	

Table B-8

Deposition D/Q Factors for Main Stack

BECO 1st Quarter 1994 General x/q's - elevated

SECTOR AVERAGE MODEL

STACK RELEASE: AVERAGE DEPOSITION RATES (DEPLETED CHI/Q * DEF. VELOCITY MODEL - MET. AND ATOMIC ENERGY 1968) - (1/M2)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	67	3.369E-12	9.264E-11	7.482E-11	6.081E-11	6.242E-11	7.555E-11	7.955E-11	7.664E-11
NNE	149	1.227E-11	3.732E-10	1.750E-10	1.247E-10	1.396E-10	1.802E-10	1.907E-10	1.834E-10
NE	189	1.422E-11	4.940E-10	2.457E-10	1.476E-10	1.489E-10	1.870E-10	2.024E-10	1.987E-10
ENE	210	1.398E-11	4.720E-10	3.082E-10	2.142E-10	2.208E-10	2.722E-10	2.839E-10	2.700E-10
E	347	1.519E-11	4.511E-10	3.198E-10	2.713E-10	3.106E-10	3.973E-10	4.118E-10	3.895E-10
ESE	293	2.592E-11	7.555E-10	3.853E-10	2.833E-10	3.004E-10	3.456E-10	3.429E-10	3.179E-10
SE	167	2.365E-11	7.568E-10	4.584E-10	2.609E-10	2.401E-10	2.920E-10	2.309E-10	2.178E-10
SSE	116	4.129E-11	1.201E-09	7.147E-10	5.421E-10	5.600E-10	4.353E-10	3.355E-10	2.648E-10
S	100	4.566E-11	9.697E-10	8.874E-10	1.209E-09	9.737E-10	7.872E-10	5.793E-10	4.238E-10
SSW	104	3.042E-11	5.026E-10	8.061E-10	1.062E-09	1.450E-09	1.066E-09	6.703E-10	4.699E-10
SW	83	6.433E-11	4.790E-10	5.601E-10	7.673E-10	6.867E-10	5.409E-10	3.987E-10	3.060E-10
WSW	95	7.911E-11	4.690E-10	3.725E-10	3.792E-10	5.019E-10	4.836E-10	3.698E-10	2.897E-10
W	49	2.584E-11	3.077E-10	3.438E-10	3.058E-10	3.134E-10	2.792E-10	2.084E-10	1.703E-10
WNW	28	5.970E-12	8.700E-11	9.583E-11	8.676E-11	1.104E-10	1.210E-10	1.017E-10	8.870E-11
NW	65	1.492E-11	2.014E-10	9.338E-11	6.283E-11	7.117E-11	9.269E-11	9.679E-11	9.182E-11
NNW	56	2.392E-12	6.765E-11	4.267E-11	2.716E-11	3.069E-11	4.857E-11	5.807E-11	5.966E-11
AVERAGE	2118	2.616E-11	4.800E-10	3.677E-10	3.628E-10	3.826E-10	3.503E-10	2.851E-10	2.387E-10

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	67	7.078E-11	6.457E-11	5.876E-11	5.364E-11	4.899E-11	3.277E-11	2.373E-11	1.447E-11
NNE	149	1.686E-10	1.533E-10	1.390E-10	1.265E-10	1.151E-10	7.588E-11	5.426E-11	3.241E-11
NE	189	1.859E-10	1.717E-10	1.581E-10	1.460E-10	1.345E-10	9.262E-11	6.833E-11	4.276E-11
ENE	210	2.466E-10	2.226E-10	2.006E-10	1.815E-10	1.645E-10	1.071E-10	7.609E-11	4.510E-11
E	347	3.542E-10	3.191E-10	2.874E-10	2.601E-10	2.359E-10	1.543E-10	1.100E-10	6.541E-11
ESE	293	2.863E-10	2.568E-10	2.310E-10	2.090E-10	1.894E-10	1.239E-10	8.857E-11	5.302E-11
SE	167	1.977E-10	1.783E-10	1.609E-10	1.459E-10	1.324E-10	8.659E-11	6.159E-11	3.652E-11
SSE	116	2.148E-10	1.787E-10	1.516E-10	1.306E-10	1.138E-10	6.646E-11	4.485E-11	2.579E-11
S	100	3.239E-10	2.579E-10	2.117E-10	1.776E-10	1.514E-10	8.269E-11	5.355E-11	2.856E-11
SSW	104	3.523E-10	2.767E-10	2.248E-10	1.871E-10	1.589E-10	8.620E-11	5.587E-11	3.015E-11
SW	83	2.431E-10	1.987E-10	1.663E-10	1.416E-10	1.223E-10	6.936E-11	4.577E-11	2.487E-11
WSW	95	2.332E-10	1.925E-10	1.623E-10	1.389E-10	1.206E-10	6.940E-11	4.630E-11	2.564E-11
W	49	1.407E-10	1.184E-10	1.012E-10	8.766E-11	7.670E-11	5.183E-11	3.307E-11	1.708E-11
WNW	28	7.638E-11	6.628E-11	5.804E-11	5.127E-11	4.559E-11	2.671E-11	2.034E-11	1.133E-11
NW	65	8.368E-11	7.564E-11	6.839E-11	6.210E-11	5.646E-11	4.735E-11	3.255E-11	1.973E-11
NNW	56	5.705E-11	5.343E-11	4.964E-11	4.610E-11	4.266E-11	2.946E-11	2.313E-11	2.431E-11
AVERAGE	2118	2.022E-10	1.740E-10	1.519E-10	1.341E-10	1.193E-10	7.517E-11	5.237E-11	3.107E-11

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	67	1.003E-11	7.452E-12	5.800E-12	4.675E-12	3.843E-12	3.959E-12	3.299E-12	
NNE	149	2.211E-11	1.628E-11	1.262E-11	1.014E-11	8.322E-12	6.995E-12	5.968E-12	
NE	189	3.008E-11	2.260E-11	1.773E-11	1.438E-11	1.189E-11	1.004E-11	8.593E-12	
ENE	210	3.072E-11	2.296E-11	1.850E-11	1.478E-11	1.207E-11	1.010E-11	8.586E-12	
E	347	4.463E-11	3.288E-11	2.777E-11	2.212E-11	1.800E-11	1.504E-11	1.275E-11	
ESE	293	3.631E-11	2.852E-11	2.200E-11	1.763E-11	1.443E-11	1.211E-11	1.031E-11	
SE	167	2.477E-11	1.958E-11	1.490E-11	1.180E-11	9.559E-12	7.954E-12	6.725E-12	
SSE	116	1.700E-11	1.228E-11	9.414E-12	7.513E-12	6.138E-12	5.148E-12	4.387E-12	
S	100	1.818E-11	1.277E-11	9.575E-12	7.500E-12	6.032E-12	4.994E-12	4.211E-12	
SSW	104	1.948E-11	1.388E-11	1.054E-11	8.329E-12	6.737E-12	5.594E-12	4.720E-12	
SW	83	1.599E-11	1.129E-11	8.478E-12	6.642E-12	5.320E-12	4.388E-12	3.695E-12	
WSW	95	1.673E-11	1.203E-11	9.250E-12	7.250E-12	5.820E-12	4.646E-12	3.892E-12	
W	49	1.055E-11	7.206E-12	5.265E-12	4.030E-12	2.940E-12	2.242E-12	1.870E-12	
WNW	28	7.334E-12	5.264E-12	3.864E-12	2.581E-12	1.945E-12	1.567E-12	1.287E-12	
NW	65	1.271E-11	9.012E-12	6.712E-12	4.136E-12	3.280E-12	2.681E-12	2.232E-12	
NNW	56	1.547E-11	1.074E-11	7.913E-12	6.060E-12	4.743E-12	3.811E-12	3.114E-12	
AVERAGE	2118	2.076E-11	1.530E-11	1.190E-11	9.348E-12	7.567E-12	6.329E-12	5.352E-12	

Table B-8

Deposition D/Q Factors for Main Stack

BECo 2nd Quarter 1994 General x/q's - elevated
 STACK RELEASE: AVERAGE DEPOSITION RATES (DEPLETED CHI/Q * DEP. VELOCITY MODEL - MET. AND ATOMIC ENERGY 1968) - (1/M2)

SECTOR AVERAGE MODEL

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	201	2.801E-11	7.990E-10	4.072E-10	2.698E-10	2.590E-10	2.654E-10	2.503E-10	2.259E-10
NNE	525	4.105E-11	1.228E-09	7.208E-10	5.348E-10	5.590E-10	6.333E-10	6.188E-10	5.666E-10
NE	204	1.611E-11	5.068E-10	2.742E-10	1.779E-10	1.732E-10	1.960E-10	2.003E-10	1.905E-10
ENE	112	1.003E-11	3.626E-10	2.527E-10	1.522E-10	1.243E-10	1.169E-10	1.135E-10	1.055E-10
E	206	1.528E-11	4.578E-10	2.896E-10	1.874E-10	1.659E-10	1.775E-10	1.864E-10	1.817E-10
ESE	152	1.561E-11	4.628E-10	2.310E-10	1.436E-10	1.307E-10	1.372E-10	1.372E-10	1.296E-10
SE	76	1.605E-11	4.981E-10	3.247E-10	2.039E-10	1.666E-10	1.846E-10	1.296E-10	1.195E-10
SSE	76	2.196E-11	5.065E-10	5.632E-10	5.636E-10	5.881E-10	4.540E-10	3.477E-10	2.731E-10
S	94	3.814E-11	7.134E-10	7.327E-10	1.114E-09	9.322E-10	8.543E-10	6.945E-10	5.288E-10
SSW	104	1.016E-10	1.304E-09	8.390E-10	8.654E-10	1.280E-09	1.055E-09	6.665E-10	4.679E-10
SW	54	5.508E-11	4.362E-10	7.183E-10	5.974E-10	4.875E-10	3.609E-10	2.621E-10	1.994E-10
WSW	47	4.199E-11	3.335E-10	4.410E-10	3.609E-10	4.100E-10	3.582E-10	2.667E-10	2.063E-10
W	71	5.021E-11	6.063E-10	4.661E-10	3.734E-10	3.875E-10	3.480E-10	2.632E-10	2.185E-10
WNW	86	3.320E-11	3.984E-10	3.457E-10	3.069E-10	3.648E-10	3.642E-10	2.946E-10	2.510E-10
NW	82	1.430E-11	2.443E-10	1.430E-10	1.344E-10	1.502E-10	1.675E-10	1.585E-10	1.424E-10
NNW	64	3.875E-12	1.287E-10	1.393E-10	1.211E-10	1.101E-10	1.064E-10	1.020E-10	9.393E-11
AVERAGE	2154	3.141E-11	5.616E-10	4.305E-10	3.817E-10	3.931E-10	3.612E-10	2.932E-10	2.438E-10

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	201	2.007E-10	1.779E-10	1.585E-10	1.422E-10	1.279E-10	8.221E-11	5.839E-11	3.485E-11
NNE	525	5.061E-10	4.500E-10	4.014E-10	3.604E-10	3.246E-10	2.093E-10	1.488E-10	8.893E-11
NE	204	1.751E-10	1.597E-10	1.456E-10	1.334E-10	1.221E-10	8.296E-11	6.093E-11	3.806E-11
ENE	112	9.598E-11	8.712E-11	7.929E-11	7.260E-11	6.653E-11	4.565E-11	3.397E-11	2.174E-11
E	206	1.698E-10	1.572E-10	1.452E-10	1.344E-10	1.242E-10	8.651E-11	6.437E-11	4.085E-11
ESE	152	1.195E-10	1.095E-10	1.005E-10	9.264E-11	8.534E-11	5.938E-11	4.457E-11	2.885E-11
SE	76	1.074E-10	9.599E-11	8.603E-11	7.756E-11	7.012E-11	4.562E-11	3.260E-11	1.961E-11
SSE	76	2.198E-10	1.814E-10	1.528E-10	1.307E-10	1.134E-10	6.477E-11	4.272E-11	2.373E-11
S	94	4.075E-10	3.260E-10	2.682E-10	2.251E-10	1.922E-10	1.047E-10	6.699E-11	3.443E-11
SSW	104	3.519E-10	2.764E-10	2.240E-10	1.857E-10	1.568E-10	8.235E-11	5.170E-11	2.629E-11
SW	54	1.575E-10	1.282E-10	1.068E-10	9.063E-11	7.802E-11	4.369E-11	2.874E-11	1.567E-11
WSW	47	1.652E-10	1.360E-10	1.145E-10	9.793E-11	8.495E-11	4.887E-11	3.253E-11	1.778E-11
W	71	1.830E-10	1.557E-10	1.345E-10	1.175E-10	1.036E-10	7.678E-11	4.950E-11	2.578E-11
WNW	86	2.134E-10	1.835E-10	1.464E-10	1.288E-10	1.141E-10	7.322E-11	5.119E-11	2.901E-11
NW	82	1.255E-10	1.107E-10	9.811E-11	8.766E-11	7.868E-11	6.261E-11	4.297E-11	2.690E-11
NNW	64	8.449E-11	7.568E-11	6.791E-11	6.129E-11	5.545E-11	3.598E-11	2.686E-11	1.975E-11
AVERAGE	2154	2.052E-10	1.757E-10	1.519E-10	1.337E-10	1.186E-10	7.529E-11	5.230E-11	3.077E-11

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	201	2.394E-11	1.777E-11	1.388E-11	1.125E-11	9.311E-12	8.490E-12	7.227E-12	
NNE	525	6.120E-11	4.551E-11	3.563E-11	2.891E-11	2.396E-11	2.032E-11	1.749E-11	
NE	204	2.688E-11	2.030E-11	1.602E-11	1.308E-11	1.089E-11	9.260E-12	7.985E-12	
ENE	112	1.562E-11	1.233E-11	1.088E-11	8.847E-12	7.327E-12	6.199E-12	5.315E-12	
E	206	2.900E-11	2.195E-11	2.086E-11	1.676E-11	1.373E-11	1.151E-11	9.787E-12	
ESE	152	2.082E-11	1.819E-11	1.429E-11	1.159E-11	9.571E-12	8.071E-12	6.895E-12	
SE	76	1.347E-11	1.202E-11	9.084E-12	7.131E-12	5.719E-12	4.700E-12	3.925E-12	
SSE	76	1.484E-11	1.021E-11	7.489E-12	5.737E-12	4.510E-12	3.652E-12	3.015E-12	
S	94	2.084E-11	1.389E-11	9.923E-12	7.447E-12	5.765E-12	4.620E-12	3.791E-12	
SSW	104	1.621E-11	1.114E-11	8.227E-12	6.386E-12	5.111E-12	4.222E-12	3.563E-12	
SW	54	1.012E-11	7.168E-12	5.399E-12	4.242E-12	3.393E-12	2.807E-12	2.364E-12	
WSW	47	1.140E-11	8.033E-12	5.899E-12	4.418E-12	3.398E-12	2.462E-12	2.004E-12	
W	71	1.597E-11	1.090E-11	7.951E-12	6.069E-12	4.319E-12	3.214E-12	2.675E-12	
WNW	86	1.917E-11	1.459E-11	1.183E-11	7.287E-12	5.331E-12	4.289E-12	3.528E-12	
NW	82	1.760E-11	1.277E-11	9.591E-12	5.232E-12	4.138E-12	3.377E-12	2.812E-12	
NNW	64	1.261E-11	8.871E-12	6.651E-12	5.199E-12	4.163E-12	3.427E-12	2.870E-12	
AVERAGE	2154	2.060E-11	1.535E-11	1.210E-11	9.349E-12	7.539E-12	6.289E-12	5.328E-12	

Table B-8

Deposition D/Q Factors for Main Stack

RECo 3rd Quarter 1994 Elevated General x/q's
 STACK RELEASE: AVERAGE DEPOSITION RATES (DEPLETED CHI/Q * DEP. VELOCITY MODEL - MET. AND ATOMIC ENERGY 1968) - (1/M2)

SECTOR AVERAGE MODEL

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	107	8.725E-12	2.838E-10	2.076E-10	1.513E-10	1.477E-10	1.671E-10	1.685E-10	1.577E-10
NNE	464	1.359E-11	4.876E-10	5.189E-10	4.603E-10	5.236E-10	6.693E-10	6.838E-10	6.371E-10
NE	341	1.214E-11	4.753E-10	5.354E-10	4.121E-10	3.831E-10	4.139E-10	4.164E-10	3.904E-10
NNE	192	8.634E-12	3.131E-10	2.785E-10	2.061E-10	1.835E-10	1.922E-10	1.983E-10	1.918E-10
E	194	6.630E-12	2.682E-10	2.068E-10	1.677E-10	1.711E-10	2.022E-10	2.121E-10	2.053E-10
ESE	125	8.507E-12	2.724E-10	1.396E-10	9.951E-11	1.125E-10	1.513E-10	1.631E-10	1.582E-10
SE	85	1.349E-11	6.164E-10	3.784E-10	2.059E-10	1.713E-10	1.986E-10	1.352E-10	1.276E-10
SSE	91	4.098E-11	1.233E-09	7.554E-10	6.321E-10	6.961E-10	5.620E-10	4.410E-10	3.524E-10
S	109	6.140E-11	1.181E-09	9.025E-10	1.401E-09	1.175E-09	1.122E-09	9.759E-10	7.611E-10
SSW	77	3.295E-11	6.528E-10	8.592E-10	1.086E-09	1.519E-09	1.121E-09	6.987E-10	4.836E-10
SW	58	4.846E-11	4.593E-10	6.904E-10	8.239E-10	7.325E-10	5.567E-10	3.978E-10	2.976E-10
WSW	75	4.341E-11	3.366E-10	4.497E-10	6.133E-10	9.232E-10	8.878E-10	6.663E-10	5.124E-10
W	67	1.219E-11	2.173E-10	4.470E-10	4.867E-10	5.239E-10	4.758E-10	3.508E-10	2.820E-10
WNW	96	5.785E-12	7.966E-11	1.817E-10	3.529E-10	5.268E-10	5.971E-10	4.988E-10	4.306E-10
NW	43	2.721E-20	3.699E-13	1.159E-11	2.636E-11	4.409E-11	7.105E-11	7.838E-11	7.668E-11
NNW	42	9.585E-13	3.222E-11	2.058E-11	1.638E-11	2.528E-11	4.879E-11	6.058E-11	6.316E-11
AVERAGE	2166	1.987E-11	4.318E-10	4.115E-10	4.464E-10	4.911E-10	4.648E-10	3.841E-10	3.205E-10

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	107	1.427E-10	1.280E-10	1.148E-10	1.035E-10	9.348E-11	6.035E-11	4.269E-11	2.516E-11
NNE	464	5.728E-10	5.100E-10	4.544E-10	4.070E-10	3.659E-10	2.330E-10	1.633E-10	9.494E-11
NE	341	3.544E-10	3.197E-10	2.887E-10	2.621E-10	2.386E-10	1.587E-10	1.150E-10	7.055E-11
NNE	192	1.787E-10	1.652E-10	1.525E-10	1.412E-10	1.307E-10	9.168E-11	6.879E-11	4.427E-11
E	194	1.908E-10	1.757E-10	1.616E-10	1.492E-10	1.376E-10	9.554E-11	7.111E-11	4.515E-11
ESE	125	1.464E-10	1.338E-10	1.220E-10	1.115E-10	1.020E-10	6.821E-11	4.927E-11	2.987E-11
SE	85	1.162E-10	1.051E-10	9.518E-11	8.660E-11	7.885E-11	5.224E-11	3.757E-11	2.267E-11
SSE	91	2.881E-10	2.411E-10	2.056E-10	1.779E-10	1.557E-10	9.246E-11	6.263E-11	3.795E-11
S	109	5.881E-10	4.706E-10	3.867E-10	3.242E-10	2.761E-10	1.471E-10	9.167E-11	4.508E-11
SSW	77	3.578E-10	2.772E-10	2.222E-10	1.825E-10	1.529E-10	7.850E-11	4.843E-11	2.408E-11
SW	58	2.314E-10	1.858E-10	1.531E-10	1.287E-10	1.099E-10	6.021E-11	3.879E-11	2.047E-11
WSW	75	4.053E-10	3.294E-10	2.739E-10	2.313E-10	1.984E-10	1.088E-10	6.921E-11	3.518E-11
W	67	2.292E-10	1.898E-10	1.601E-10	1.369E-10	1.187E-10	7.875E-11	5.009E-11	2.569E-11
WNW	96	3.678E-10	3.167E-10	2.526E-10	2.219E-10	1.965E-10	1.251E-10	8.550E-11	4.613E-11
NW	43	7.132E-11	6.562E-11	6.024E-11	5.545E-11	5.107E-11	5.131E-11	3.642E-11	2.526E-11
NNW	42	6.080E-11	5.716E-11	5.321E-11	4.950E-11	4.586E-11	3.166E-11	2.475E-11	2.508E-11
AVERAGE	2166	2.689E-10	2.294E-10	1.973E-10	1.731E-10	1.533E-10	9.585E-11	6.595E-11	3.859E-11

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	107	1.706E-11	1.250E-11	9.631E-12	7.703E-12	6.295E-12	6.264E-12	5.175E-12	
NNE	464	6.397E-11	4.676E-11	3.608E-11	2.891E-11	2.368E-11	1.989E-11	1.696E-11	
NE	341	4.927E-11	3.695E-11	2.902E-11	2.358E-11	1.955E-11	1.657E-11	1.424E-11	
NNE	192	3.176E-11	2.518E-11	2.268E-11	1.835E-11	1.512E-11	1.272E-11	1.085E-11	
E	194	3.206E-11	2.420E-11	2.417E-11	1.928E-11	1.568E-11	1.304E-11	1.100E-11	
ESE	125	2.056E-11	1.691E-11	1.300E-11	1.036E-11	8.428E-12	7.022E-12	5.936E-12	
SE	85	1.557E-11	1.508E-11	1.150E-11	9.100E-12	7.342E-12	6.063E-12	5.080E-12	
SSE	91	2.404E-11	1.654E-11	1.205E-11	9.148E-12	7.113E-12	5.694E-12	4.647E-12	
S	109	2.656E-11	1.744E-11	1.235E-11	9.224E-12	7.121E-12	5.696E-12	4.668E-12	
SSW	77	1.473E-11	1.007E-11	7.397E-12	5.700E-12	4.517E-12	3.692E-12	3.078E-12	
SW	58	1.304E-11	9.153E-12	6.841E-12	5.335E-12	4.284E-12	3.506E-12	2.921E-12	
WSW	75	2.150E-11	1.460E-11	1.048E-11	7.691E-12	5.796E-12	4.089E-12	3.245E-12	
W	67	1.590E-11	1.086E-11	7.914E-12	6.022E-12	4.201E-12	3.018E-12	2.479E-12	
WNW	96	2.902E-11	2.022E-11	1.417E-11	8.706E-12	6.284E-12	4.920E-12	3.937E-12	
NW	43	1.646E-11	1.194E-11	8.757E-12	3.296E-12	2.444E-12	1.878E-12	1.478E-12	
NNW	42	1.568E-11	1.072E-11	7.775E-12	5.866E-12	4.519E-12	3.574E-12	2.872E-12	
AVERAGE	2166	2.545E-11	1.869E-11	1.461E-11	1.114E-11	8.898E-12	7.352E-12	6.160E-12	

Table B-8

Deposition D/Q Factors for Main Stack

BECo 4th Quarter 1994 Elevated General X/Q's
 STACK RELEASE: AVERAGE DEPOSITION RATES (DEPLETED CHI/Q * DEP. VELOCITY MODEL - MET. AND ATOMIC ENERGY 1968) - (1/M2)

SECTOR AVERAGE MODEL

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	67	4.104E-13	1.493E-11	4.310E-11	5.710E-11	6.975E-11	9.267E-11	9.867E-11	9.527E-11
NNE	230	3.835E-12	1.263E-10	1.439E-10	1.378E-10	1.618E-10	2.256E-10	2.499E-10	2.461E-10
NE	279	1.282E-12	8.085E-11	2.197E-10	2.056E-10	2.050E-10	2.400E-10	2.522E-10	2.438E-10
ENE	150	1.529E-12	8.879E-11	1.760E-10	1.440E-10	1.298E-10	1.429E-10	1.515E-10	1.478E-10
E	251	4.455E-12	1.548E-10	1.128E-10	1.080E-10	1.416E-10	2.112E-10	2.349E-10	2.316E-10
ESE	310	1.691E-11	4.955E-10	3.005E-10	2.481E-10	2.698E-10	3.325E-10	3.455E-10	3.289E-10
SE	211	1.895E-11	5.446E-10	3.063E-10	2.425E-10	2.614E-10	3.362E-10	2.628E-10	2.463E-10
SSE	117	2.367E-11	6.642E-10	5.142E-10	5.231E-10	5.441E-10	4.348E-10	3.516E-10	2.889E-10
S	96	3.894E-11	6.101E-10	6.915E-10	9.952E-10	8.246E-10	7.678E-10	6.721E-10	5.319E-10
SSW	138	3.552E-11	6.088E-10	1.257E-09	1.453E-09	2.059E-09	1.694E-09	1.064E-09	7.435E-10
SW	63	1.654E-11	1.367E-10	3.168E-10	5.618E-10	5.076E-10	3.980E-10	2.929E-10	2.243E-10
WSW	63	7.427E-14	2.948E-11	3.349E-10	4.392E-10	5.747E-10	5.073E-10	3.741E-10	2.857E-10
W	41	2.410E-12	3.020E-11	1.565E-10	2.034E-10	2.293E-10	2.142E-10	1.612E-10	1.312E-10
WNW	49	6.807E-15	9.722E-12	1.154E-10	1.728E-10	2.259E-10	2.266E-10	1.796E-10	1.520E-10
NW	68	5.020E-15	6.443E-12	3.765E-11	6.376E-11	9.468E-11	1.336E-10	1.366E-10	1.267E-10
NNW	70	4.597E-13	2.426E-11	4.282E-11	3.636E-11	4.756E-11	7.883E-11	9.205E-11	9.260E-11
AVERAGE	2203	1.031E-11	2.266E-10	2.980E-10	3.495E-10	3.966E-10	3.772E-10	3.075E-10	2.573E-10

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	67	8.785E-11	8.014E-11	7.297E-11	6.668E-11	6.100E-11	4.091E-11	2.956E-11	1.784E-11
NNE	230	2.292E-10	2.106E-10	1.927E-10	1.768E-10	1.621E-10	1.091E-10	7.876E-11	4.744E-11
NE	279	2.262E-10	2.082E-10	1.916E-10	1.769E-10	1.635E-10	1.145E-10	8.597E-11	5.538E-11
ENE	150	1.379E-10	1.274E-10	1.174E-10	1.085E-10	1.002E-10	6.941E-11	5.138E-11	3.229E-11
E	251	2.162E-10	1.992E-10	1.830E-10	1.685E-10	1.551E-10	1.066E-10	7.855E-11	4.910E-11
ESE	310	3.008E-10	2.731E-10	2.480E-10	2.262E-10	2.064E-10	1.380E-10	1.001E-10	6.116E-11
SE	211	2.237E-10	2.024E-10	1.836E-10	1.674E-10	1.530E-10	1.035E-10	7.585E-11	4.700E-11
SSE	117	2.416E-10	2.060E-10	1.785E-10	1.563E-10	1.383E-10	8.490E-11	5.863E-11	3.638E-11
S	96	4.149E-10	3.351E-10	2.779E-10	2.350E-10	2.021E-10	1.125E-10	7.295E-11	3.803E-11
SSW	138	5.561E-10	4.347E-10	3.511E-10	2.902E-10	2.446E-10	1.276E-10	7.941E-11	3.949E-11
SW	63	1.774E-10	1.445E-10	1.205E-10	1.022E-10	8.809E-11	4.943E-11	3.210E-11	1.680E-11
WSW	63	2.250E-10	1.824E-10	1.512E-10	1.275E-10	1.091E-10	5.915E-11	3.717E-11	1.840E-11
W	41	1.087E-10	9.128E-11	7.786E-11	6.725E-11	5.876E-11	3.979E-11	2.530E-11	1.299E-11
WNW	49	1.288E-10	1.105E-10	9.602E-11	8.436E-11	7.480E-11	4.407E-11	3.357E-11	1.844E-11
NW	68	1.134E-10	1.009E-10	8.988E-11	8.056E-11	7.253E-11	5.758E-11	3.887E-11	2.287E-11
NNW	70	8.725E-11	8.073E-11	7.427E-11	6.840E-11	6.294E-11	4.282E-11	3.313E-11	2.669E-11
AVERAGE	2203	2.172E-10	1.867E-10	1.629E-10	1.439E-10	1.283E-10	8.125E-11	5.695E-11	3.376E-11

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	67	1.220E-11	8.942E-12	6.860E-12	5.450E-12	4.415E-12	4.680E-12	3.818E-12	
NNE	230	3.246E-11	2.391E-11	1.852E-11	1.488E-11	1.220E-11	1.025E-11	8.744E-12	
NE	279	3.976E-11	3.030E-11	2.401E-11	1.963E-11	1.633E-11	1.386E-11	1.191E-11	
ENE	150	2.274E-11	1.762E-11	1.513E-11	1.213E-11	9.914E-12	8.295E-12	7.039E-12	
E	251	3.457E-11	2.599E-11	2.540E-11	2.033E-11	1.659E-11	1.385E-11	1.172E-11	
ESE	310	4.238E-11	3.449E-11	2.661E-11	2.127E-11	1.735E-11	1.449E-11	1.227E-11	
SE	211	3.262E-11	2.844E-11	2.121E-11	1.645E-11	1.304E-11	1.062E-11	8.797E-12	
SSE	117	2.335E-11	1.630E-11	1.206E-11	9.296E-12	7.364E-12	5.967E-12	4.940E-12	
S	96	2.302E-11	1.524E-11	1.077E-11	7.991E-12	6.110E-12	4.839E-12	3.929E-12	
SSW	138	2.384E-11	1.605E-11	1.164E-11	8.873E-12	6.971E-12	5.662E-12	4.700E-12	
SW	63	1.047E-11	7.176E-12	5.243E-12	4.000E-12	3.097E-12	2.495E-12	2.051E-12	
WSW	63	1.100E-11	7.296E-12	4.996E-12	3.768E-12	2.937E-12	2.304E-12	1.908E-12	
W	41	8.001E-12	5.454E-12	3.980E-12	3.038E-12	2.215E-12	1.674E-12	1.386E-12	
WNW	49	1.150E-11	7.957E-12	5.471E-12	3.384E-12	2.508E-12	2.004E-12	1.638E-12	
NW	68	1.461E-11	1.030E-11	7.638E-12	4.577E-12	3.564E-12	2.864E-12	2.346E-12	
NNW	70	1.653E-11	1.127E-11	8.198E-12	6.222E-12	4.839E-12	3.877E-12	3.162E-12	
AVERAGE	2203	2.244E-11	1.667E-11	1.298E-11	1.008E-11	8.089E-12	6.734E-12	5.648E-12	

Table B-8

Deposition D/Q Factors for Main Stack

BECo 1994 General Elevated X/Q's

SECTOR AVERAGE MODEL

STACK RELEASE: AVERAGE DEPOSITION RATES (DEPLETED CHI/Q * DEP. VELOCITY MODEL - MRT. AND ATOMIC ENERGY 1968) - (1/M2)

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		.12	.25	.50	.75	1.00	1.50	2.00	2.50
N	442	1.010E-11	2.968E-10	1.829E-10	1.346E-10	1.347E-10	1.502E-10	1.493E-10	1.389E-10
NNE	1368	1.763E-11	5.519E-10	3.893E-10	3.144E-10	3.461E-10	4.273E-10	4.361E-10	4.086E-10
NE	1013	1.087E-11	3.872E-10	3.188E-10	2.362E-10	2.280E-10	2.596E-10	2.682E-10	2.562E-10
NNE	664	8.479E-12	3.072E-10	2.532E-10	1.788E-10	1.642E-10	1.805E-10	1.862E-10	1.782E-10
E	998	1.033E-11	3.314E-10	2.312E-10	1.828E-10	1.965E-10	2.462E-10	2.605E-10	2.513E-10
ESE	880	1.669E-11	4.951E-10	2.636E-10	1.934E-10	2.032E-10	2.416E-10	2.472E-10	2.338E-10
SE	539	1.531E-11	4.982E-10	3.278E-10	2.137E-10	2.013E-10	2.431E-10	1.898E-10	1.779E-10
SSE	400	2.548E-11	7.192E-10	5.207E-10	5.652E-10	5.971E-10	4.716E-10	3.691E-10	2.949E-10
S	399	4.211E-11	7.927E-10	8.027E-10	1.179E-09	9.757E-10	8.829E-10	7.311E-10	5.621E-10
SSW	423	4.800E-11	7.365E-10	9.425E-10	1.119E-09	1.580E-09	1.237E-09	7.769E-10	5.426E-10
SW	258	4.401E-11	3.601E-10	5.408E-10	6.868E-10	6.028E-10	4.636E-10	3.375E-10	2.565E-10
WSW	280	3.693E-11	2.600E-10	3.822E-10	4.486E-10	6.032E-10	5.597E-10	4.195E-10	3.237E-10
W	228	2.252E-11	2.887E-10	3.361E-10	3.387E-10	3.632E-10	3.291E-10	2.457E-10	2.005E-10
WSW	259	1.119E-11	1.431E-10	1.745E-10	2.166E-10	2.905E-10	3.094E-10	2.527E-10	2.168E-10
NW	258	7.224E-12	1.120E-10	7.103E-11	7.176E-11	9.007E-11	1.163E-10	1.177E-10	1.095E-10
NNW	232	1.910E-12	6.293E-11	6.125E-11	5.022E-11	5.342E-11	7.075E-11	7.832E-11	7.748E-11
AVERAGE	8641	2.055E-11	3.964E-10	3.624E-10	3.831E-10	4.144E-10	3.868E-10	3.166E-10	2.643E-10

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		3.00	3.50	4.00	4.50	5.00	7.50	10.00	15.00
N	442	1.256E-10	1.127E-10	1.013E-10	9.153E-11	8.288E-11	5.408E-11	3.861E-11	2.309E-11
NNE	1368	3.695E-10	3.313E-10	2.972E-10	2.679E-10	2.422E-10	1.570E-10	1.114E-10	6.600E-11
NE	1013	2.357E-10	2.151E-10	1.963E-10	1.798E-10	1.649E-10	1.124E-10	8.268E-11	5.177E-11
NNE	664	1.643E-10	1.502E-10	1.371E-10	1.257E-10	1.152E-10	7.831E-11	5.746E-11	3.580E-11
E	998	2.321E-10	2.122E-10	1.938E-10	1.776E-10	1.628E-10	1.105E-10	8.085E-11	5.005E-11
ESE	880	2.133E-10	1.934E-10	1.755E-10	1.599E-10	1.459E-10	9.748E-11	7.068E-11	4.327E-11
SE	539	1.614E-10	1.456E-10	1.316E-10	1.195E-10	1.087E-10	7.208E-11	5.198E-11	3.150E-11
SSE	400	2.413E-10	2.020E-10	1.723E-10	1.491E-10	1.305E-10	7.726E-11	5.229E-11	3.102E-11
S	399	4.342E-10	3.479E-10	2.865E-10	2.408E-10	2.058E-10	1.119E-10	7.140E-11	3.658E-11
SSW	423	4.056E-10	3.171E-10	2.562E-10	2.119E-10	1.787E-10	9.388E-11	5.897E-11	3.005E-11
SW	258	2.021E-10	1.641E-10	1.365E-10	1.156E-10	9.943E-11	5.559E-11	3.629E-11	1.942E-11
WSW	280	2.573E-10	2.102E-10	1.75E-10	1.489E-10	1.283E-10	7.153E-11	4.628E-11	2.423E-11
W	228	1.653E-10	1.387E-10	1.183E-10	1.023E-10	8.935E-11	6.173E-11	3.945E-11	2.036E-11
WSW	259	1.848E-10	1.591E-10	1.385E-10	1.218E-10	1.079E-10	6.288E-11	4.773E-11	2.623E-11
NW	258	9.860E-11	8.829E-11	7.923E-11	7.151E-11	6.474E-11	5.476E-11	3.773E-11	2.371E-11
NNW	232	7.253E-11	6.687E-11	6.137E-11	5.642E-11	5.182E-11	3.504E-11	2.702E-11	2.397E-11
AVERAGE	8641	2.227E-10	1.909E-10	1.661E-10	1.463E-10	1.299E-10	8.165E-11	5.693E-11	3.357E-11

DOWNWIND SECTOR	NO. OBS	DISTANCE FROM RELEASE POINT (MILES)							
		20.00	25.00	30.00	34.95	40.00	45.00	50.00	
N	442	1.581E-11	1.167E-11	9.044E-12	7.270E-12	5.967E-12	5.850E-12	4.881E-12	
NNE	1368	4.498E-11	3.315E-11	2.574E-11	2.073E-11	1.706E-11	1.438E-11	1.230E-11	
NE	1013	3.656E-11	2.759E-11	2.173E-11	1.770E-11	1.469E-11	1.246E-11	1.070E-11	
NNE	664	2.518E-11	1.951E-11	1.679E-11	1.352E-11	1.110E-11	9.325E-12	7.943E-12	
E	998	3.502E-11	2.622E-11	2.454E-11	1.961E-11	1.599E-11	1.335E-11	1.131E-11	
ESE	880	3.005E-11	2.456E-11	1.900E-11	1.523E-11	1.246E-11	1.043E-11	8.864E-12	
SE	539	2.165E-11	1.882E-11	1.421E-11	1.114E-11	8.935E-12	7.349E-12	6.143E-12	
SSE	400	1.985E-11	1.386E-11	1.027E-11	7.935E-12	6.284E-12	5.121E-12	4.251E-12	
S	399	2.218E-11	1.485E-11	1.066E-11	8.044E-12	6.258E-12	5.037E-12	4.149E-12	
SSW	423	1.859E-11	1.280E-11	9.6E-12	7.324E-12	5.835E-12	4.792E-12	4.015E-12	
SW	258	1.238E-11	8.677E-12	6.7E-12	5.043E-12	4.013E-12	3.290E-12	2.747E-12	
WSW	280	1.513E-11	1.047E-11	7.8E-12	5.767E-12	4.475E-12	3.365E-12	2.753E-12	
W	228	1.259E-11	8.595E-12	6.1E-12	4.785E-12	3.415E-12	2.534E-12	2.100E-12	
WSW	259	1.678E-11	1.202E-11	8.845E-12	5.494E-12	4.020E-12	3.197E-12	2.600E-12	
NW	258	1.535E-11	1.101E-11	8.178E-12	4.311E-12	3.357E-12	2.700E-12	2.217E-12	
NNW	232	1.508E-11	1.041E-11	7.637E-12	5.838E-12	4.567E-12	3.673E-12	3.005E-12	
AVERAGE	8641	2.232E-11	1.651E-11	1.291E-11	9.985E-12	8.027E-12	6.679E-12	5.624E-12	