

**Colt Industries**



**Fairbanks Morse  
Engine Division**  
701 Lawton Avenue  
Beloit, Wisconsin 53511  
608/364-4411

March 8, 1984

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Ill. 60137

Attention: Mr. James G. Keppler, Director, Region III


Subject: Colt Industries-Fairbanks Morse Engine Division  
Emergency Diesel Generators  
SNUPPS Contract  
May 2, 1980 Part 21 Report-Failed Engine Thrust Bearing  
Supplement No. 6-Public Service of New Hampshire, Seabrook Unit 1

Gentlemen:

We have completed our field inspection of the Colt-Pielstick Type PC-2 Diesel Generator Sets for Public Service of New Hampshire, Seabrook Unit 1. The inspection was made to written procedures utilizing the revised drawings mentioned in our May 2, 1980 report which provide adequate clearance. The unit is in compliance with the inspection procedure and is free of the reported potential defect.

A copy of this report is being forwarded to the utility involved.

Very truly yours,

  
J. M. Moriarty  
MANAGER UTILITY SALES

JMM:jc

cc: United Engineers & Constructors, Inc.  
P. O. Box 8223  
Philadelphia, PA 19101  
Attention: Mr. D. H. Rhoads  
Project Engineering Manager (Seabrook)

U. S. Nuclear Regulatory Commission  
c/o Document Management Branch  
Washington, D. C. 20555

8403190374 840308  
PDR ADOCK 05000443  
S PDR

A division of the Colt Industries Operating Corp.

MAR 9 1984

IE17  
110