



Carolina Power & Light Company  
P. O. Box 10429  
Southport, NC 28461

MAR 31 1995

SERIAL: BSEP 95-0105

U. S. Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1  
DOCKET NO. 50-325/LICENSE NO. DPR-71  
SUPPLEMENT TO ASME CODE RELIEF REQUEST  
NON-CODE REPAIR OF SERVICE WATER PIPING  
(NRC TAC NO. M89030)

Gentlemen:

By letter dated August 23, 1993 (Serial: BSEP 93-0134), Carolina Power & Light Company (CP&L) requested relief from the requirements of the American Society of Mechanical Engineers (ASME) Code, Section XI in order to perform a temporary non-Code repair to service water system piping for the Brunswick Steam Electric Plant, Unit No. 1. The request applied to a through-wall leak discovered on the Unit 1 6-inch Class 3 service water elbow butt-to-inlet flange weld for valve 1-SW-V116.

Repair of the service water piping was accomplished by replacing the elbow and flange in accordance with the ASME Code, Section XI, IWA/D-4000 and IWA/D-7000. This repair was completed on August 31, 1993.

Please refer questions regarding this submittal to Mr. George Honma at (910) 457-4712.

Sincerely

R. P. Lopriore  
Manager  
Regulatory Affairs

040183

9504040299 950331  
PDR ADDCK 05000325  
P PDR

AO-471/0

Document Control Desk  
BSEP 95-0105 / Page 2

WRM/wrm

cc: Mr. S. D. Ebnetter, Regional Administrator, Region II  
Mr. D. C. Trimble, Jr., NRR Project Manager (Acting) - Brunswick  
Mr. C. A. Patterson, NRC Senior Resident Inspector - Brunswick  
The Honorable H. Wells, Chairman - North Carolina Utilities Commission  
Mr. Billy Walker, Assistant Director - Boiler & Pressure Vessel Division