

Dmb

## WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

March 12, 1984

Mr. J. G. Keppler, Regional Administrator  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Dear Mr. Keppler:

Docket 50-305  
Operating License DPR-43  
Kewaunee Nuclear Power Plant  
I.E. Bulletin 83-08: Electrical Circuit Breakers With an Undervoltage Trip  
Feature in Use in Safety-Related Applications Other Than the Reactor Trip System

In response to the "Required Actions for Holders of Operating Licenses" in the referenced I.E. Bulletin:

A review of electrical circuit breakers used in safety-related applications has verified that there are no circuit breakers with mechanical undervoltage trip attachments, similar to the DB-50 breaker, being used in safety-related applications other than as reactor trip breakers.

Approximately twelve (12) hours of staff time was expended to prepare and review this response.

Very truly yours,

C. W. Giesler  
Vice President - Nuclear Power

CAS/js

cc - Mr. S. A. Varga, US NRC  
Mr. Robert Nelson, US NRC  
Director, Office of I&E

8403200016 840312  
PDR ADCK 05000305  
Q PDR

IEH

MAR 15 1984

110