

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Donald C. Shelton
SENIOR VICE PRESIDENT
NUCLEAR

August 14, 1995
PY-CEI/OEPA-0227 L

Ohio Environmental Protection Agency
P.O. Box 163669
Columbus, Ohio 43216-3669

Gentlemen:

Enclosed are the NPDES monthly report forms for the month of July, 1995.

If you have questions or require additional information, please contact Donna Tizzano at (216) 280-5514.

Very truly yours,

A handwritten signature in dark ink, appearing to be 'DGT', written over a horizontal line.

DGT:sc

Enclosure

cc: NRC Project Manager
NRC Resident Inspectors Office
NRC Document Control Desk
NRC Region III

170012

1023

CLEVELAND ELECTRIC ILLUM CO 3IB00016002 AUG 1995
 NUCLEAR GROUP
 C/O PERRY NUCLEAR POWER PLANT
 10 CENTER ROAD ROOM E210
 NORTH PERRY 44081 LAKE

1 1

OHIO
 63461

002 DISCHARGE FROM CHEMICAL CLEANING
 LAGOON E PLANT

FORM

CEI. PERRY

J.J. GRIMM

1 999	1 999	2 96	3 1	2 96	2 96	2 96
CONDUIT FLOW MGD	PH S.U.	RESIDUE T NFLT MG/L	G&G TOTAL MG/L	PHOS-T P-WET MG/L	COPPER CU.TOT MG/L	IRON FE.TOT MG/L
50050	00400	00530	00550	00665	01042	01045

NO DISCHARGE OCCURRED DURING THE MONTH.

REPORTER

8/14/95

[Handwritten signature]

3IB00016002



4500

ITALY REPORT FORM

CLEVELAND ELECTRIC ILLUM CO 3IB00016001 AUG 1995
 NUCLEAR GROUP
 C/O PERRY NUCLEAR POWER PLANT
 10 CENTER ROAD ROOM E210
 NORTH PERRY 44081 LAKE

1 1

OHIO
 63461

001 DISCHARGE FROM REGENERATE
 NEUTRALIZATION PITS

FORM

CEI, PERRY

J.J. GRIMM

1 1 1 2 3
 999 999 999 96 1

CONDUI FLOW MGD	PH (MAX) S.U.	PH (MIN) S.U.	RESIDUE T NFLT MG/L	O&G TOTAL MG/L
-----------------------	---------------------	---------------------	---------------------------	----------------------

50050	00401	00402	00530	00550
-------	-------	-------	-------	-------

31	AH	AH	AH	
32	AH	AH	AH	
33	AH	AH	AH	
34	AH	AH	AH	
35	0.0210	7.2	7.0	18 AA
36	AH	AH	AH	
37	AH	AH	AH	
38	0.0185	8.8	8.7	
39	AH	AH	AH	
40	AH	AH	AH	
41	AH	AH	AH	
42	AH	AH	AH	
43	AH	AH	AH	
44	AH	AH	AH	
45	AH	AH	AH	
46	0.0174	7.3	7.2	23 AA
47	AH	AH	AH	
48	0.0167	7.1	7.1	14 AA
49	AH	AH	AH	
50	AH	AH	AH	
51	AH	AH	AH	
52	0.0154	8.0	7.7	
53	0.0150	7.2	7.1	
54	AH	AH	AH	
55	AH	AH	AH	
56	AH	AH	AH	
57	AH	AH	AH	
58	AH	AH	AH	
59	0.0179	7.6	7.5	19 AA
60	AH	AH	AH	
61	AH	AH	AH	
	0.1219	53.2	52.3	74 AA
	0.0174	7.6	7.5	18 AA
	0.0210	8.8	8.7	23 AA
	0.0150	7.1	7.0	14 AA

AA - BELOW DETECTABLE LIMIT (5 mg/l for O&G and 2.5 mg/l for RESIDUE)
 AH - SAMPLE NOT TAKEN, NO DISCHARGE PERFORMED THIS DATE

WHITE - ANALYST
 GRAY - REPORTER

R/11/05

3IB00016001



CLEVELAND ELECTRIC ILLUM CO 3IB00016004 AUG 1995
 NUCLEAR GROUP
 C/O PERRY NUCLEAR POWER PLANT
 10 CENTER ROAD ROOM E210
 NORTH PERRY 44081 LAKE

1 1

OHIO
 63461

004 POINT REP OF DISCHARGE PRIOR TO
 ENTRY TO TUNNEL

FORM

CEI. PERRY

J.J. GRIMM

1 1 3 3
 999 999 1 1

WATER CONDUIT CHLOR PH
 TEMP FLOW FREE A
 F. MGD MG/L S.U.

00011 50050 50064 00400


31	75	81.5	0.00	
32	75	74.3	0.00	
33	75	79.3	0.00	
34	77	75.9	0.00	8.2
35	76	94.4	0.00	
36	77	89.8	0.00	
37	78	75.5	0.00	8.2
38	76	75.8	0.00	
39	74	77.1	0.00	
40	75	90.0	0.00	
41	77	75.5	0.00	8.2
42	78	80.4	0.00	
43	81	67.8	0.00	
44	81	78.4	0.00	8.1
45	83	79.8	0.00	
46	82	77.5	0.00	
47	83	77.7	0.00	
48	82	73.4	0.00	8.2
49	82	82.7	0.00	
50	83	82.2	0.00	
51	81	95.2	0.00	8.2
52	80	91.5	0.00	
53	81	93.7	0.00	
54	81	103.1	0.00	
55	82	96.4	0.00	8.2
56	82	98.5	0.00	
57	82	97.6	0.00	
58	82	97.1	0.00	8.2
59	82	94.3	0.00	
60	82	93.8	0.00	
61	82	94.3	0.00	

2467	2635.5	0.00	65.5
80	85.0	0.00	8.2
83	103.1	0.00	8.2
74	67.8	0.00	8.1

NEITHER CHLORINE CONCENTRATION LIMITS. NOR CHLORINATION TIME LIMITS
 WERE EXCEEDED BETWEEN 8/9-8/11.

REPORTER

8/14/95



3IB00016004



CLEVELAND ELECTRIC ILLUM CO 3IB00016800 AUG 1995
 NUCLEAR GROUP
 C/O PERRY NUCLEAR POWER PLANT
 10 CENTER ROAD ROOM E210
 NORTH PERRY 44081 LAKE

1 1

OHIO
 63461

800 INTAKE WATER AT INLET TO PLANT
 FROM LAKE ERIE

FORM

CEI, PERRY

J.J. GRIMM

1
 999

WATER
 TEMP
 F.

00011

01	65
02	69
03	69
04	68
05	69
06	70
07	70
08	70
09	69
10	70
11	70
12	70
13	71
14	72
15	74
16	75
17	76
18	76
19	76
20	76
21	75
22	74
23	75
24	75
25	76
26	76
27	76
28	75
29	76
30	77
31	76

2256
 73
 77
 65

NONE

REPORTER

8/14/95

refm

3IB00016800

