

OPERATING DATA REPORT

DOCKET NO.	50-348
DATE	March 6, 1995
COMPLETED BY	R. D. Hill
TELEPHONE	(334) 899-5156

OPERATING STATUS

- | | | |
|-----|--|----------------------------------|
| 1. | Unit Name: | Joseph M. Farley - Unit 1 |
| 2. | Reporting Period: | February 1995 |
| 3. | Licensed Thermal Power (MWt): | 2,652 |
| 4. | Nameplate Rating (Gross MWe): | 860 |
| 5. | Design Electrical Rating (Net MWe): | 829 |
| 6. | Maximum Dependable Capacity (Gross MWe): | 855.7 |
| 7. | Maximum Dependable Capacity (Net MWe): | 812 |
| 8. | If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: | N/A |
| 9. | Power Level To Which Restricted, If Any (Net MWe): | N/A |
| 10. | Reasons For Restrictions, If Any: | N/A |

Notes

- 1) Cumulative data since 12-01-77, date of commercial operation.

	This Month	Yr. to Date	Cumulative
11. Hours in Reporting Period	672.0	1,416.0	151,176.0
12. Number Of Hours Reactor Was Critical	672.0	1,325.7	120,582.5
13. Reactor Reserve Shutdown Hours	0.0	0.0	3,650.0
14. Hours Generator On-line	672.0	1,305.9	118,759.8
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1,772,517.2	3,441,156.4	305,576,873.4
17. Gross Electrical Energy Generated (MWH)	584,115.0	1,133,102.0	98,546,807.0
18. Net Electrical Energy Generated (MWH)	555,371.0	1,072,826.0	93,072,815.0
19. Unit Service Factor	100.0	92.2	78.6
20. Unit Availability Factor	100.0	92.2	78.6
21. Unit Capacity Factor (Using MDC Net)	101.8	93.3	75.6 93.3
22. Unit Capacity Factor (Using DER Net)	99.7	91.4	74.3
23. Unit Forced Outage Rate	0.0	7.8	6.0
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	N/A		

25. If Shut Down at End Of Report Period, Estimated Date of Startup:	N/A	
26. Units In Test Status (Prior To Commercial Operation):	Forecast	Achieved
Initial Criticality	08/06/77	08/09/77
Initial Electricity	08/20/77	08/18/77
Commercial Operation	12/01/77	12/01/77

OPERATING DATA REPORT

DOCKET NO.	50-364
DATE	March 6, 1995
COMPLETED BY	R. D. Hill
TELEPHONE	(334) 899-5156

OPERATING STATUS

- | | |
|---|---------------------------|
| 1. Unit Name: | Joseph M. Farley - Unit 2 |
| 2. Reporting Period: | February 1995 |
| 3. Licensed Thermal Power (MWt): | 2,652 |
| 4. Nameplate Rating (Gross MWe): | 860 |
| 5. Design Electrical Rating (Net MWe): | 829 |
| 6. Maximum Dependable Capacity (Gross MWe): | 863.6 |
| 7. Maximum Dependable Capacity (Net MWe): | 822 |
| 8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: | N/A |
| 9. Power Level To Which Restricted, If Any (Net MWe): | N/A |
| 10. Reasons For Restrictions, If Any: | N/A |

Notes

- 1) Cumulative data since 07-30-81, date of commercial operation.

	This Month	Yr. to Date	Cumulative
11. Hours in Reporting Period	672.0	1,416.0	119,089.0
12. Number Of Hours Reactor Was Critical	672.0	1,338.4	102,996.1
13. Reactor Reserve Shutdown Hours	0.0	0.0	138.0
14. Hours Generator On-line	672.0	1,326.8	101,549.4
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1,742,523.1	3,470,548.5	259,810,254.2
17. Gross Electrical Energy Generated (MWH)	579,256.0	1,150,948.0	85,205,490.0
18. Net Electrical Energy Generated (MWH)	551,934.0	1,094,568.0	80,816,866.0
19. Unit Service Factor	100.0	93.7	85.3
20. Unit Availability Factor	100.0	93.7	85.3
21. Unit Capacity Factor (Using MDC Net)	99.9	94.0	82.8 94.0
22. Unit Capacity Factor (Using DER Net)	99.1	93.2	81.9
23. Unit Forced Outage Rate	0.0	0.0	3.9
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			
<i>Refueling/Maintenance outage, March 10, 1995. Approximately 39 days.</i>			

25. If Shut Down at End Of Report Period, Estimated Date of Startup:	N/A	
26. Units In Test Status (Prior To Commercial Operation):	Forecast	Achieved
Initial Criticality	05/06/81	05/08/81
Initial Electricity	05/24/81	05/25/81
Commercial Operation	08/01/81	07/30/81