



231 W Michigan, PO Box 2046, Milwaukee, WI 53201-2046

(414) 221-2345

VPNPD-95-067

August 14, 1995

Document Control Desk
U.S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, DC 20555

Ladies/Gentlemen:

DOCKET 50-266
LICENSEE EVENT REPORT 95-006-00
REACTOR TRIP DUE TO LOSS OF GENERATOR EXCITATION
POINT BEACH NUCLEAR PLANT, UNIT 1

Enclosed is Licensee Event Report 95-006-00 for Point Beach Nuclear Plant, Unit 1. This report is provided in accordance with 10 CFR 50.73(a)(2)(iv), "The licensee shall report...any event or condition that resulted in a manual or automatic actuation of any engineered safety feature (ESF), including the reactor protection system (RPS)."

This report describes the event that occurred on July 14, 1995, in which the Unit 1 main electrical generator tripped due to a loss of excitation, which in turn led to a reactor trip from full power.

Please contact us if any further information is required.

Sincerely,

A handwritten signature in cursive script, appearing to read 'Jeffrey S. Link', followed by the word 'for'.

Bob Link
Vice President
Nuclear Power

CAC

Enclosure

cc: NRC Resident Inspector
NRC Resident Administrator, Region III

9508180156 950814
PDR ADDCK 05000266
S PDR

150014

Handwritten initials, possibly 'JE22', in the bottom right corner.