

Number of Personnel (>100 mRem)

Total Man-Rem

Station
EmployeesUtility
EmployeesContract Workers
and OthersStation
EmployeesUtility
EmployeesContract
and Others


Work & Job Function

ROUTINE OPERATIONS & SURVEILLANCE						
Maintenance Personnel	5	0	1	2.3	0	1.3
Operating Personnel	18	0	0	12.5	0	0.1
Health Physics Personnel	14	0	11	10.2	0.1	4.4
Supervisory Personnel	4	0	0	1.0	0	0.1
Engineering Personnel	2	1	3	2.9	0.5	1.4
ROUTINE MAINTENANCE						
Maintenance Personnel	12	0	14	6.2	0	9.9
Operating Personnel	4	0	0	2.0	0	0.1
Health Physics Personnel	10	0	30	9.0	0	25.6
Supervisory Personnel	1	0	0	0.2	0	0.1
Engineering Personnel	0	0	0	0.2	0.4	0.1
INSERVICE INSPECTION						
Maintenance Personnel	1	0	24	1.3	0	15.6
Operating Personnel	2	0	2	3.1	0	0.7
Health Physics Personnel	4	0	1	1.5	0	0.5
Supervisory Personnel	2	0	0	4.0	0.1	0.2
Engineering Personnel	7	1	6	8.2	1.5	2.3
SPECIAL MAINTENANCE						
Maintenance Personnel	43	0	339	22.3	0	399.7
Operating Personnel	11	0	5	3.6	0	5.6
Health Physics Personnel	8	0	14	2.7	0	4.1
Supervisory Personnel	8	0	3	3.1	0	1.3
Engineering Personnel	10	0	3	6.1	0.8	2.0
WASTE PROCESSING						
Maintenance Personnel	3	0	3	1.3	0	2.5
Operating Personnel	0	0	0	0	0	0
Health Physics Personnel	2	0	1	2.6	0	0.3
Supervisory Personnel	0	0	0	0	0	0.1
Engineering Personnel	0	0	0	0	0	0
REFUELING						
Maintenance Personnel	0	0	0	0	0	0
Operating Personnel	0	0	0	0	0	0
Health Physics Personnel	0	0	0	0	0	0
Supervisory Personnel	0	0	0	0	0	0
Engineering Personnel	0	0	0	0	0	0
TOTAL						
Maintenance Personnel	64	0	381	33.4	0	429.0
Operating Personnel	35	0	7	21.2	0	6.5
Health Physics Personnel	38	0	57	26.0	0.1	34.9
Supervisory Personnel	15	0	3	8.3	0.1	1.8
Engineering Personnel	19	2	12	17.4	3.2	5.8
TOTAL	171	2	460	106.3	3.4	478.0

Applicable for the Period January 1, 1983 to December 31, 1983

 12/24
 VI

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 739.8200



February 29, 1984
IP-DQ-710

Docket No. 50-286
License No. DPR-64


Dr. Thomas E. Murley
Regional Administrator
Region 1
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Dear Sir:

The enclosed summary report of personnel radiation exposure by work and job function is provided in accordance with the requirements of the Indian Point No. 3 Technical Specifications and Regulatory Guide 1.16.

The report covers the period January 1, 1983 through December 31, 1983. Please note that the totals listed are based on thermoluminescent dosimeter (TLD) readings. The breakdown of dose by category was based on pocket dosimeter (ion chamber) readings and adjusted to equal the record TLD doses. The TLD readings were approximately 89% of the pocket dosimeter totals for 1983 on an average annual basis.

Very truly yours,


John C. Brons
Resident Manager

DQ:pw

cc: IP-3 Resident Inspector's Office

IE24
1/1