

James A. FitzPatrick
Nuclear Power Plant
P.O. Box 41
Lycoming, New York 13093
315 342.3840



**New York Power
Authority**

Corbin McNeill
Resident Manager

February 28, 1984
JAFP 84-0228

United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Attention: Richard W. Starostecki, Director
Division of Project & Resident Programs

SUBJECT: JAMES A. FITZPATRICK NUCLEAR POWER PLANT
DOCKET NO. 50-333
INSPECTION NO. 33-28

Gentlemen:

In accordance with the provisions of 10CFR 2.201, we are submitting our response to Appendix A Notice of Violation transmitted by your letter dated January 17, 1984. This refers to the inspection conducted by L. Doerflein of your office on November 7, 1983 - December 4, 1983 at the James A. FitzPatrick Nuclear Power Plant.

RESPONSE TO NOTICE OF VIOLATION

A. The Power Authority agrees with this finding.

As reported in Licensee Event Report 83-060/03X-1, the valve actuator in question was replaced with an actuator meeting all required design and Quality Assurance requirements on January 19, 1984. As noted in Inspection 83-28 a review of safety related work for the period of time from approximately January 28, 1978 to August 28, 1981 was performed in response to Inspection 81-07.

A similar review will be conducted for the period of time from the start of commercial operation to January 31, 1978. This review will be completed by September 9, 1984 and will assure that the corrective actions related

8403220081 840315
PDR ADOCK 05000333
g PDR

United States Nuclear Regulatory Commission

Feb. 28, 1984

From: Corbin A. McNeill, Jr.

JAFP 84-0228


Subject: James A. FitzPatrick Nuclear Power Plant Page -2-

Docket No. 50-333

Inspection No. 83-28

to Inspection 81-07 and discussed in Inspection 83-28 have been applied throughout the entire period of commercial operation for the James A. FitzPatrick Nuclear Power Plant. The results of the review will be forwarded to your office upon completion.

Very truly yours,



CORBIN A. McNEILL, JR.
RESIDENT MANAGER

CAM:WVC:fah

Distribution:

Leroy W. Sinclair, NYPA, WPO
J. P. Bayne, NYPA, WPO
R. A. Burns, NYPA, WPO
T. Dougherty, NYPA, WPO
G. M. Wilverding, NYPA, WPO
J. A. Gray, Jr., NYPA, WPO
A. Klausmann, NYPA, WPO
R. J. Converse, NYPA, JAF
M. C. Cosgrove, NYPA, JAF
NRC Resident Inspector, JAF
Document Control Center
NRCI 83-28 File