



Log # TXX-95217  
File # 10200  
Ref. # 10CFR.73(a)(2)(iv)

August 14, 1995

C. Lance Terry  
Group Vice President, Nuclear

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)  
DOCKET NO. 50-445  
ACTUATION OF REACTOR PROTECTION SYSTEM  
LICENSEE EVENT REPORT 445/95-003-00

REF: 1) TU Electric letter logged TXX-95196 from C.L. Terry to  
the NRC dated July 11, 1995

Gentlemen:

Enclosed is Supplement 1 to Licensee Event Report (LER) 95-003-00 for  
Comanche Peak Steam Electric Station Unit 1, "Loss of Both Condensate and  
Both Feedwater Pumps Due to Failure of Non-Safety Related Inverter  
Resulted in a Manual Reactor Trip." The initial LER was submitted on July  
11, 1995 (Reference 1).

This supplement provides additional information on the cause of the event,  
the corrective actions, and the preventive actions.

Sincerely,

*C. L. Terry*  
C. L. Terry

By: *Roger D. Walker*  
Roger D. Walker  
Regulatory Affairs Manager

GLM/cc

cc: Mr. L. J. Callan, Region IV  
Mr. D. F. Kirsch, Region IV  
Resident Inspectors, CPSES

950821008

9508210081 950814  
PDR ADDCK 05000445  
PDR  
S