

**Florida
Power**
CORPORATION

March 19, 1984
3F0384-13

Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
Off Site Power Sources

Reference: Letter to Mr. John F. Stoltz from Mr. G. R. Westafer Dated
March 12, 1984 (3F0384-07).

Dear Sir:

By this letter, Florida Power Corporation (FPC) confirms the information given your staff by telecon on March 16, 1984.

In response to concerns related to paralleling Crystal River 1 and 2 4160 volt busses while supplying the Crystal River 3 (CR-3) cable from either the CR-1 or CR-2 step-up transformer, FPC commits to the following administrative controls.

- A. While supplying the CR-3 cable from the CR-2 step-up transformer, 4160 volt breaker 12B will be "red tagged" open.
- B. While supplying the CR-3 cable from the CR-1 step-up transformer, 4160 volt breaker 22B will be "red tagged" open.
- C. The clearance for this red tag will be made out to the CR-3 shift supervisor on duty.

These controls will assure that the CR-1 and CR-2 4160 volt busses are not inadvertently interconnected.


8403230014 840319
PDR ADDCK 05000302
P PDR

*A015
1/0*

March 19, 1984
3F0384-13
Page 2

Should there be any questions, please contact this office.

Sincerely,

A handwritten signature in cursive script, appearing to read "G. R. Westafer".

G. R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management

AEF/feb

cc: Mr. J. P. O'Reilly
Regional Administrator, Region II
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, GA 30303