

Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379-2000

R.J. Adney
Site Vice President
Sequoyah Nuclear Plant

August 16, 1995


U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT (SQN)
UNIT 1 - DOCKET NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 -
LICENSEE EVENT REPORT 50-327/95011

The enclosed report provides details concerning a power range neutron flux monitor power cable that became disconnected. After returning the channel to operable status, it was determined that the channel had been inoperable longer than allowed by technical specifications. This event is being reported in accordance with 10 CFR 50.73(a)(2)(i)(B) as an operation prohibited by technical specifications.

Sincerely,



R. J. Adney

Enclosure

cc: See page 2

220013

9508220204 950816
PDR ADDCK 05000327
S PDR



U.S. Nuclear Regulatory Commission

Page 2

August 16, 1995

Enclosure

cc (Enclosure):

INPO Records Center
Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, Georgia 30339-5957

Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-2711